

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2021		Day : Monday				Date : 25.10.21						
Probable Maximum Demand :		12000 MW		Probable Maximum Generation :		15057 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 104.92 ft		Today = 104.83 ft		Rule Curve = 108.30 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.10.21 (Yesterday)		25.10.21 (Today)		24.10.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	10		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	50	50	86	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP/HPL	Gas (IPP)	1x235+1x125	360	360	272	226	300	300	134	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	342	350	412	70		
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	300	300	335			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	280	240	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	40	55	55	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	22	50	50			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	17	18	20			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.07+3x1.73	80	80	54	54	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	33	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	70	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	32	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	166	300	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	108	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0			
Dhaka Zone Total			5717	5560	2699	2836	3490	3859	660	730		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	165	160	165	165	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	120	120	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	60	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	247	305	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	50	80	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
47	Dohazari -Kalash- 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	67	51	100			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		Environment issue	
*	Malanha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	4	5	15			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	45	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	18	36	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	38	110	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	77	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total			2442	2382	971	1375	1486	1558	240	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	100	100	55	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	30	30			
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	69	179	220	220			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	250	250	300			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	330	330	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	52	20	55	55			
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+11*6	195	195	153	68	78	78	127	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	117	122	135	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	0	138	138			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	100	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	7	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	20	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	18	18			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	0	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	70	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	58	97	100	100			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impopt (Tripura)	India		160	160	118	136	138	164			
Cumilla Zone Total			3094	3034	1321	1664	2110	2418	445	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	153	153	200	200	49	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	4	3	8	8		Dependable cap. :8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	65	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	115	200	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
83	Tangail 22 MW PP/PPGL	HFO (IPP)	4x6.7	22	22	0	23	22	22			
Mymensingh Zone Total			717	622	302	431	619	567	49	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.10.21 (Yesterday)		25.10.21 (Today)		24.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	44	50	50					
87	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
88	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	60	65	4		Gas Shortage		
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	109	111	110	110	219		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	80	84	84					
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	217	220	220					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341					
97	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	324	323	324	324					
98	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total					2422	2377	1742	1758	1820	1825	225	75		
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	410	400	400					
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	120	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	70	105	105					
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	100			Line Overload		
**	Bheramara (HVDC)	India	1000	1000	716	715	727	727						
Khulna Zone Total					2133	2129	1206	1315	1507	1727	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	27	28	28					
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	66	62	65	65		132	Gas Shortage		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	62	62					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	500	622	622		744	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	150					
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	221	206	220	220					
Barishal Zone Total					2046	2046	621	829	1107	1257	0	876		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30					
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	28	28					
121	Chapsainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	95	95	95					
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40					
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43					
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	17	35					
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.		
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	193	178	210	210	42		Gas Shortage		
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	168	182	220	220					
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	384	365	400	400					
129	Bogra 22 MW PP (BBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	0	43	43	43					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	30	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total					2179	2179	846	1217	1558	1653	423	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	80	80	80	5		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	13	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total					655	605	101	193	201	193	5	359		
Sub-total: Plants in operation					21435	20934	9809.0	11618	13898	15057	2047	2455		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9446	11188	13383	14500						
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0		
Gross Total					22031	20934	9809	11618	13898	15057	2047	2455		
(C) Actual data of 24.10.21 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	11618.00	MW,	at =	19:00 hrs	12	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11188.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11618.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	7831.00	MW,	at =	7:00 hrs	Dhaka	4254	4254	0	Mymensingh	864	864	0
05.	Day-peak Generation (Generation end)	:	9809.00	MW,	at =	12:00 hrs	Chattogram	1251	1251	0	Sylhet	451	451	0
06.	Evening-peak Generation (Generation end)	:	11618.00	MW,	at =	19:00 hrs	Khulna	1307	1307	0	Barishal	309	309	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	1060	1060	0	Rangpur	648	648	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7877.00	MW,	at =	5:00 hrs	Cumilla	1044	1044	0				
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	2042	MW										
c)	Coal supply Limitation	:	5	MW										
b)	Low water level in Kaplai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2455	MW										
10.	Total Energy (Generation + India Import)	:	230.41	MKWh										
	By Gas =	148.129	MKWh											
	By Oil =	46.061	MKWh											
	By Coal =	11.466	MKWh											
	By Solar =	0.795	MKWh											
11.	Total Gas Supplied	:	1173.50	MMCFD										
(D) Forecast of 25.10.21 (Today) Monday :														
01.	Maximum Demand	:	12000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15057	MW	(Generation end)		05.	Total Generation	:	237.99	MKWh			
03.	Maximum Shortage	:	-3057	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka	:	30.9° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation