

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 28-Oct-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4252500	Under maint.
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	22	5561818	Gas shortage
7	Harpur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Harpur 412 MW CCGP	EGCB	1*273+1139	412	330	8266820	Gas shortage
9	Harpur 360MW CCGP(HPL)	IPP	1*235+1125	360	167	4678000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1150	450	250	6194000	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2*110+1110	305	240	6183738	FGMO
13	Madangan 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madangan-55 MW PP(Summit)	ORPP	3*17.08+111.3	55	40	668136	Engine problem
15	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	25	423163	Engine problem
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.80	22	19	369216	
17	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirganj 335 MW CCGP	EGCB	1*217+118	335	200	4941657	ST Under maint.
21	Saganagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	931248	
22	Katohli 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1276560	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	64	140640	Low demand.
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	685881	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	848671	
27	Basia 108MW RPCL	IPP	12*8.775+113.5	0	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	55	1232520	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	826400	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	763900	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	51	425280	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	3466563	
34	Karaniganj 300 MW PP (APR)	IPP	25*11.4	300	0	135958	Reserve.
35	Bramhangon 100 MW PP (Aggr)	IPP	100	100	0	41668	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	97353	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	133	2669180	Engine problem
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	806520	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5*6	104	104	2227200	
40	Manikganj 162MW PP(MPL)	IPP	9*18	162	162	3738240	
41	Spectra Solar Plant Ltd	IPP	35	35	0	169680	
Dhaka area Total				5560	2779	62224000	
42	Chattogram TPP-1	PDB	1*210	180	110	2700000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
45	Taknai 20MW PP (SolarTech)	Renew Solartech Energy	20	20	0	93420	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	739200	
47	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	157	3696365	Low water level & #2 Under m
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2232254	
51	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dobhasari-Kaleshi 100 MW Peaker	PDB	6*17	102	102	410714	
53	Juidah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	100	529680	
54	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	1998720	Engine problem
55	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	18	441264	Engine problem
56	Malancha, Cig, EPZ (United)	IPP	5*8.73+3*9.34	0	19	499680	
57	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	85	418560	
58	Kaptai 7 MW Solar PP	PDB	7*4	7	0	16320	
59	Amwara 300 MW PP (United)	IPP	300 MW	300	304	7158438	
60	Jodiac Power	IPP	3*18.55+1*3.6	54	35	824825	Engine problem
61	Karnaphuli Power Ltd.	IPP	110	110	110	2446353	
62	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	1829760	
63	Anilima Energy Ltd.	IPP	6*21.2	116	91	1081418	Engine problem
Chattogram area Total				2382	1476	27116971	
64	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2036516	Gas shortage
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
67	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	216	4697000	FGMO
68	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	290	7506000	FGMO
69	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	300	7444000	FGMO
70	Ashuganj 50 MW PP	RPCL	4*13.968	45	29	645080	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	51	1182720	
72	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	16	250509	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1150098	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	132	2331781	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	42	98472	Engine problem
76	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	134	3296940	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	200	2274240	
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	504396	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	197460	
80	Impoport (Tripura)	Imported power	0	160	140	2917440	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	597300	Engine problem
82	Jangalia 52 MW PP (Lakdhanav)	IPP	6*8.92	52	43	261192	Engine problem
83	Comilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	4870982	
84	Dauidkandi 200 MW PP (B. Trac)	IPP	15*11.4	200	0	141504	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	413820	
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	97	1352400	Engine problem
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	437400	33 KV feeder fault.
Comilla Area Total				3034	2030	40200458	
88	RPCL 210MW CCGP	IPP	4*35+1*70	202	135	3268000	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	491616	
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	8	164160	
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11850	
92	Mymensingh 200 MW PP (United)	IPP	200	200	180	2961600	Engine problem
93	Jamalpur 115 MW PP (United)	IPP	115 MW	115	85	421200	Engine problem
94	Sulakhal 50 MW Solar PP	IPP	50	50	0	273300	
95	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	396920	
Mymensingh Area Total				822	454	7900426	
96	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	43	1025000	Machine problem
97	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	997800	Machine problem
98	Kushihara 163 MW CCGP (KP)	IPP	1*109+1*54	163	120	3402327	frequency control
99	Shahjibazar 330 MW CCGP	PDB	3*110	330	112	2533000	GT-2 under maint
100	Fenchugonj 51 MW PP (Barakati)	RPP	18*2.90	51	44	1053600	Engine problem
101	Fenchugonj 44MW (Energyprime)	RPP	12*3.34+2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	219216	
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	40	1277376	
104	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	81	1852800	
105	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	219	5029370	
107	Sylhet 20 MW CCGP	PDB	1*20	20	18	383000	
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	509520	
110	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	280	7151500	FGMO
111	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	321	7680000	Gas shortage
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	241560	
113	Bibiyana South 400 MW	PDB	400 MW	385	320	7627400	Gas shortage
Sylhet Area Total				2377	1665	40982469	
114	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
115	Bheramara (HVDC)	Imported power	2*500	1000	713	117232000	
116	Khuila 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
117	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
118	Khuila 225 MW CCGP	NWPGCL	1*150+1*75	230	225	355920	
119	Osapatti 100 MW Peaking PP	PDB	16*8.98	109	0	0	Reserve.
120	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	0	0	Under maint.
121	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	0	0	Reserve.
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1573440	
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	67	363600	Line O/L
Khuila Area Total				2129	1110	12222960	
125	Barsail 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	27	492729	Engine problem
127	Bhola 225 MW CCGP	PDB	2*63+1*68	194	65	1332000	Machine problem
128	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	58	1062809	Gas shortage
129	Payra 1320 MW	BCPCL	2*622	1244	600	10976940	
130	Bhola Nutan Bidut BD LTD	IPP	220	220	107	2134610	
131	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	81	394800	Line O/L
Barisal Area Total				2046	938	16384868	
132	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	165488	
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	21	28364	Engine problem
136	Amnura 50 MW PP(Sinna)	ORPP	7*7.79	50	12	26590	Engine problem
137	Katakhali 50 MW PP (Northern)	ORPP	6*8.9	50	43	32589	Engine problem
138	Katakhali 50 MW Peaking PP	PDB	6*8.7	50	30	44475	Engine problem
139	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
140	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	181	4522291	FGMO
141	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	181	4441436	FGMO
142	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	310	8936545	FGMO
143	Santihar 50 MW Peaking PP	PDB	6*8.7	50	27	48932	Engine problem
144	Bogra 22 MW PP (GBB)	RPP	6*4	22	21	486240	
145	Bogra 20 MW PP (Energyprima)	RPP	5*3.35+2	0	0	0	Contract Expired
146	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	134550	
147	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	305760	
148	Chapainawabganj 100 MW Peaki	PDB	12*8.924	104	96	232024	Engine problem
149	Baghabari 200 MW (Paramou	IPP	200 MW	200	0	0	Reserve.
150	Bogra 113 MW PP (Confidence)	IPP	6*18.55	113	113	2105544	
151	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	1571136	
152	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	28380</	