

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2021		Day : Sunday				Date : 31.10.21					
Probable Maximum Demand :		12000 MW		Probable Maximum Generation :		14758 MW		Rule Curve = 108.90 ft.			
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 104.04 ft		Today = 103.98 ft		30.10.21 (Yesterday)		31.10.21 (Today)			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	81	98	98	27	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	212	197	250	250	163	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	287	395	360	360	17	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	335	335	335		
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	270	220	300	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	25	42	55	55		
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	25	40	40		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	94	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	47	54	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	34	105	105		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	149	149		
24	Kanailghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	222	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	103	133	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300		
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	40	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0		
Dhaka Zone Total			5717	5560	2231	2779	3354	3724	700	677	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	40	40	150	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	115	115	70	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	100	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	304	304	300	300		
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	100	80	100		
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	63	90	90	90		
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	100		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	18		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	10	5	15		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	71	90	90		
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	54		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	6	108	116	116		
Chattogram Zone Total			2442	2382	964	1337	1355	1538	250	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	110	110	110	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	29	29		
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	200	214	200	215		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	340	305	320	330		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	280	320	330		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	51	52	55	55		
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	36	36	36	159	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	46	127	135	135		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	136	138	138		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	8	200	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	20		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.059	200	200	0	0	0	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	114	114		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	47	97	100	100		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impoprt (Tripura)	India		160	160	94	136	138	164		
Cumilla Zone Total			3094	3034	1529	1993	2142	2403	477	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	141	131	180	180	71	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8		Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	75	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	98	191	200	200		
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0		
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	22	22	22		
Mymensingh Zone Total			717	622	329	449	599	547	71	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.10.21 (Yesterday)		31.10.21 (Today)		30.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	43	43		28	GT1 Load gear problem
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	39	50	50	50			
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	65	5		Gas Shortage
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	108	111	110	110	219		Gas Shortage
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	84	81	84			
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	192	220	220			
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24			
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	341	341			
97	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	322	322	324	324			
98	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320			
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
Sylhet Zone Total			2422	2377	1761	1740	1817	1825	226	76		
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	300	300			Under maint.
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	226	220	220			
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	33	105	105	105			
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	0	100			Line Overload
**	Bheramara (HVDC)	India	1000	1000	708	707	731	731				
Khulna Zone Total			2133	2129	861	1088	1406	1626	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	27	28	28			
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65		129	Gas Shortage
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	18	18	22	58			
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	530	620	620		714	Line Overload
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150			
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	219	188	220	220			
Barishal Zone Total			2046	2046	670	863	1065	1251	0	843		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50			
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30			
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27			
121	Chapsainwabarjan 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	97	95	95			
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40			
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43			
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	17	35			
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	210			Under Maint.
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	187	178	210	210	42		Gas Shortage
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	196	186	210	210			
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	419	337	400	400			
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	22	22			
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	52	52			
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	100	113	113	113			
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	75	113	113	113			
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total			2179	2179	1005	1199	1556	1651	423	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80	5		Coal Shortage
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	38	113	113	113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
Rangpur Zone Total			655	605	125	193	201	193	5	359		
Sub-total: Plants in operation			21435	20934	9475.0	11641	13495	14758	2152	2370		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9039	11105	12873	14078				
(B) Plants under long term maintenance/ contract expired												
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
141	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired			596	0	0	0	0	0	0	0	0	
Gross Total			22031	20934	9475	11641	13495	14758	2152	2370		
(C) Actual data of 30.10.21 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	11641.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11105.00	MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11641.00	MW, at = 19:00 hrs	Dhaka	4194	4194	0	Mymensingh	839	839	0
04.	Minimum Generation (Generation end)	:	7764.00	MW, at = 6:00 hrs	Chattogram	1363	1363	0	Sylhet	480	480	0
05.	Day-peak Generation (Generation end)	:	9475.00	MW, at = 12:00 hrs	Khulna	1253	1253	0	Barishal	310	310	0
06.	Evening-peak Generation (Generation end)	:	11641.00	MW, at = 19:00 hrs	Rajshahi	956	956	0	Rangpur	628	628	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:00 hrs	Cumilla	1082	1082	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7775.00	MW, at = 5:00 hrs					Total	11105	11105	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :						
a)	Gas limitation	:	2147	MW	(a) Gas =	149546710	Taka	(c) Coal =	56590797	Taka		
b)	Coal supply Limitation	:	5	MW	(b) Oil =	368961711	Taka	Total =	575099217	Taka		
c)	Low water level in Kaptai lake	:	0	MW								
d)	Plants under shut down/ maintenance	:	2370	MW	14.	Maximum Temperature in Dhaka was : 34.0° C						
e)	Total Energy (Generation + India Import)	:	224.89	MKWh	15.	Export through East-West interconnections :						
	By Gas =	140.294	MKWh	By Oil =	49.318	MKWh						
	By Coal =	12.167	MKWh	By Hydro =	2.589	MKWh						
	By Solar =	0.811	MKWh									
11.	Total Gas Supplied	:	1116.11	MMCFD								
(D) Forecast of 31.10.21 (Today) Sunday :												
01.	Maximum Demand	:	12000	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14758	MW (Generation end)	05.	Total Generation : 231.83 MKWh						
03.	Maximum Shortage	:	-2758	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 29.5° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation