

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month November, 2021		Day : Sunday				Date : 07.11.21						
Probable Maximum Demand :		10400 MW		Yesterday = 103.37 ft		Probable Maximum Generation :		14099 MW		Rule Curve = 108.40 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.11.21 (Yesterday)		07.11.21 (Today)		06.11.21 Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	13	22	30	30	86	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	214	174	250	250	186	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	380	400	400	400	12		
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	300	335	335	335			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	140	120	140	150			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	47	55	55	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	25	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	32	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	21	20	21			
18	Summit Power (Madhaboli+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	53	56	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	0	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	104	117	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	0	50	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	91	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0			
Dhaka Zone Total			5717	5560	1877	2210	3152	3533	782	672		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	103	102	73	103	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	29	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	17	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	124	303	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	80	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	48	68	51	100			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			4	14	10	15			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	70	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	17	33	116	116			
Chattogram Zone Total			2442	2382	753	1148	1419	1498	240	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	70	80	80	100	55	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	27	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	201	216	200	215			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	335	275	320	340			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	280	320	340			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	5	56	20	20			
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	83	135	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	135	138	138			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	68	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	22	20	20			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x31.015+1x1.059	200	200	0	0	0	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	114	100	100			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impopt (Tripura)	India		160	160	96	100	138	164			
Cumilla Zone Total			3094	3034	1295	1589	2041	2344	505	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	150	132	150	150	70	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	8	8	8			Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	40	170	200	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22			
Mymensingh Zone Total			717	622	262	332	569	517	70	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.11.21 (Yesterday)		07.11.21 (Today)		06.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	10	30	30	30		40	GT1 Load gear problem
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	8	53	50	50			
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163			
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11			
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	63	60	65	3		Gas Shortage
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	115	122	131	132	208		Gas Shortage
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	80	81	84			
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220			
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24			
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	280	341	341			
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	352	240	324	400			
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	100	260	0	0			
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
Sylhet Zone Total			2422	2377	1436	1585	1493	1578	231	100		
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	205	270	300			
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	220	220			
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105			
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0	100			Line Overload
**	Bheramara (HVDC)	India	1000	1000	719	719	733	733				
Khulna Zone Total			2133	2129	939	1044	1378	1628	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	13	21	28	30			
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	78	78	90	90		116	Gas Shortage
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	12	12			
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	270	390	620	620		854	Line Overload
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	130	191	220	220			
Barisal Zone Total			2046	2046	491	680	1080	1232	0	970		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50			
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	1	0	30	30			
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25			
121	Chapsainwabarjan 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	95	95			
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40			
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	40			
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	17	35			
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	45	115	130	150	105		Gas Shortage
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	167	150	200	200			
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	421	364	400	400			
129	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	15	20	22	22			
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	9	11	11	11			
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	8	0	52	52			
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113			
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	109	113	113			
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
Rajshahi Zone Total			2179	2179	670	882	1464	1576	486	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	82	80	80	3		Coal Shortage
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	107	113	113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
Rangpur Zone Total			655	605	122	189	201	193	3	359		
Sub-total: Plants in operation			21435	20934	7845.0	9659	12797	14099	2317	2516		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					7492	9224	12220	13464				
(B) Plants under long term maintenance/ contract expired												
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired			596	0	0	0	0	0	0	0	0	
Gross Total			22031	20934	7845	9659	12797	14099	2317	2516		
(C) Actual data of 06.11.21 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	: 9659.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9224.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9659.00 MW, at = 19:00 hrs	Dhaka	3560	3560	0	Mymensingh	716	716	0		
04.	Minimum Generation (Generation end)	: 6094.00 MW, at = 5:00 hrs	Chattogram	1076	1076	0	Sylhet	359	359	0		
05.	Day-peak Generation (Generation end)	: 7845.00 MW, at = 12:00 hrs	Khulna	1058	1058	0	Barisal	252	252	0		
06.	Evening-peak Generation (Generation end)	: 9659.00 MW, at = 19:00 hrs	Rajshahi	869	869	0	Rangpur	557	557	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	777	777	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6465.00 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation	: 2314 MW	13.	Fuel cost : (a) Gas = 140099935 Taka (c) Coal = 47449558 Taka								
b)	Coal supply Limitation	: 3 MW		(b) Oil = 168924700 Taka Total = 356474194 Taka								
c)	Low water level in Kaptai lake	: 0 MW										
d)	Plants under shut down/ maintenance	: 2516 MW	14.	Maximum Temperature in Dhaka was : 30.1° C								
e)	Total Energy (Generation + India Import)	: 187.89 MKWh	15.	Export through East-West interconnections :								
	By Gas = 132.340 MKWh	By Oil = 23.229 MKWh		At evening peak-hour : -74 MW, at 19:00 hrs								
	By Coal = 10.089 MKWh	By Hydro = 2.363 MKWh		Maximum : -140 MW, at 18:30 hrs								
	By Solar = 0.775 MKWh			Energy : 0.2315 MKWh								
11.	Total Gas Supplied	: 1020.24 MMCFD										
(D) Forecast of 07.11.21 (Today) Sunday :												
01.	Maximum Demand	: 10400 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14099 MW (Generation end)	05.	Total Generation : 202.31 MKWh								
03.	Maximum Shortage	: -3699 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 28.3° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation