

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month November, 2021														Day : Saturday				Date : 13.11.21					
Probable Maximum Demand :				10500 MW		Probable Maximum Generation :				14233 MW		Rule Curve = 107.80 ft.											
Water Level of Kaptai Lake at 06:00 AM														Yesterday = 102.64 ft		Today = 102.56 ft.		12.11.21 (Yesterday)		13.11.21 (Today)		Status of Machines under shut-down/ Maintenance	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.11.21 (Yesterday) Actual Peak Generation (MW)		13.11.21 (Today) Probable Peak Generation (MW)		12.11.21 (Yesterday) Gen. shortfall for :		Description/ Remarks	Probable start-up date											
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)													
<b>(A) Plants in operation:</b>																							
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work											
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work											
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80													
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			Under maint.											
4	Ghorasah 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage											
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem											
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage											
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	295	336	300	360	24		Gas Shortage											
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	250	250	250	200		Gas Shortage											
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling											
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	302	398	400	400		14												
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage											
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	265	262	335	335														
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	275	265	260	300														
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55														
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	0	25	25														
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	102	102														
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	16	16														
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	43	53	55	55														
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33														
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33														
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	51	51														
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	35	105	105														
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	149	149														
24	Kanailaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54														
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	300														
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	32	149	149														
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300														
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100														
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100														
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	0	35	55	55														
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55														
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	0	104	104														
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	162	162														
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	10	0	30	0														
<b>Dhaka Zone Total</b>				<b>5717</b>	<b>5560</b>	<b>1725</b>	<b>2062</b>	<b>3288</b>	<b>3758</b>	<b>642</b>	<b>674</b>												
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	80	40	70	70		40	Unit 2 under overhauling											
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110	70		Gas Shortage											
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage											
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0														
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25														
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0														
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	11	0	50	50														
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	32	105	105	105														
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.											
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval											
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	158	286	300	300														
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	80	100														
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	60	50	80	80														
47	Dohazari-Kalash-100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85														
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue											
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	21														
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			16	17	10	30														
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90														
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54														
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	50	110	110	110														
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	10	0	100	100														
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	0	116	116														
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>606</b>	<b>886</b>	<b>1396</b>	<b>1446</b>	<b>250</b>	<b>415</b>												
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55		Gas Shortage											
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage											
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage											
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	29	29														
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	167	210	200	220														
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	360	320	330														
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	315	320	330	330														
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	10	5	30	30														
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage											
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51														
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	0	130	130														
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50														
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	138	136	138														
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200														
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22														
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11														
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	25	33														
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43														
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	22	22														
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x31.915+1x1.999	200	200	0	0	0	200														
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114														
74	Chowmuhanj 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	17	46	113	113														
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17														
**	Impopt (Tripura)	India		160	160	98	108	138	164														
<b>Cumilla Zone Total</b>				<b>3094</b>	<b>3034</b>	<b>1325</b>	<b>1459</b>	<b>2069</b>	<b>2335</b>	<b>505</b>	<b>0</b>												
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	130	158	150	160	44		Gas Shortage											
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22														
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. :8MW											
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	0	115	115														
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	35	120	200	200														
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0														
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0														
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22														
<b>Mymensingh Zone Total</b>				<b>717</b>	<b>622</b>	<b>236</b>	<b>300</b>	<b>561</b>	<b>519</b>	<b>44</b>	<b>0</b>												

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.11.21 (Yesterday)		13.11.21 (Today)		12.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	47	50	50				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	110	163	163				
88	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	60	65	26		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	162	160	162	168		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	83	80	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	172	212	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	320	341	341				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	329	389	324	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	103	80	80	80		20	Under project work	
<b>Sylhet Zone Total</b>					<b>2422</b>	<b>2377</b>	<b>1358</b>	<b>1518</b>	<b>1571</b>	<b>1658</b>	<b>214</b>	<b>130</b>	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	295	370	350	370				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload	
103	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	731	731	750	750				
<b>Khulna Zone Total</b>					<b>2133</b>	<b>2129</b>	<b>1026</b>	<b>1101</b>	<b>1255</b>	<b>1715</b>	<b>0</b>	<b>0</b>	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	22	28	30				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	89	90	90	90		104	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	12	12	12				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	350	620	620		894	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	151	219	220	220				
<b>Barisal Zone Total</b>					<b>2046</b>	<b>2046</b>	<b>567</b>	<b>693</b>	<b>1080</b>	<b>1232</b>	<b>0</b>	<b>998</b>	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	9	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	18	18	18				
121	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	95	95				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	8				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	20	33				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	153	141	190	190	79		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0			Under Maint.	
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	421	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	0	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	70	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2179</b>	<b>2179</b>	<b>520</b>	<b>772</b>	<b>1320</b>	<b>1375</b>	<b>460</b>	<b>0</b>	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	82	80	82	3		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	34	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabala 8 MW Solar PP (Symba Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>124</b>	<b>116</b>	<b>201</b>	<b>195</b>	<b>3</b>	<b>359</b>	
<b>Sub-total: Plants in operation</b>					<b>21435</b>	<b>20934</b>	<b>7487.0</b>	<b>8907</b>	<b>12741</b>	<b>14233</b>	<b>2118</b>	<b>2576</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>					<b>7257</b>	<b>8633</b>	<b>12349</b>	<b>13795</b>					
<b>(B) Plants under long term maintenance/ contract expired</b>													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>596</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>22031</b>	<b>20934</b>	<b>7487</b>	<b>8907</b>	<b>12741</b>	<b>14233</b>	<b>2118</b>	<b>2576</b>	
<b>(C) Actual data of 12.11.21 (Yesterday) Friday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 8907.00 MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 8633.00 MW, at = 19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 8907.00 MW, at = 19:30 hrs	Dhaka	MW	MW	MW	Mymensingh	MW	MW	MW			
04.	Minimum Generation (Generation end)	: 6821.00 MW, at = 9:00 hrs	Dhaka	3049	3049	0	Mymensingh	679	679	0			
05.	Day-peak Generation (Generation end)	: 7487.00 MW, at = 12:00 hrs	Chattogram	1181	1181	0	Sylhet	360	360	0			
06.	Evening-peak Generation (Generation end)	: 8907.00 MW, at = 19:30 hrs	Khulna	973	973	0	Barisal	255	255	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs	Rajshahi	801	801	0	Rangpur	504	504	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6283.00 MW, at = 5:00 hrs	Cumilla	831	831	0	Total	8633	8633	0			
09.	Generation shortfall at evening peak due to :		13.	Fuel cost :	(a) Gas = 144550949 Taka (c) Coal = 49375204 Taka								
a)	Gas limitation	: 2115 MW		(b) Oil = 152643843 Taka	Total = 346569995 Taka								
c)	Coal supply Limitation	: 3 MW											
b)	Low water level in Kapitai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2576 MW	14.	Maximum Temperature in Dhaka was :	29.2° C								
10.	Total Energy (Generation + India Import)	: 187.69 MKWh	15.	Export through East-West interconnections :									
	By Gas = 135.780 MKWh	By Oil = 21.014 MKWh		At evening peak-hour	: 0 MW, at 19:30 hrs								
	By Coal = 10.512 MKWh	By Hydro = 1.792 MKWh		Maximum	: -112 MW, at 18:00 hrs								
	By Solar = 0.990 MKWh			Energy	: 0.173 MKWh								
11.	Total Gas Supplied	: 1020.07 MMCFD											
<b>(D) Forecast of 13.11.21 (Today) Saturday :</b>													
01.	Maximum Demand	: 10500 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14233 MW (Generation end)	05.	Total Generation	: 221.26 MKWh								
03.	Maximum Shortage	: -3733 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 25.8° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)  
Deputy Secretary, Generation