

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month November, 2021		Day : Tuesday				Date : 16.11.21						
Probable Maximum Demand :		9800 MW		Probable Maximum Generation :		13864 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 102.39 ft		Today = 102.27 ft		Rule Curve = 107.50 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.11.21 (Yesterday)		16.11.21 (Today)		15.11.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	106	100	100	2	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	336	337	340	350	23	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	387	351	400	400	61		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	84	100	100	116	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		Under maint.	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	255	315	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	55	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	10	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	21	20	21			
18	Summit Power (Madhaboli+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	53	42	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	6	0	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	52	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	16	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	44	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	130	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	30	94	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	124	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	4	0	30	0			
Dhaka Zone Total			5717	5560	1913	2264	3127	3508	551	721		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	108	110	110	110	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	110	110	110	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	15	43	43			
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	34	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	265	303	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	80	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	100	80	100			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	21			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	2	10	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	62	108	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	55	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	17	116	116			
Chattogram Zone Total			2442	2382	847	1095	1429	1479	250	415		
55	a) Ashuganj TPP Unit-3	Gas (APSCS)	1 x 150	150	135	135	130	100	100	5	Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCS)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCS)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCS)	14x3.968	53	45	29	29	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCS)	1x142+1*75	221	221	184	200	200	220			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCS)	1x360	360	360	0	0	300	300			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCS)	1x361	360	360	310	330	330	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	40	5	5			
61	Ashuganj 195MW PP (APSCS-United)	Gas (IPP)	20*9.73+1*16	195	195	63	73	8	8	122	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	28	78	130	133			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	136	136	138			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	46	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	20	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	22	22			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x31.015+1x1.059	200	200	0	0	0	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	65	113	113			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impopt (Tripura)	India		160	160	94	96	138	164			
Cumilla Zone Total			3094	3034	1169	1371	2061	2312	390	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	174	183	160	200	19	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	8	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	100	125	200	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22			
Mymensingh Zone Total			717	622	358	336	571	559	19	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.11.21 (Yesterday)		16.11.21 (Today)		15.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	30	30	30		60		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	45	50	50				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	50	60	65	16		Gas Shortage	
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	160	161	160	160	169		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	84				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	165	0	0				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	401	413	324	400				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	60	70	0	80		30	Under project work	
Sylhet Zone Total					2422	2377	1546	1563	1283	1448	205	100	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	310	380	350	410				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	50	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	733	731	745	745					
Khulna Zone Total					2133	2129	1043	1161	1250	1750	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	20	28	30				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	92	91	90	90		103	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	370	620	620		874	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	170	220	220	220				
Barisal Zone Total					2046	2046	537	712	1080	1232	0	977	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
115	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	8	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	18	18	18				
120	Chapsainwabarjan 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	95	95				
121	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	0	40				
122	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	16				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	20	35				
124	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
125	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	163	191	190	190	29		Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0			Under Maint.	
127	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	408	412	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	18	18				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	70	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	102	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2179	2179	705	865	1316	1381	410	0	
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	81	80	82	4		Coal Shortage	
134	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	71	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	85	152	201	195	4	359	
Sub-total: Plants in operation					21435	20934	8203.0	9519	12318	13864	1829	2572	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8100	9399	12162	13689			
(B) Plants under long term maintenance/ contract expired													
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0	
Gross Total					22031	20934	8203	9519	12318	13864	1829	2572	
(C) Actual data of 15.11.21 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	: 9519.00 MW, at = 18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 9399.00 MW, at = 18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 9519.00 MW, at = 18:00 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)	: 6141.00 MW, at = 5:00 hrs	Dhaka	3519	3519	0	Mymensingh	717	717	0			
05.	Day-peak Generation (Generation end)	: 8203.00 MW, at = 12:00 hrs	Chattogram	1347	1347	0	Sylhet	358	358	0			
06.	Evening-peak Generation (Generation end)	: 9519.00 MW, at = 18:00 hrs	Khulna	1043	1043	0	Barisal	235	235	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 18:00 hrs	Rajshahi	864	864	0	Rangpur	591	591	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6310.00 MW, at = 5:00 hrs	Cumilla	725	725	0	Total	9399	9399	0			
09.	Generation shortfall at evening peak due to :		13.	Fuel cost :	(a) Gas = 138877542 Taka	(c) Coal = 46861611 Taka							
a)	Gas limitation	: 1825 MW		(b) Oil = 195560443 Taka	Total = 381299595 Taka								
d)	Coal supply Limitation	: 4 MW											
b)	Low water level in Kaptai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2572 MW											
10.	Total Energy (Generation + India Import)	: 189.15 MKWh	14.	Maximum Temperature in Dhaka was :	24.6° C								
	By Gas = 130.149 MKWh	By Oil = 28.064 MKWh	15.	Export through East-West interconnections :									
	By Coal = 9.973 MKWh	By Hydro = 2.635 MKWh		At evening peak-hour	: -30 MW, at 18:00 hrs								
	By Solar = 0.449 MKWh			Maximum	: -30 MW, at 18:00 hrs								
11.	Total Gas Supplied	: 1003.45 MMCFD		Energy	: 0.086 MKWh								
(D) Forecast of 16.11.21 (Today) Tuesday :													
01.	Maximum Demand	: 9800 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 13864 MW (Generation end)	05.	Total Generation	: 194.73 MKWh								
03.	Maximum Shortage	: -4064 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 28.9° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzl Islam Shaker)
Deputy Secretary, Generation