

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month November, 2021													Day: Sunday		Date: 21.11.21				
Probable Maximum Demand :				10200 MW				Probable Maximum Generation :				14618 MW							
Water Level of Kaptai Lake at 06:00 AM													Yesterday = 101.85 ft		Today = 101.73 ft		Rule Curve = 107.00 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.11.21 (Yesterday)		21.11.21 (Today)		Gas/water/Coal limitation (MW)	Machines shut down	Status of Machines under shut-down/ Maintenance	Probable start-up date							
					Actual Peak Generation (MW)		Probable Peak Generation (MW)												
					Day	Evening	Day	Evening											
(A) Plants in operation:																			
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work							
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work							
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	180	180	180	10									
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			Under maint.							
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	99	99	100	102	9		Gas Shortage							
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem							
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage							
7	Haripur 360MW CCPP/HPL	Gas (IPP)	1x235+1x125	360	360	303	332	330	350	28		Gas Shortage							
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180		Gas Shortage							
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling							
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	348	367	350	412	45		Gas Shortage							
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	100	100	210		Gas Shortage							
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	199	221	221	221	114		Gas Shortage							
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	246	275	300	300										
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55										
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	20	0	25	25										
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	64	102	102										
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	20	21										
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+3x4.73	80	80	34	38	55	55										
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	25	25	33	33										
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	25	33	33	33										
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	4	24	51	51										
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	0	105	105										
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	16	149	149										
24	Kanalgat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54										
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	250	300										
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	16	149	149										
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300										
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100										
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100										
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55										
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55										
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	53	104	104										
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	105	162	162	162										
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0										
Dhaka Zone Total			5717	5560	2051	2301	3488	3943	616	660									
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	114	115	115		40	Unit 2 under overhauling							
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110	70		Gas Shortage							
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage							
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0										
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25										
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0										
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	5	43	43										
41	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	12	56	105	105										
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.							
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval							
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	139	297	300	300										
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	80	100										
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	64	100	80	100										
47	Dohazari - Kalash- 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	51	85										
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue							
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	21	21										
*	Malanha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34			2	2	15	30										
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90										
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	44	54	54										
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	28	64	110	110										
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	0	100	100	100										
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	0	0	116	116										
Chattogram Zone Total			2442	2382	615	995	1440	1504	250	415									
	a) Ashuganj TPP Unit- 3	Gas (APSCS)	1 x 150	150	135	80	80	80	80	55		Gas Shortage							
55	b) Ashuganj TPP Unit- 4	Gas (APSCS)	1 x 150	150	129	0	0	0	0	129		Gas Shortage							
	c) Ashuganj TPP Unit- 5	Gas (APSCS)	1 x 150	150	134	0	0	0	0	134		Gas Shortage							
56	Ashuganj 50 MW PP	Gas (APSCS)	14x3.968	53	45	29	29	29	29										
57	Ashuganj 225 MW CCPP	Gas (APSCS)	1x142+1x75	221	221	180	194	220	220										
58	Ashuganj 450 MW CCPP(South)	Gas (APSCS)	1x360	360	360	270	320	340	340										
59	Ashuganj 450 MW CCPP(North)	Gas (APSCS)	1x361	360	360	260	325	330	330										
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	5	56	20	55										
61	Ashuganj 195MW PP (APSCS-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage							
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51										
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	43	130	133										
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50										
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	135	135	136	138										
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	24	200	200										
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22										
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11										
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33										
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52										
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	9	22	22										
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	0	0										
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114										
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	87	111	113	113										
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	11	17	17										
**	Impoprt (Tripura)	India		160	160	92	112	138	164										
Cumilla Zone Total			3094	3034	1288	1567	2116	2382	505	0									
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	158	172	205	205	30		Gas Shortage							
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	22	22										
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW							
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	20	115	115										
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	110	170	200	200										
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0										
82	Suitkathi 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0										
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22										
Mymensing Zone Total			717	622	342	382	616	564	30	0									

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.11.21 (Yesterday)		21.11.21 (Today)		20.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	30	30	30		40	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	25	50	50				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	62	62				
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	161	160	160	160	170		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	80	84				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	20	150	165	165				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	342	402	324	400				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	60	70	80	80				
Sylhet Zone Total					2422	2377	1232	1518	1548	1628	190	100	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	310	340	400	410	70		Gas Shortage	
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	60	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Bheramara (HVDC) India			1000	1000	713	714	727	727				
Khulna Zone Total					2133	2129	1023	1114	1282	1732	70	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	22	28	30				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	50	50	90	90		144	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	260	350	620	620		894	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	142	207	220	220				
Barishal Zone Total					2046	2046	480	640	1080	1232	0	1038	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	27	27	27	27				
121	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	30	95	95				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	20	35				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Undir Overhauling	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	164	176	200	200	44		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	304	417	400	400				
129	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	18	22	18	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	85	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2179	2179	641	932	1335	1438	435	210	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	84	79	80	82	6		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	90	149	201	195	6	359	
Sub-total: Plants in operation					21435	20934	7762.0	9598	13106	14618	2102	2782	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					7633	9439	12888	14376					
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0	
Gross Total					22031	20934	7762	9598	13106	14618	2102	2782	
(C) Actual data of 20.11.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 9598.00 MW, at = 18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 9430.00 MW, at = 18:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9598.00 MW, at = 18:00 hrs		Dhaka	3552	3552	0	Mymensingh	718	718	0		
04.	Minimum Generation (Generation end)	: 5815.00 MW, at = 5:00 hrs		Chattogram	1301	1301	0	Sylhet	359	359	0		
05.	Day-peak Generation (Generation end)	: 7762.00 MW, at = 12:00 hrs		Khulna	1047	1047	0	Barishal	242	242	0		
06.	Evening-peak Generation (Generation end)	: 9598.00 MW, at = 18:00 hrs		Rajshahi	863	863	0	Rangpur	598	598	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 18:00 hrs		Cumilla	759	759	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6240.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2096 MW	13.	Fuel cost :	(a) Gas = 140968522 Taka	(c) Coal = 46604483 Taka							
d)	Coal supply Limitation	: 6 MW		(b) Oil = 143198908 Taka		Total = 330771913 Taka							
b)	Low water level in Kapitai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2782 MW	14.	Maximum Temperature in Dhaka was :	30.4° C								
10.	Total Energy (Generation + India Import)	: 183.46 MKWh	15.	Export through East-West interconnections :									
	By Gas = 133.286 MKWh	By Oil = 20.222 MKWh		At evening peak-hour	: -30 MW, at 18:00 hrs								
	By Coal = 9.896 MKWh	By Hydro = 2.742 MKWh		Maximum	: -144 MW, at 8:00 hrs								
	By Solar = 0.554 MKWh			Energy	: 0.2055 MKWh								
11.	Total Gas Supplied	: 1049.63 MMCFD											
(D) Forecast of 21.11.21 (Today) Sunday :													
01.	Maximum Demand	: 10200 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14618 MW (Generation end)	05.	Total Generation	: 194.96 MKWh								
03.	Maximum Shortage	: -4418 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 29.7° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation