

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month November, 2021		Day : Thursday				Date : 25.11.21						
Probable Maximum Demand :		9900 MW		Probable Maximum Generation :		13615 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 101.39 ft		Today = 101.33 ft		Rule Curve = 106.60 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.11.21 (Yesterday)		25.11.21 (Today)		24.11.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	190	190	190			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	93	168	200	200	192	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	300	322	350	350			
11	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	150	150	150	150			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	24	24	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	21	21	21			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	43	45	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	20	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	280	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	101	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0			
Dhaka Zone Total			5717	5560	1701	2312	2848	3168	1045	660		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	81	74	75	75	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	45	46	46			
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	286	300	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	30	80	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
47	Dohazari -Kalash-100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80			
48	Hafiznari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20			
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			3	7	10	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	5	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	110	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	70	116	116			
Chattogram Zone Total			2442	2382	999	1196	1417	1441	250	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	90	90	90	90	44	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	200	210	220	220			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	295	340	340			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under maint.	
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	51	56	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	155	148	160	160	47	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	10	25	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	120	125			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	88	90	90			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	100	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	0	10			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	0	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	10	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	69	106	113	113			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impopt (Tripura)	India		160	160	100	103	138	164			
Cumilla Zone Total			3094	3034	1178	1395	1915	2146	355	360		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	132	143	160	160	59	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	80	130	200	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22			
Mymensingh Zone Total			717	622	256	303	571	519	59	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.11.21 (Yesterday)		25.11.21 (Today)		24.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	GT1 Load gear problem
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50			
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	32	33	33			
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	150	149	160	160	181		Gas Shortage
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	84			
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	218	220	220			
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24			
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	285	341	341			
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	251	401	400	400			
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	60	60	100	100			
Sylhet Zone Total					2422	2377	1404	1559	1682	1686	201	88
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	320	410	410			
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105			
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			
**	Bheramara (HVDC)	India		1000	1000	725	720	742	742			
Khulna Zone Total					2133	2129	1092	1145	1307	1747	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	25	25	25			
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	50	50	90	90		144	Under maint.
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	42	42			
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	360	620	620		884	Line Overload
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	160	212	220	220			
Barisal Zone Total					2046	2046	517	658	1107	1257	0	1028
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	50	50			
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30			
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27			
121	Chapsainwabarjan 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	33	95	95			
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	0	40			
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	50			
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	20	35			
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Under Overhauling
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	175	173	200	220	47		Gas Shortage
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	399	374	400	400			
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52			
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113			
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113			
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
Rajshahi Zone Total					2179	2179	716	951	1339	1458	438	210
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	80			
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	113	113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
Rangpur Zone Total					685	605	119	149	201	193	0	359
Sub-total: Plants in operation					21435	20934	7982.0	9668	12387	13615	2348	3120
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							7724	9356	11987	13176		
(B) Plants under long term maintenance/ contract expired												
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0
Gross Total					22031	20934	7982	9668	12387	13615	2348	3120
(C) Actual data of 24.11.21 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	: 9668.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9356.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9668.00 MW, at = 19:00 hrs	Dhaka	3721	3721	0	Mymensingh	703	703	0		
04.	Minimum Generation (Generation end)	: 6582.00 MW, at = 5:00 hrs	Chattogram	1062	1062	0	Sylhet	339	339	0		
05.	Day-peak Generation (Generation end)	: 7982.00 MW, at = 12:00 hrs	Khulna	1057	1057	0	Barisal	241	241	0		
06.	Evening-peak Generation (Generation end)	: 9668.00 MW, at = 19:00 hrs	Rajshahi	883	883	0	Rangpur	586	586	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	764	764	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6354.00 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation	: 2348 MW	13.	Fuel cost :		(a) Gas = 137667764 Taka	(c) Coal = 48071182 Taka					
b)	Coal supply Limitation	: 0 MW		(b) Oil = 269904524 Taka		Total = 455643470 Taka						
c)	Low water level in Kapitai lake	: 0 MW										
d)	Plants under shut down/ maintenance	: 3120 MW	14.	Maximum Temperature in Dhaka was : 31.4° C								
10.	Total Energy (Generation + India Import)	: 194.87 MKWh	15.	Export through East-West interconnections :								
	By Gas = 125.243 MKWh	By Oil = 39.251 MKWh		At evening peak-hour : 16 MW, at 19:00 hrs								
	By Coal = 10.230 MKWh	By Hydro = 1.611 MKWh		Maximum : -98 MW, at 8:00 hrs								
	By Solar = 0.592 MKWh			Energy : 0.1105 MKWh								
11.	Total Gas Supplied	: 962.20 MMCFD										
(D) Forecast of 25.11.21 (Today) Thursday :												
01.	Maximum Demand	: 9900 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 13615 MW (Generation end)	05.	Total Generation : 199.56 MKWh								
03.	Maximum Shortage	: -3715 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 28.1° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation