

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021										Day : Sunday		Date : 28.11.21			
Probable Maximum Demand : 9700 MW										Yesterday = 101.19 ft		Today = 101.19 ft		Rule Curve = 106.40 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.11.21 (Yesterday)		28.11.21 (Today)		27.11.21 (Yesterday)		Status of Machines under shut-down Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date		
(A) Plants in operation:															
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190						
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	0	0	0	0		365	Under maint.			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		108	Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem			
6	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage			
7	Hanpur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	140	118	140	200		242	Gas Shortage			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270		180	Gas Shortage			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Hanpur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	336	361	360	360						
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage			
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage			
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	305	305	150	150	150	150						
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	4	25	25	25						
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	102	102	102						
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22						
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x0.97+1x8.73	80	80	54	54	55	55						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x8.73	33	33	33	28	33	33						
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x8.73	33	33	33	33	33	33						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	51	51						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	50	105	105						
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	82	149	149						
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54						
25	Kodda 300 MW PP Unit-3 (Summit)	HFO (IPP)	18x17.076	300	300	0	145	300	300						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	102	149	149						
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	300						
28	Bismariganj 100 MW PP (Aggraka)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
29	Aurahi 100MW PP (Aggraka)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100						
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x18.3	55	55	53	35	55	55						
31	Maniganj 55 MW PP (Northern)	HFO (IPP)	3x18.3	55	55	0	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	85	104	104	104						
33	Maniganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162						
34	Maniganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0						
Dhaka Zone Total				5717	5560	1672	2246	2799	3179	1095	1025				
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	72	72	75	75		40	Unit 2 under overhauling			
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0						
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	13	25	25						
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0						
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	46	50	50	50						
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	21	17	105	105						
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
43	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval			
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300						
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	80	100						
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	70	100	100	100						
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80						
48	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment Issue			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20						
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			3	6	10	20						
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	1	57	90	90						
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	54	54						
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	67	110	110	110						
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	100	100						
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	98	107	116	116						
Chattogram Zone Total				2442	2382	773	965	1311	1345	0	775				
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage			
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129	Gas Shortage			
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	100	120	120	120		14	Gas Shortage			
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	29	29						
57	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	198	182	220	220						
58	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	320	355	360	360						
59	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Under maint.			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	49	56	55	55						
61	Ashuganj 195MW PP (APSLC-United)	Gas (IPP)	20*9.73+1*16	195	195	68	68	68	68		127	Gas shortage			
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51						
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	140	140	140						
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50						
65	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	88	90	90	90						
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	200	200						
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	9	34	52	52						
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9						
72	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	8x14+8x15+1x155	200	200	0	0	0	200						
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114						
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	116	118	113	113						
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
**	Chandpur 115(Doreen)	HFO (IPP)	115			14	0	0	0			On Test			
**	Imporgit (Tripura)	India		160	160	84	105	138	164						
Cumilla Zone Total				3094	3034	1344	1457	1892	2118	405	360				
76	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	152	148	200	200		54	Gas Shortage			
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. :8MW			
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.67	115	115	40	115	115	115						
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	5	60	200	200						
81	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
82	Sutabkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0						
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22						
Mymensingh Zone Total				717	622	266	369	611	559	54	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.11.21 (Yesterday)		28.11.21 (Today)		27.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	GT1 Coupling problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT4 Load gear problem	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	50	50	50				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	30	33	33				
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	101	96	100	100	234		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	80	80	84				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	179	218	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	400	400	400				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	102	62	100	100				
Sylhet Zone Total					2422	2377	1522	1463	1622	1626	254	88	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	22	70	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Bheramara (HVDC)	India		1000	1000	492	633	741	741				
Khulna Zone Total					2133	2129	514	703	896	1336	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	20	25	25				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	60	67	68	68		127	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	400	620	620		844	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	151	221	220	220				
Barisal Zone Total					2046	2046	526	719	1054	1204	0	971	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	9	14	30	30				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27				
121	Chapsainwabarjan 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	95	95				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	0	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	20	35				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Overhauling	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	173	220	200	220	0		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	192	200	200	28		Gas Shortage	
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	400	330	400	400				
129	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	1	8	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	74	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2179	2179	765	1226	1539	1658	199	210	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	78	80	80				
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	50	112	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	605	138	190	201	193	0	359	
Sub-total: Plants in operation					21435	20934	7520.0	9338	11925	13218	2007	3788	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							7224	8971	11456	12699			
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0	
Gross Total					22031	20934	7520	9338	11925	13218	2007	3788	
(C) Actual data of 27.11.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 9338.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 8971.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 9338.00 MW, at = 19:00 hrs	Dhaka	3454	3454	0	Mymensingh	691	691	0			
04.	Minimum Generation (Generation end)	: 5609.00 MW, at = 6:00 hrs	Chattogram	1016	1016	0	Sylhet	341	341	0			
05.	Day-peak Generation (Generation end)	: 7520.00 MW, at = 12:00 hrs	Khulna	1035	1035	0	Barisal	252	252	0			
06.	Evening-peak Generation (Generation end)	: 9338.00 MW, at = 19:00 hrs	Rajshahi	864	864	0	Rangpur	595	595	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	723	723	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5959.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2007 MW	13.	Fuel cost :		(a) Gas = 127327151 Taka	(c) Coal = 49470464 Taka						
d)	Coal supply Limitation	: 0 MW		(b) Oil = 231811874 Taka		Total = 408609489 Taka							
b)	Low water level in Kapitai lake	: 0 MW	14.	Maximum Temperature in Dhaka was : 29.4° C									
c)	Plants under shut down/ maintenance	: 3788 MW	15.	Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	: 178.98 MKWh		At evening peak-hour : -48 MW, at 19:00 hrs									
	By Gas = 117.356 MKWh	By Oil = 34.602 MKWh		Maximum : -344 MW, at 8:00 hrs									
	By Coal = 10.560 MKWh	By Hydro = 1.741 MKWh		Energy : 0.884 MKWh									
	By Solar = 0.671 MKWh												
11.	Total Gas Supplied	: 897.46 MCFD											
(D) Forecast of 28.11.21 (Today) Sunday :													
01.	Maximum Demand	: 9700 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 13218 MW (Generation end)	05.	Total Generation : 186.11 MKWh									
03.	Maximum Shortage	: -3518 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 27.9° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation