

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 30-Nov-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	190	4504500	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1'234+1'122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	0	Gas shortage
7	Haripur GTTP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	393	8656900	Gas shortage
9	Haripur 360MW CCGP(HPL)	IPP	1'235+1'125	360	320	6730000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	270	6646300	Gas shortage
11	Meghnaghat 100 MW (IEL)	QRPP	12'8.9	0	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	305	150	3630487	Gas shortage
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	15	70081	Low demand.
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	25	107204	Engine problem
16	Narsinghji 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	441432	
17	210 MW Siddhirganj	PDB	1'210	115	0	0	Under maint.
18	Siddhirganj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12'8.9	0	0	0	Contract Expired
20	Siddhirganj 335 MW CCGP	EGCB	1'217+1'118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	50	309024	Low demand.
22	Kalpoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1161000	
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	16	637440	Low demand.
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	17	135278	Low demand.
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	54	698406	
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulla)	SIPP-REB	3'3.67+4'8.73	80	55	1251960	Engine problem
29	Masna 33 MW PP(Summit)	SIPP-REB	4'8.73	33	33	685000	
30	Rugganji 33 MW PP(Summit)	SIPP-REB	4'8.73	33	17	778500	Engine problem
31	Gazipur 52 MW PP	RPCL	6'8.9	52	25	253440	Low demand.
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	95	885709	Low demand.
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve.
35	Bramhaniganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
36	Aurhatti 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	100	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	121	1391180	Low demand.
38	Gazipur 100 MW PP	RPCL	100 MW	105	17	582896	Low demand.
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	1310400	
40	Manikganj 162MW PPI(MPGL)	IPP	9'18	162	162	2342880	
41	Specira Solar Plant Ltd.	IPP	35	35	35	202675	
Dhaka area Total				5660	2202	43425992	
42	Chattoagram TPP-1	PDB	1'210	180	0	0	Gas shortage
43	Chattoagram TPP-2	PDB	1'210	180	0	0	Gas shortage
44	Raozan 25 MW PP	IPP	3'8.9	25	8	93283	Low demand.
45	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	134865	
46	Patenga 50MW PP (Baraka)	IPP	6'8.98	50	50	986400	
47	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	104	2532042	Low water level & #2 Under n
48	Sikalbaha 225MW GT	PDB	1'150+1'175	150	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	17	98690	Low demand.
51	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under S/D
52	Dohazari -Kalash 100 MW Peaking	PDB	6'17	102	51	126753	Low demand.
53	Julda 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	10	86720	Low demand.
54	Julda 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	690240	
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	18	425952	Engine problem
56	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	4	434400	
57	Chattoagram 108 MW PP (ECPV)	IPP	16'7	108	70	278400	Line OIL
58	Kapta 7 MW Solar PP	PDB	7.4 MW	7	0	26041	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	300	6230073	
60	Jodac Power	IPP	3'18.55+1'3.6	54	54	1300921	
61	Kamarghull Power Ltd.	IPP	1'10	110	34	589524	
62	Julda unit-2 (Acorn)	IPP	8'13.6	100	20	154560	Low demand.
63	Anilma Energy Ltd.	IPP	6'21.2	116	51	883200	Low demand.
Chattoagram area Total				2382	891	15022064	
64	Ashuganj TPP Unit- 3	APSCL	1'150	135	0	0	Gas shortage
65	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage
66	Ashuganj TPP Unit- 5	APSCL	1'150	134	100	2654770	Gas shortage
67	Ashuganj 225 MW CCGP	APSCL	1'142+1'175	221	210	4563300	FGMO
68	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	0	0	Ashuganj 400 kv Bus S/D
69	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	290	7437200	FGMO
70	Ashuganj 50 MW PP	APSCL	14'3.968	45	29	666864	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	55	1188000	
72	Ashuganj 195MW PP (APSCL-United)	IPP	20'17.3+1'16	195	58	1589990	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6'8.34	51	51	1037350	
74	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	115	1154181	Engine problem
75	Tilas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Reserve.
76	Chandpur 150 MW CCGP	PDB	1'106+1'157	163	88	2119180	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	34	342720	Low demand.
78	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	516780	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	232020	
80	Impopt (Tripura)	Imported power	0	160	98	2029440	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	616300	
82	Jangalia 52 MW PP (Lakdanav)	IPP	6'8.92	52	16	199757	Low demand.
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	9	201020	Engine problem
84	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7'18.415+1'6.78	114	17	76380	Low demand.
86	Chowmuhani 113 MW	IPP	12'3.78+2'3.1	113	115	1431360	
87	Bhairab 54.5 MW	IPP	3'18.2	54	17	432360	33 kv feeder fault.
88	Chandpur 115(Doreen)	IPP	115	0	0	94080	On test
Cumilla Area Total				3034	1358	26806652	
89	RPCL 210MW CCGP	IPP	4'35+1'70	202	124	3175680	Gas shortage
90	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	483912	
91	Jamulpur 95 MW PP(Powerpac)	IPP	12'8.924	8	0	0	Engine problem
92	Sanshabari 3 MW Solar Plant	IPP	1'3	3	0	13300	
93	Mymensingh 200 MW PP (United)	IPP	200	200	24	91200	Low demand.
94	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1370400	
95	Suitakhal 50 MW Solar PP	IPP	50	50	0	317950	
96	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	0	0	
Mymensingh Area Total				622	283	5432442	
97	Fenchuganj CCGP Phase-1	PDB	2'32+1'33	70	40	931000	Machine problem
98	Fenchuganj CCGP Phase-2	PDB	2'35+1'35	90	30	705960	Machine problem
99	Kushnara 183 MW CCGP (KP)	IPP	1'109+1'54	163	163	3552872	
100	Shahjibazar 330 MW CCGP	PDB	3'110	330	124	2832000	GT-1 under maint
101	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1074000	
102	Fenchuganj 44MW (Energyprima)	RPP	12'3.3+5'2	0	0	0	Contract Expired
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	4716576	
104	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	40	815808	GT-8 under maint
105	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.80	86	77	1504320	
106	Shahjibazar 100 MW GTTP	PDB	1'100	100	60	1645727	Gas shortage
107	Sylhet 225 MW CCGP	PDB	1'142+1'189	231	218	4842770	
108	Sylhet 20 MW GTTP	PDB	1'20	20	0	0	Gas shortage
109	Sylhet 30MW PP (EPL)	RPP	2'7.2	0	0	0	Contract Expired
110	Shahjibazar 25 MW PP	SIPP, REB	3'9.34	25	24	477048	
111	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	280	7269003	FGMO
112	Bibiana-III 400 MW CCGP	PDB	400 MW	400	400	8350000	
113	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	251640	
114	Bibiana South 400 MW	PDB	400 MW	383	45	2883000	ST under preparation
Sylhet Area Total				2377	1575	41907724	
115	Bheramara 57MW Unit-3	PDB	1'20	16	0	0	Reserve.
116	Bheramara (WDC)	Imported power	2'500	1000	715	14781818	
117	Khulna 115 MW PP (KPCL-2)	QRPP	7'17	0	0	0	Contract Expired
118	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve.
119	Khulna 225 MW CCGP	NWPGCL	1'150+1'175	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.
121	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	0	0	Under maint.
122	Nospara 40 MW PP (Barigatah Ali)	QRPP	5'2	0	0	0	Contract Expired
123	Nospara 100 MW PP (Barigatah Trac)	IPP	70'1.4	100	0	0	Reserve.
124	Rupsha 105 MW PP (Oron rupsha)	IPP	6'18.445	105	27	758880	Low demand.
125	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line OIL
Khulna Area Total				2129	742	15540698	
126	Barisal 110 MW PP (Summit)	IPP	71'7.076	110	0	0	Reserve.
127	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	20	362000	Engine problem
128	Bhola 225 MW CCGP	PDB	2'35+1'188	194	66	1577000	Machine problem
129	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	11	273858	Gas shortage
130	Payra 1320 MW	BCPCL	2'622	1244	400	8598500	Line OIL
131	Bhola Nutan Bidut BD LTD	IPP	220	220	217	4593518	
132	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Reserve.
Barisal Area Total				2046	714	15434877	
133	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
134	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
135	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	91792	
136	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve.
137	Amnura 50 MW PP(Sinha)	QRPP	7'7.79	50	12	36410	Low demand.
138	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	8	21549	Low demand.
139	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	31	60841	Low demand.
140	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	140	1084200	Gas shortage
141	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	194	4517964	Gas shortage
142	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	202	4519982	FGMO
143	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1'282+1'132	414	373	85501145	FGMO
144	Santahar 50 MW Peaking PP	PDB	6'8.7	50	36	64538	Low demand.
145	Bogra 22 MW PP (GBB)	RPP	6'4	22	22	452880	
146	Bogra 20 MW PP (Energyprima)	RPP	5'3.3+5'2	0	0	0	Contract Expired
147	Ullapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	22842	
148	Natore 52 MW PP (Rajanka)	PDB	6'8.92	52	16	109920	
149	Chapainawabganj 100 MW Peaking PP	PDB	12'8.924	104	42	96016	Low demand.
150	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve.
151	Bagura 113 MW PP (Confidence)-2	IPP	113 MW	113	112	1115328	
152	Confidence Power Barura Unit-1 113 MW	IPP	6'18.53	113	70	529920	
153	Sirajgonj 6.55 MW Solar	NWPGCL					