

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month December, 2021		Day : Monday					Date : 20.12.21					
Probable Maximum Demand :		9200 MW					Probable Maximum Generation : 12929 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 99.92 ft			Today = 99.84 ft			Rule Curve = 104.20 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.12.21 (Yesterday)		20.12.21 (Today)		19.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable shut-up date
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	107	106	106			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem
6	Hairpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Hairpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	350	353	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Hairpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage
11	Siddhirganj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	37	100	100	173		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	230	275	300	75		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	40	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	25	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	0	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.67+8x7.5	80	80	31	34	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	25	25	25			
20	Rugganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	25	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	32	48	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	281	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	57	126	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Branhanganj 100 MW PP (Agregko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurath 100MW PP (Agregko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0			
	Kanchan Purbachal Power Generation	HFO (IPP)				35	36	57	0			On test
Dhaka Zone Total				5717	5560	1698	2205	2820	3108	1375	660	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x30	230	230	78	77	46	46	153		Low water level & maint.
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
38	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalb.)	HFO (IPP)	6x18.415	105	105	0	17	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100			
46	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	10	90	90	90			
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment Issue
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
*	Melancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	16	10	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	21	68	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	0	10	100	100			
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	75	88	116	116			
Chattogram Zone Total				2442	2382	619	850	1291	1295	153	735	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	130	130	130	130			
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	26	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1'175	221	221	193	184	225	225			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under maint. 22-12-21
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	335	315	360	360			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	56	55	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8			
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	132	125	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	17	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	31	136	136	136			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	28	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	10	25	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.51+15x1.288	200	200	0	0	0	200			
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	48	38	113	113			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test
**	Import (Tripura)	India		160	160	85	98	138	164			
Cumilla Zone Total				3094	3034	1184	1306	1878	2114	264	360	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	151	135	202	202			
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	20	20			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	65	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	55	200	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0			
83	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total				717	622	316	351	611	559	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.12.21 (Yesterday)		20.12.21 (Today)		19.12.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down Maintenance Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22-1x33	97	70	43	43	42	42				
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	43	43	44	44				
86	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	48	50	51	51				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	110	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	50	50	50				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	09-01-22	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	80	80	80				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	25	135	140	140				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0	341	Under maint.	30-12-21	
97	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	80	80	80	80				
Sylhet Zone Total					2422	2377	961	1054	1113	1113	0	745	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	360	355	400	410	55	Gas Shortage		
102	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150-1x75	230	230	0	0	0	220				
105	Nospara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Mongla Orion 100 MW Solar PP	Solar (IPP)				68	0	10	0				
**	Bheramara (HVDC)	India		1000	1000	678	724	680	728				
Khulna Zone Total					2133	2129	1141	1184	1245	1733	55	0	
108	Barsail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	20	23	23				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	72	72	72	72				
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11			122	
112	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	250	420	620	620			824	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	135	200	200	220				
Barishal Zone Total					2046	2046	483	723	1036	1206	0	946	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
115	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
119	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25				
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	48	90	100				
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	33				
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	50	50				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	207	184	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	387	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	110	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	34	113	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2179	2179	716	1025	1362	1434	601	0	
134	a) Barapukuria TTP Unit-1	Coal (PDB)	1 x 125	125	85	83	82	84	84				
134	b) Barapukuria TTP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	
135	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	168	169	170	170				
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	112	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Maipara, Talata 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	605	326	363	375	367	0	85	
Sub-total: Plants in operation					21435	20934	7644	9061	11731	12929	2448	3531	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							7350	8712	11279	12431			
(B) Plants under long term maintenance/contract expired													
140	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PPI/Dutch Bangla	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PPI/Summit	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/contract expired					596	0	0	0	0	0			
Gross Total					22031	20934	7644	9061	11731	12929	2448	3531	
(C) Actual data of 19.12.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 9061.00	MW, at = 19:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 8712.00	MW, at = 19:00 hrs										
03.	Highest Generation (Generation end)	: 9061.00	MW, at = 19:00 hrs										
04.	Minimum Generation (Generation end)	: 5611.00	MW, at = 5:00 hrs										
05.	Day-peak Generation (Generation end)	: 7644.00	MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 9061.00	MW, at = 19:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5684.00	MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :												
a)	Gas Limitation	: 2295	MW										
d)	Coal supply Limitation	: 0	MW										
b)	Low water level in Kapali lake	: 153	MW										
c)	Plants under shut down/ maintenance	: 3531	MW										
10.	Total Energy (Generation + India Import)	: 177.68	MKWh										
	By Gas =	111.610	MKWh										
	By Coal =	14.069	MKWh										
	By Solar=	1.077	MKWh										
11.	Total Gas Supplied	: 844.18	MMCFD										
Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
12.	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
		MW	MW	MW		MW	MW	MW		MW	MW	MW	
	Dhaka	3179	3179	0	Mymensingh	706	706	0					
	Chattoagram	968	968	0	Sylhet	325	325	0					
	Khulna	1062	1062	0	Barishal	242	242	0					
	Rajshahi	892	892	0	Rangpur	608	608	0					
	Cumilla	730	730	0									
					Total	8712	8712	0					
13.	Fuel cost :	(a) Gas =	110341532	Taka	(c) Coal =	69265636	Taka						
		(b) Oil =	212734664	Taka	Total =	392341832	Taka						
14.	Maximum Temperature in Dhaka was :		24.2° C										
15.	Export through East-West interconnections :												
	At evening peak-hour	: 344	MW, at	19:00 hrs									
	Maximum	: 140	MW, at	7:00 hrs									
	Energy	: 0	MKWh										
(D) Forecast of 20.12.21 (Today) Monday :													
01.	Maximum Demand	: 9200	MW	(Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	: 12929	MW	(Generation end)	05.	Total Generation	: 180.40	MKWh					
03.	Maximum Shortage	: -3729	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	23.8° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation