

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 20-Dec-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
								Unit No. X Capacity
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.	
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Engine problem	
5	Ghorasal 78.5 MW PP(MAX)	ORPP	240	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	105	2462045		
7	Harijpur GTPP	SBU, PDB	232	20	0	0	Engine problem	
8	Harijpur 412 MW CCGP	EGCB	1273+1139	412	0	0	Under maint.	
9	Harijpur 350MW CCGP(HPL)	IPP	1235+1125	360	351	8104000		
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	280	6896800	Gas shortage	
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired	
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	250	6842793	FGMO	
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired	
14	Madanganj-55 MW PP(Summit)	ORPP	3*17.08+1*11.3	55	55	433797		
15	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.5	100	0	145671	Engine problem	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	455652		
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.	
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	97	1856000	Gas shortage	
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*7.9	0	0	0	Contract Expired	
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	0	Gas shortage	
21	Sagaraganj 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1136304	Reserve.	
22	Katohli 52 MW PP (Sinha)	IPP	7*7.9	0	0	0		
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	35	552240	Engine problem	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	176160	High Voltage.	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	630090		
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	5	438293	line SD	
27	Bosila 108MW RPCL	IPP	12*9.15+1*3.5	0	0	0		
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.87+4*8.73	80	31	767940	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	829200		
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	793700		
31	Gazipur 52 MW PP	RPCL	6*8.9	52	42	232800	Engine problem	
32	Tongi 80 MW GTTP	PDB	11*105	105	0	0	Machine problem	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	266	2421272	Engine problem	
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.	
35	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.	
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1270510		
38	Gazipur 100 MW PP	RPCL	100 MW	105	73	170400	High Voltage.	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.9	104	104	1635540		
40	Manikganj 162MW (MPL)	IPP	9*18	162	162	3044460		
41	Spectra Solar Plant Ltd.	IPP	35	35	0	170280		
Kanchan Purbachal Power Gener				55	0	35	380520	On test
<b>Dhaka Area Total</b>				<b>5560</b>	<b>2333</b>	<b>41846467</b>		
42	Chattogram TPP-1	PDB	1210	180	0	0	Gas shortage	
43	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage	
44	Razzan 25 MW PP	IPP	3*8.9	25	0	0	High Voltage.	
45	Taksoni 20MW PP (Solarteck/Teknaf Solarteck Energ	IPP	20	20	0	103140		
46	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	38	796320	Engine problem	
47	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	46	1087800	Low water level & #2 Under n	
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.	
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.	
50	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	0	0	High Voltage.	
51	Hathazari 100 MW Peaking PP	PDB	11*9.9	99	0	0	Under SID	
52	Dokhazari-Kalaish 100 MW Peakin	PDB	6*17	102	51	190406	Engine problem	
53	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	10	46800	High Voltage.	
54	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	50	927360	High Voltage.	
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	438096		
56	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	18	496800		
57	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	13	53560	High Voltage.	
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	22799		
59	Anwara 300 MW PP (United)	IPP	300 MW	300	300	6082036		
60	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1309419		
61	Karnaphuli Power Ltd.	IPP	110	110	51	601342	High Voltage.	
62	Juddah unit-2 (Acorn)	IPP	8*13.6	100	50	259200	High Voltage.	
63	Anilima Energy Ltd.	IPP	6*21.2	116	51	1334836	High Voltage.	
<b>Chattogram Area Total</b>				<b>2382</b>	<b>751</b>	<b>13754914</b>		
64	Ashuganj TPP Unit-3	APSCCL	1150	133	0	0	Contract Expired	
65	Ashuganj TPP Unit-4	APSCCL	1150	129	0	0	Gas shortage	
66	Ashuganj TPP Unit-5	APSCCL	1150	134	100	2915238	Gas shortage	
67	Ashuganj 225 MW CCGP	APSCCL	1*142+1*175	221	162	4386000	#REF!	
68	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	295	7715500	Gas shortage	
69	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	0	0	Under maint.	
70	Ashuganj 50 MW Peaking PP	APSCCL	14*3.968	45	29	658566	Gas shortage	
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	56	1308000		
72	Ashuganj 195MW PP (APSCCL-UR)	IPP	20*9.73+1*16	195	36	719272	Gas shortage	
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1241388		
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	127	2204654	High Voltage.	
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	61808	Reserve.	
76	Chandpur 150 MW Peaking PP	IPP	1*106+1*157	163	138	333990	Engine problem	
77	Chandpur 200MW (Dash energy)	IPP	0	200	17	63840	High Voltage.	
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	502848		
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	220500	Engine problem	
80	Imporrt (Tripura)	Imported power	0	160	97	1798000		
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	781700		
82	Jangalia 52 MW PP (Madanav)	IPP	8*6.92	52	46	365424	High Voltage.	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.87+2*9.27	25	6	197450	Engine problem	
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.	
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.	
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	25	696360	Engine problem	
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	437760	33 kV feeder O/L	
Chandpur 115(Doreen)				115	0	0	On test	
<b>Cumilla Area Total</b>				<b>3034</b>	<b>1284</b>	<b>28518188</b>		
88	RPCL 210MW CCGP	IPP	4*35+1*70	202	142	3522240	Engine problem	
89	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	498780		
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.	
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10650		
92	Mymensingh 200 MW PP (Unitec)	IPP	200	200	50	283200	High Voltage.	
93	Shahjibazar 115 MW PP (Unitec)	IPP	115 MW	115	115	1744600		
94	Sutakhal 50 MW Solar PP	IPP	50	50	0	2631300		
95	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	25	336960		
<b>Mymensingh Area Total</b>				<b>622</b>	<b>354</b>	<b>6659760</b>		
96	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	43	1009000	Machine problem	
97	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	43	1020120	Machine problem	
98	Kushara 163 MW CCGP (KP)	IPP	1*109+1*154	163	163	3603681		
99	Shahjibazar 330 MW PP (Summit)	PDB	3*110	330	0	0	Under maint.	
100	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	53	1175400		
101	Fenchugonj 44MW (Energyprima)	RPP	12*3.5+5*2	0	0	0	Contract Expired	
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	189408		
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	50	1214208	Engine problem	
104	Shahjibazar 96MW PP (Shahjibaz	RPP	32*2.90	86	79	1712640	Engine problem	
105	Shahjibazar 100 MW GTTP	PDB	1*100	100	60	1915945	On test	
106	Sylhet 225 MW CCGP	PDB	1*142+1*189	231	191	3982990	ST under maint	
107	Sylhet 20 MW GTTP	PDB	1*20	20	18	418000		
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired	
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	498216		
110	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.	
111	Bibiana-III 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.	
112	Sylhet 10MW PP (Dash)	RPP	8*1.95	10	10	252720		
113	Bibiana South 400 MW	PDB	400 MW	383	400	9301700		
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1165</b>	<b>26309328</b>		
114	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.	
115	Bheramara (HVDC)	Imported power	2*500	1000	714	13610909		
116	Khulna 115 MW PP (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired	
117	Farijpur 50 MW Peaking PP	PDB	8*6.88	50	0	0	Reserve.	
118	Khulna 225 MW CCGP	NWPGCL	1*150+1*175	230	0	0	Reserve.	
119	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.	
120	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	410	7373852		
121	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired	
122	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	0	0	Reserve.	
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1126080		
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	53	84528	Line O/L	
125	Mongla Orion 100 MW Solar PP	IPP	100	0	0	454400	On test	
<b>Khulna Area Total</b>				<b>2129</b>	<b>1282</b>	<b>22659869</b>		
126	Barisal 110 MW PP (Summit I)	IPP	7*17.076	110	16	12960	Reserve.	
127	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	20	385000	Engine problem	
128	Bhola 225 MW CCGP	PDB	2*63+1*68	194	90	1888343	Machine problem	
129	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	269033	Gas shortage	
130	Payra 1320 MW	BPCL	2*622	1244	40	6560093	Line O/L	
131	Bhola Nutan Bidut BD LTD	IPP	220	229	229	4090409		
132	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	35	67200	High Voltage.	
<b>Barisal Area Total</b>				<b>2046</b>	<b>441</b>	<b>13262945</b>		
133	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage	
134	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage	
135	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	43	86674	Engine problem	
136	Bara 70 MW Peaking PP	PDB	9*8.29	71	5	52396	Engine problem	
137	Amnura 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	Reserve.	
138	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	50	111233		
139	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	24	48241	Engine problem	
140	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*175	210	0	0	Gas shortage	
141	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*175	220	0	0	Gas shortage	
142	Sirajgonj Unit-3 225MW	NWPGCL	1*141	230	199	4409099	FGMO	
143	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	380	8887200	FGMO	
144	Santahar 50 MW Peaking PP	PDB	6*8.7	50	21	42072	Engine problem	
145	Bogra 22 MW PP (GBB)	RPP	6*4	22	21	504240		
146	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired	
147	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	247860		
148	Natore 52 MW PP (Barakata)	PDB	8*6.92	52	52	384956		
149	Chapainawabganj 100 MW Peakin	IPP	12*8.924	104	100	204336		
150	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.	
151	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	110	932352		
152	Confidence Power Bogura Unit-1	IPP</						