

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2022				Day : Saturday				Date : 01.01.22				
Probable Maximum Demand : 9200 MW				Probable Maximum Generation : 12422 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.51 ft				Today = 98.31 ft				
				Rule Curve = 103.00 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.12.21 (Yesterday)		01.01.22 (Today)		31.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	100	90	100	100	90	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	230	230	230	230	135	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	160	165	250	250	195	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	235	135	235	235	315	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	11	11	11			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	72	32	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22			
18	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	34	31	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	18	18	18			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	15	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	16	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	70	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	10	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	170	282	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	34	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
28	Bramhangoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahali 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	17	35	35			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	75	94	104	104			
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	148	162	162			
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0			
	Kanchan Purbachal Power Generation	HFO (IPP)				28	17	55	55		On test	
Dhaka Zone Total			5717	5560	1410	1524	2771	2791	2092	703		
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	80	84	86	150	Low water level & maint.	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120			
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	28	50	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	17	87	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	105	300	300			
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	40	76	90	90			
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	51	70			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment Issue	
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			23	40	10	25			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	18	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	54	54			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	87	91	110	110			
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	100	100	100			
54	Chattogram 116 MW PP (Anlima Enerc)	HFO (IPP)	6x21.06	116	116	51	51	116	116			
Chattogram Zone Total			2442	2382	597	908	1450	1461	150	555		
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	30	30	40	Gas Shortage	
57	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	130	193	200	220			
58	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	265	350	350	95	Gas Shortage	
59	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	150	150	250	250	210	Gas Shortage	
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	10	10	50	Gas Shortage	
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	113	127	150	150			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	50	50	50			
65	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	133	129	141	141			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	24	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	0	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	52	105	113	113			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0		On Test	
**	Impoprt (Tripura)	India		160	160	69	78	138	164			
Cumilla Zone Total			3094	3034	1207	1389	2029	2275	900	0		
76	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	71	98	120	120	104	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	35	25	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	130	184	200	200			
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	23	24	22	22			
Mymensing Zone Total			717	622	328	353	531	479	104	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.12.21 (Yesterday)		01.01.22 (Today)		31.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	Under maint.	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	43	43		60	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
87	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	41	72	72				
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	79	80	80				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	203	190	200	200				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	
97	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	400	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	985	1062	1115	1115	0	758	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
	Mongla Orion 100 MW Solar PP	Solar (IPP)				72	0	10	0				
**	Bheramara (HVDC)	India		1000	1000	562	671	685	733				
Khulna Zone Total					2133	2129	669	776	850	1328	410	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	3	24	24	24				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	68	67	70	70		127	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPL)	2x622	1244	1244	300	420	620	620		824	Line Overload	
113	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BD)	Gas/HSD (IPP)	2x75+1x70	220	220	151	220	200	220				
Barishal Zone Total					2046	2046	533	742	1035	1205	0	951	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	2	0	30	30				
119	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25				
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	100	90	100				
121	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	9	32	32	33				
122	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	43	50	50				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	0	36				
124	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
125	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	170	209	200	200				
127	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	346	377	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	100	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	100	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2179	2179	781	1128	1394	1435	601	0	
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	212	200	200		62	Coal shortage	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	54	99	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	605	258	311	321	313	147	85	
Sub-total: Plants in operation					21435	20934	6768.0	8193	11496	12402	4404	3052	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					6544	7922	11115	12011					
(B) Plants under long term maintenance/ contract expired													
140	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	20			Running for test purpose	
141	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
142	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	20				
Gross Total					22031	20934	6768	8193	11496	12422	4404	3052	

(C) Actual data of 31.12.21 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	8193.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	7922.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8193.00	MW,	at =	19:00 hrs	Dhaka	2581	2581	0	Mymensingh	698	698	0
04.	Minimum Generation (Generation end)	:	5879.00	MW,	at =	5:00 hrs	Chattogram	956	956	0	Sylhet	321	321	0
05.	Day-peak Generation (Generation end)	:	6768.00	MW,	at =	12:00 hrs	Khulna	1008	1008	0	Barishal	241	241	0
06.	Evening-peak Generation (Generation end)	:	8193.00	MW,	at =	19:00 hrs	Rajshahi	824	824	0	Rangpur	582	582	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	711	711	0	Total	7922	7922	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5492.00	MW,	at =	5:00 hrs	Fuel cost :		(a) Gas =	97561974 Taka	(c) Coal =	66653867 Taka		
09.	Generation shortfall at evening peak due to :	:							(b) Oil =	287776691 Taka	Total =	451992532 Taka		
	a) Gas limitation	:	4107	MW			14. Maximum Temperature in Dhaka was :						27.1° C	
	d) Coal supply Limitation	:	147	MW			15. Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	150	MW			At evening peak-hour						162 MW, at 19:00 hrs	
	c) Plants under shut down/ maintenance	:	3052	MW			Maximum						-140 MW, at 8:00 hrs	
10.	Total Energy (Generation + India Import)	:	165.32	MKWh			Energy						0.031 MKWh	
	By Gas =	94.337	MKWh	By Oil =	41.322	MKWh								
	By Coal =	14.036	MKWh	By Hydro =	1.878	MKWh								
	By Solar =	1.143	MKWh											
11.	Total Gas Supplied	:	744.57	MKWh										

(D) Forecast of 01.01.22 (Today) Saturday :												
01.	Maximum Demand	:	9200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12422	MW	(Generation end)	05.	Total Generation	:	185.64	MKWh		
03.	Maximum Shortage	:	-3222	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	24.5° C			