

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month January, 2022		Day : Wednesday				Date : 05.01.22					
Probable Maximum Demand :		9500 MW		Probable Maximum Generation :		12501 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 97.92 ft		Today = 97.72 ft		Rule Curve = 102.24 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.01.22 (Yesterday)		05.01.22 (Today)		04.01.22 (Yesterday) Gen. shortfall for :	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening			Day
						Gas/water/Coal limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	320	320	320	45	Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Harijpur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	240	220	250	250	140	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	180	180	180	270	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Harijpur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	Gas Shortage
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	9	11	11	11		
16	Gagnagar 102 MW PP (Digital Power)	Gas (IPP)	12x8.924	102	102	32	102	102	102		
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16		
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	34	34	35	35		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	22	22		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	26	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105		
23	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	150	48	149	149		
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	35	35		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	283	300	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	302	300	300		
28	Bramhangon 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	60	100	100		
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	50	100		
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0		
	Kanchan Purbachal Power Generation	HFO (IPP)				55	55	55	55		On test
Dhaka Zone Total				5717	5560	1951	2503	2704	2724	2097	598
35	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86	144	Low water level & maint.
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
38	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	11	44	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	65	210	300	300		
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	30	0	100	100		
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90		
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	70		
48	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	20	21		
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			4	6	10	10		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	73	84	90	90		
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
52	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	34	34	116	116		
Chattogram Zone Total				2442	2382	803	994	1332	1327	144	833
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	80	130	130	54	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	5	23	23	40	Gas Shortage
57	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1x75	221	221	167	193	200	220		
58	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	295	265	350	350		
59	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	140	150	0	150	210	Gas Shortage
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	20	5	20	20	50	Gas Shortage
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	65	65	187	Gas Shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	140	150	150		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50	50		
65	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	138	136	135	137		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	25	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	15	24	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9		
72	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.258	200	200	0	20	0	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	0	114	114		
74	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	69	65	113	113		
75	Bhitaro 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0		On Test
**	Import (Tripura)	India		160	160	93	97	138	164		
Cumilla Zone Total				3094	3034	1311	1364	1883	2281	805	0
76	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	66	70	100	100	132	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	85	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	176	184	200	200		
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
82	Sutakahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0		
83	Tangail 22 MW PP(MPGL)	HFO (IPP)	4x6.7	22	22	24	22	22	22		
Mymensingh Zone Total				717	622	347	383	511	459	132	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.01.22 (Yesterday)		05.01.22 (Today)		04.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	42		27	GT 1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	51	51				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
88	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	70	71	71				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	78	80	83				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	190	190	190	190				
93	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
95	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	10	330	330			Was under maint.	
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	400	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total						2422	2377	1935	1390	1393	0	447	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
102	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	37	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
	Mongla Orion 100 MW Solar PP	Solar (IPP)				78	0	10	0				
**	Bheramara (HVDC)	India		1000	1000	671	718	683	731				
Khulna Zone Total						2133	2129	784	870	848	1326	410	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	110	110	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	22	24	24				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	93	92	91	91		102	Under maint.	
111	Bhola 95 MW PP (Agreko)	Gas (QRPP)	1,1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	410	620	620			834	Line Overload
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BL)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	200	220				
Barishal Zone Total						2046	2046	620	755	1056	1226	0	936
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	15	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	24	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25				
120	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	100	90	100				
121	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	31	31	32	32				
122	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	0	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	125	208	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	362	381	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
129	Ullaspara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
130	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	43	34	34	34				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
133	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	834	1119	1369	1408	601	0
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200		75	Coal shortage	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				Condenser mode
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	112	112	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				Condenser mode
139	Majpara, Tatala 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
	Energypac Power Ventures Thakurgaon Ltd.	HFO (IPP)				0	0	0	0				
Rangpur Zone Total						685	605	317	311	321	313	160	85
Sub-total: Plants in operation						21435	20934	7902.0	9366	11414	12457	4349	2899
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7603	8991	10952	11949				
(B) Plants under long term maintenance/ contract expired													
140	Katpali 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	52	40	44	44				Running for test purpose
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Contract Expired
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogura 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired						596	0	52	40	44	44		
Gross Total						22031	20934	7954	9406	11458	12501	4349	2899
(C) Actual data of 04.01.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 9406.00 MW, at = 19:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 8991.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 9406.00 MW, at = 19:00 hrs	Dhaka	3259	3259	0	Mymensingh	762	762	0			
04.	Minimum Generation (Generation end)	: 5837.00 MW, at = 5:00 hrs	Chattoogram	1019	1019	0	Sylhet	347	347	0			
05.	Day-peak Generation (Generation end)	: 7954.00 MW, at = 12:00 hrs	Khulna	1075	1075	0	Barishal	247	247	0			
06.	Evening-peak Generation (Generation end)	: 9406.00 MW, at = 19:00 hrs	Rajshahi	926	926	0	Rangpur	622	622	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	734	734	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5648.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:											
a)	Gas limitation	: 4045 MW											
b)	Coal supply Limitation	: 160 MW											
c)	Low water level in Kaplai lake	: 144 MW											
d)	Plants under shut down/ maintenance	: 2899 MW											
10.	Total Energy (Generation + India Import)	: 183.85 MKWh											
	By Gas = 92.768 MKWh	By Oil = 57.623 MKWh											
	By Coal = 13.719 MKWh	By Hydro = 1.997 MKWh											
	By Solar= 0.860 MKWh												
11.	Total Gas Supplied	: 723.98 MMCFD											
(D) Forecast of 05.01.22 (Today) Wednesday :													
01.	Maximum Demand	: 9500 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 12501 MW (Generation end)	05.	Total Generation	: 185.69 MKWh								
03.	Maximum Shortage	: -3001 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 25.8° C								

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzl Islam Shaker)
Deputy Secretary, Generation