

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel- 9564667, 9551095

Month January, 2022										Day : Friday				Date : 14.01.22										
Probable Maximum Demand : 8600 MW										Probable Maximum Generation : 11677 MW														
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 96.57 ft					Today = 96.45 ft					Rule Curve = 100.53 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.01.22 (Yesterday)		14.01.22 (Today)		13.01.22 (Yesterday)		14.01.22 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date										
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks													
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)														
(A) Plants in operation:																								
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work											
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	240	180	240				Gas Shortage											
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage											
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365			Gas Shortage											
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage											
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.											
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage											
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	200	80	155	155	280			Gas Shortage											
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	170	140	150	150	310			Gas Shortage											
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling											
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage											
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage											
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage											
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage											
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55															
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	58	60	65	65															
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102															
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19															
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	34	34	35	35															
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33															
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	25	33															
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51															
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105															
23	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	150	150	150	150															
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	46	54	54															
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	300	300	300															
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	149	149	149															
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	192	305	200	300															
28	Branhangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100															
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	70	100	100	100															
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	35	35															
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55															
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104															
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162															
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	28	0	30	0															
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	36	55	55	55															
36	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	48	48	51	51															
Dhaka Zone Total				5853	5696	2431	2530	2528	2658	2447	598													
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	75	81	86	86	149			Low water level & maint.											
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage											
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage											
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0															
40	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	25	25															
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0															
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	25	25	25	25															
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105															
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.											
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		HQPI awaiting											
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	60	135	300	300															
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	70	50	100	100															
48	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90															
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51															
50	Hafzabari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		98		Environment issue											
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	21	21															
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	16	15	30															
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	72	86	90	90															
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	37	54	54	54															
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110															
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100															
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	102	116	116	116															
Chattogram Zone Total				2442	2382	906	1056	1313	1303	509	473													
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage											
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	80	80	80	54			Gas Shortage											
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40			Gas Shortage											
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	122	126	150	150															
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	250	250	330	330															
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	90	90	200	200	270			Gas Shortage											
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5															
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	8	8	195			Gas Shortage											
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51															
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	130	150	150															
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50	50															
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.											
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	5	34	200	200															
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22															
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11															
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	7	8	33	33															
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	14	43	52	52															
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9															
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	96x1.4+6x1.915+15x1.096	200	200	30	40	100	200															
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114															
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	115	119	113	113															
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	9	17	17	17															
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0				On Test											
**	Import (Tripura)	India		160	160	89	103	138	163															
Cumilla Zone Total				2944	2899	1043	1184	1838	1963	688	163													
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	71	70	85	100	132			Gas Shortage											
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	22	22	22															
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924																					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.01.22 (Yesterday)		14.01.22 (Today)		13.01.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22-1x33	97	70	43	43	42	42			GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x25+1x35	104	90	0	0	10	10			Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	45	50	51	51				
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	130	130	130				
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	68	69	72	72				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	40	110	110	110			220 Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	124	124	0	0				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24				
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	330	330				
99	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	266	266	260	260				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1119	1238	1149	1149	0	337	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0			410 Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	10	100	60	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	16	0				
**	Bheramara (HVDC)	India		1000	1000	478	714	628	723				
Khulna Zone Total					2233	2229	675	952	859	1323	410	0	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	26	25	25				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	92	91	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	490	620	620			754 Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	208	115	220	220				
Barishal Zone Total					2046	2046	636	733	1077	1227	0	754	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71 Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100 Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	42	50	50	50				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	45	45	45				
122	Amnura 50 MW PP(Sintha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
123	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	17	100	90	100				
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	32	32				
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	25	34	34				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			210 Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0			220 Gas Shortage	
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	185	169	180	200				
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	370	398	400	400				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	43	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	111	113	113	113				
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total					2179	2179	968	1218	1348	1372	601	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85 Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85 Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	199	200	200			75 Coal shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	111	111	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
142	Majpara, Taluka 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
	Energyrac Power Venture Thakurgaon Ltd	HFO (IPP)				12	0	0	0				
Rangpur Zone Total					685	605	325	310	321	313	160	85	
Sub-total: Plants in operation					21521	21035	8555.0	9643	10929	11767	4947	2410	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					8498	9579	10856	11689					
(B) Plants under long term maintenance/contract expired													
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
144	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/contract expired					545	0	0	0	0	0	0	0	
Gross Total					22066	21035	8555	9643	10929	11767	4947	2410	
(C) Actual data of 13.01.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 9643.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9579.00	MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9643.00	MW, at = 19:00 hrs	Dhaka	3664	3664	0	Mymensingh	837	837	0		
04.	Minimum Generation (Generation end)	: 5763.00	MW, at = 5:00 hrs	Chattoagram	1036	1036	0	Sylhet	345	345	0		
05.	Day-peak Generation (Generation end)	: 8555.00	MW, at = 12:00 hrs	Khulna	1086	1086	0	Barishal	245	245	0		
06.	Evening-peak Generation (Generation end)	: 9643.00	MW, at = 19:00 hrs	Rajshahi	939	939	0	Rangpur	663	663	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs	Cumilla	764	764	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6166.00	MW, at = 5:00 hrs					Total	9579	9579	0		
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :								
a)	Gas limitation	: 4638	MW	(a) Gas =	85547544	Taka	(c) Coal =	66778744	Taka				
d)	Coal supply Limitation	: 160	MW	(b) Oil =	567581990	Taka	Total =	719908278	Taka				
b)	Low water level in Kaptai lake	: 149	MW										
c)	Plants under shut down/ maintenance	: 2410	MW	14.	Maximum Temperature in Dhaka was : 26.6° C								
10.	Total Energy (Generation + India Import)	: 189.57	MKWh	15.	Export through East-West interconnections :								
	By Gas =	83.393	MKWh		At evening peak-hour : 176 MW, at 19:00 hrs								
	By Coal =	14.075	MKWh		Maximum : 80 MW, at 20:00 hrs								
	By Solar =	1.026	MKWh		Energy : 0 MKWh								
11.	Total Gas Supplied	: 681.69	MMCFD										
(D) Forecast of 14.01.22 (Today) Friday :													
01.	Maximum Demand	: 8600	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 11767	MW (Generation end)	05.	Total Generation : 169.07 MKWh								
03.	Maximum Shortage	: -3167	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 22.4° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation