

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2022				Day : Monday				Date : 17.01.22							
Probable Maximum Demand :				9900 MW				Probable Maximum Generation : 11965 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.21 ft				Today = 96.02 ft				Rule Curve = 99.96 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.01.22 (Yesterday)		17.01.22 (Today)		16.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			Description/ Remarks		
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	200	200	200						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage			
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	170	140	200	200	220		Gas Shortage			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	160	160	180	180	290		Gas Shortage			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40						
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	40	59	60	60						
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102						
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22						
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	34	34	35	35						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	33	33						
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	24	33	33						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105						
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	82	64	150	150						
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54						
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	260	300	300						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149						
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	108	303	200	300						
28	Branhanganj 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100						
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	60	100	100	100						
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	35	35	35						
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104						
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162						
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0						
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55						
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	45	48	51	51						
Dhaka Zone Total				5853	5696	2091	2442	2606	2676	2367	598				
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	65	70	75	165		Low water level & maint.			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	25	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	24	25	25						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	155	300	300						
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	70	100	100	100						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51						
50	Hafzara 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment issue			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	8	10	10						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	83	86	90	90						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54						
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	91	110	110	110						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	90	90	90						
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	100	100	116	116						
Chattogram Zone Total				2442	2382	910	1072	1278	1258	525	473				
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage			
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	80	80	80	54		Gas Shortage			
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40		Gas Shortage			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	173	167	200	200						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	300	330	330						
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	140	140	200	200	220		Gas Shortage			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50		Gas Shortage			
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195		Gas Shortage			
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	95	103	110	110						
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	28	42	42	42						
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under maint.			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	19	65	200	200						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11						
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	8	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	52	52						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	8	9	9						
74	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.915+15x1.099	200	200	0	150	100	200						
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	52	114	114						
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	99	109	113	113						
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	17	17						
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test			
**	Import (Tripura)	India		160	160	95	100	138	163						
Cumilla Zone Total				2944	2899	1121	1433	1832	1957	688	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	50	60	60	152		Gas Shortage			
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	108	115	115						
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	182	192	200	200						
83	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0						
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22						
Mymensingh Zone Total				717	622	419	394	471	419	152	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.01.22 (Yesterday)		17.01.22 (Today)		16.01.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Water/Cool limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22-1x33	97	70	42	42	42	42			GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	20	20	20	20			Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	45	48	51	51				
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	68	40	66	66				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	112	143	140	140		187	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	75	80	80				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	20	50	50				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	13	24	24	24				
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	280	330	330				
99	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1272	1261	1405	1405	0	285	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	27	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	31	97	60	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	0	0	16	0				
**	Bheramara (HVDC)	India		1000	1000	709	708	724	724				
Khulna Zone Total					2233	2229	855	947	955	1324	410	0	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	25	25	25				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (ORPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	400	620	620		844	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2046	2046	627	747	1077	1227	0	844	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	172	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	42	42	44				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	12	99	90	100				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
124	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	34	34	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	122	118	180	200		102	Gas Shortage	
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	224	214	400	400		200	Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	15	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	43	43	43				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	103	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2129	2129	674	1053	1345	1371	903	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	199	200	200		75	Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	15	0	15			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	605	317	327	321	328	160	85	
Sub-total: Plants in operation					21471	20985	8286.0	9676	11290	11965	5205	2448	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8161	9530	11119	11784			
(B) Plants under long term maintenance/contract expired													
142	Bosilla 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
143	Soldirganj 100 PP (Dutch Bangla)	HFO (ORPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP (Summit)	HFO (ORPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW (IEL)	HFO (ORPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (ORPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Amnura 50 MW PP (Sinha)	HFO (ORPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					545	0	0	0	0	0			
Gross Total					22016	20985	8286	9676	11290	11965	5205	2448	
(C) Actual data of 16.01.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 9676.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9530.00	MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9676.00	MW, at = 19:00 hrs	Dhaka	3524	3524	0	Mymensingh	866	866	0		
04.	Minimum Generation (Generation end)	: 6079.00	MW, at = 5:00 hrs	Chattoagram	1031	1031	0	Sylhet	338	338	0		
05.	Day-peak Generation (Generation end)	: 8286.00	MW, at = 12:00 hrs	Khulna	1107	1107	0	Barishal	237	237	0		
06.	Evening-peak Generation (Generation end)	: 9676.00	MW, at = 19:00 hrs	Rajshahi	992	992	0	Rangpur	658	658	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs	Cumilla	777	777	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6021.00	MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 4880	MW	13.	Fuel cost :	(a) Gas = 82033650	Taka	(c) Coal = 63729952	Taka				
d)	Coal supply Limitation	: 160	MW			(b) Oil = 530495661	Taka	Total = 676259263	Taka				
b)	Low water level in Kaptai lake	: 165	MW										
c)	Plants under shut down/ maintenance	: 2448	MW	14.	Maximum Temperature in Dhaka was :	24.4° C							
10.	Total Energy (Generation + India Import)	: 190.49	MKWh	15.	Export through East-West interconnections :								
	By Gas = 85.193	MKWh	By Oil = 70.687	MKWh	At evening peak-hour	: -90	MW, at 19:00 hrs						
	By Coal = 13.377	MKWh	By Hydro = 1.817	MKWh	Maximum	: -222	MW, at 20:00 hrs						
	By Solar= 0.936	MKWh			Energy	: 0.188	MKWh						
11.	Total Gas Supplied	: 695.81	MMCFD										
(D) Forecast of 17.01.22 (Today) Monday :													
01.	Maximum Demand	: 9900	MW (Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	: 11965	MW (Generation end)	05.	Total Generation	: 194.90	MKWh						
03.	Maximum Shortage	: -2065	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	33.1° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation