

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel- 9564667, 9551085

Month January, 2022										Day : Saturday		Date : 29.01.22					
Probable Maximum Demand : 9800 MW										Probable Maximum Generation : 12341 MW		Rule Curve = 97.60 ft.					
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 94.34 ft		Today = 94.19 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.01.22 (Yesterday)		29.01.22 (Today)		28.01.22 (Yesterday)	29.01.22 (Today)	Status of Machines under shut-down/ Maintenance	Probable start-up date					
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)									
						Day	Evening	Day	Evening	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks					
(A) Plants in operation:																	
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work					
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	200	220	220	220								
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.					
6	Hanipur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage					
7	Hanipur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	147	180	240	260	180		Gas Shortage					
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	150	190	200	200	260		Gas Shortage					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling					
10	Hanipur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage					
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage					
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage					
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage					
14	Madanganj-35 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	35	55	55	55								
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	26	40	60	60								
16	Gaganpur 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	64	102	102								
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22								
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x4.73	80	80	31	31	35	35								
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	20	20	20								
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	33	33								
21	Cazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	22	25	51	51								
22	Cazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105								
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	32	48	150	150								
24	Kamalighat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35								
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	184	266	300	300								
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	76	89	149	149								
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200	300								
28	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100								
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100								
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55								
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55								
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	104	104								
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	162	162								
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0								
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	0	55	55	55								
36	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	48	48	51	51								
Dhaka Zone Total										5853	5696	1499	1846	2689	2779	2297	598
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	83	84	84	84	146		Low water level & maint.					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage					
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0								
40	Raocan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	17	17	17								
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0								
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	40	40	40								
43	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	60	17	105	105								
44	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.					
45	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	170	280	260	300								
47	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100								
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	50	70	90	90								
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	51	51								
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment Issue					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20								
	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			33	27	20	30								
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	59	89	90	90								
53	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	54	54								
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	43	17	110	110								
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	10	20	100	100								
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	100	116	116	116								
Chattogram Zone Total										2442	2382	686	856	1282	1307	506	473
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage					
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	100	100	134		Gas Shortage					
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40							
59	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+17x5	221	221	168	231	180	220								
60	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	260	280	280	300	80		Gas Shortage					
61	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	220	180	220	260	180		Gas Shortage					
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	6	50		Gas Shortage					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	8	8	195		Gas Shortage					
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51								
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	142	150	150								
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50								
67	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	47	45	50	50	118		Gas Shortage					
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	12	34	200	200								
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	21								
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11								
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	8	33	33								
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	30	52	52	52								
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	8	9	9								
74	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	96x1.4+6x1.01+15x1.09	200	200	0	0	100	200								
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+7*3.1	114	114	17	17	114	114								
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	105	113	113								
77	Bhairabi 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17								
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test					
**	Impoprt (Tripura)	India		160	160	99	98	138	164								
Cumilla Zone Total										2944	2899	1117	1360	1906	2134	926	0
78	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	80	112	80	115	90		Gas Shortage					
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22								
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	89	115	115								
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200								
83	Saishaban 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0								
84	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0								
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22								
Mymensingh Zone Total										717	622	459	445	491	474	90	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.01.22 (Yesterday)		29.01.22 (Today)		28.01.22 (Yesterday)	28.01.22 (Yesterday)	Status of Machines under shut-down/ Maintenance		
					Actual Generation (MW)		Probable Peak Generation (MW)				Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks
					Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22+1x33	97	70	30	30	30	30		40	GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barkatullah)	Gas (RPP)	19x2.90	51	51	48	48	51	51				
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	130	130	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	35	71	66	66				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	136	135	160	160	195		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x2.90	86	86	82	82	80	81				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	177	178	180	180	53		Gas Shortage	
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	10		Gas Shortage	
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibianna-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	285	330	330				
99	Bibianna-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibianna South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1364	1396	1512	1513	340	40	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35				
105	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	0	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	91	91	90	90				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	736	735	748	748				
Khulna Zone Total					2233	2229	904	826	1018	1333	410	0	
111	Barsal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	22	25	26				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	92				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	380	620	620	864		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyt BT)	Gas/HSD (IPP)	2x75+1x70	220	220	200	210	220	220				
Barishal Zone Total					2046	2046	611	714	1077	1229	0	864	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	43	43				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	50	50				
122	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	50	100	90	100				
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	32	40	40				
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	50	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0	50		Under maint.	
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	137	137	130	150	83		Gas Shortage	
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	258	288	300	300	126		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
131	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	94	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2129	2129	775	934	1220	1244	810	50	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	99	107	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Malpara, Talula 8 MW Solar PP (Sympa Powe Energy&ac Power Venture Thakurgan Ltd)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Rangpur Zone Total					685	605	303	306	321	328	160	85	
Sub-total: Plants in operation					21471	20985	7718.0	8683	11516	12341	5539	2110	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							7474	8408	11151	11950			
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					595	0	0	0	0	0	0	0	
Gross Total					22066	21035	7718	8683	11516	12341	5539	2110	
(C) Actual data of 28.01.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 8683.00	MW, at = 19:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 8408.00	MW, at = 19:00 hrs										
03.	Highest Generation (Generation end)	: 8683.00	MW, at = 19:00 hrs										
04.	Minimum Generation (Generation end)	: 6256.00	MW, at = 4:00 hrs										
05.	Day-peak Generation (Generation end)	: 7718.00	MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 8683.00	MW, at = 19:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5727.00	MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 5233	MW										
d)	Coal supply Limitation	: 160	MW										
b)	Low water level in Kaptai lake	: 146	MW										
c)	Plants under shut down/ maintenance	: 2110	MW										
10.	Total Energy (Generation + India Import)	: 177.33	MKWh										
	By Gas =	90.844	MKWh										
	By Coal =	13.464	MKWh										
	By Solar =	1.158	MKWh										
11.	Total Gas Supplied	: 724.56	MMCFD										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	2707	2707	0	Mymensingh	841	841	0					
	Chattoagram	906	906	0	Sylhet	316	316	0					
	Khulna	1035	1035	0	Barishal	231	231	0					
	Rajshahi	967	967	0	Rangpur	685	685	0					
	Cumilla	720	720	0									
					Total	8408	8408	0					
13.	Fuel cost :	(a) Gas = 90110020 Taka	(c) Coal = 64122670 Taka										
		(b) Oil = 340742849 Taka	Total = 494975539 Taka										