

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-Feb-22

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|---------------------------------------|---|----------------|--------------------|------------------|----------------------|------------------|------------------|
| | | | | | | | |
| 1 | Ghorasal Repowered CCPP Unit-1 | PDB | 1260 | 260 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCPP Unit-2 | PDB | 1210 | 180 | 222 | 5285000 | |
| 3 | Ghorasal TPP Unit-5 | PDB | 1210 | 190 | 0 | 0 | Gas shortage |
| 4 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1243+1122 | 365 | 0 | 0 | Under maint. |
| 5 | Ghorasal 78.5 MW PP(MAX) | ORPP | 2*40 | 0 | 0 | 0 | Contract Expired |
| 6 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 0 | 65863 | Gas shortage |
| 7 | Haripur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | Under maint. |
| 8 | Haripur 412 MW CCPP | EGCB | 1273+1139 | 412 | 0 | 0 | Gas shortage |
| 9 | Haripur 350MW CCPP(HPL) | IPP | 1235+1125 | 360 | 267 | 6712000 | Gas shortage |
| 10 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 225 | 5282000 | Gas shortage |
| 11 | Meghnaghat 100 MW(EL) | ORPP | 12*8.9 | 0 | 0 | 0 | Contract Expired |
| 12 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 335 | 0 | 0 | Gas shortage |
| 13 | Madanganj 102 PP(Summit) | ORPP | 6*17 | 0 | 0 | 0 | Contract Expired |
| 14 | Madanganj-55 MW PP(Summit) | ORPP | 3*17.08+1*11.3 | 55 | 40 | 524142 | Engine problem |
| 15 | Karanganj 102 MW PP (Powerpac) | ORPP | 8*13.45 | 100 | 60 | 833515 | Engine problem |
| 16 | Narsingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 495828 | |
| 17 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 18 | Siddhirgonj 2*120 MW GTTP | EGCB | 2*105 | 210 | 0 | 0 | Gas shortage |
| 19 | Siddhirgonj 100 PP(Dutch Bangla) | ORPP | 12*8.9 | 0 | 0 | 0 | Contract Expired |
| 20 | Siddhirgonj 335 MW CCPP | EGCB | 1217+118 | 335 | 0 | 0 | Gas shortage |
| 21 | Sagarajal 102 MW PP (Digital Po) | IPP | 12*8.924 | 102 | 102 | 1368684 | |
| 22 | Katobli 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 47 | 1122144 | |
| 23 | Kamalaghat 54 MW PP(Banco En) | IPP | 3*18 | 54 | 48 | 965880 | Engine problem |
| 24 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 133 | 1345440 | |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 1134983 | |
| 26 | Nabaganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 55 | 770411 | |
| 27 | Bosila 108MW RPCL | IPP | 12*9.17+13.5 | 0 | 0 | 0 | |
| 28 | Summit Power (Madhabdi-Ashuli) | SIPP, REB | 3*3.67+4*8.73 | 80 | 34 | 803760 | Engine problem |
| 29 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 610100 | Engine problem |
| 30 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 551300 | |
| 31 | Gazipur 52 MW PP | RPCL | 6*8.9 | 52 | 51 | 547680 | |
| 32 | Tongi 80 MW GTTP | PDB | 1*105 | 105 | 0 | 0 | Machine problem |
| 33 | Koinda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 300 | 4907780 | |
| 34 | Karanganj 300 MW PP (APR) | IPP | 25*11.4 | 300 | 27 | 125504 | Low Demand |
| 35 | Bramhangonj 100 MW PP (Aggr) | IPP | 100 | 100 | 100 | 252231 | |
| 36 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 60 | 163153 | Low Demand |
| 37 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 149 | 1796980 | |
| 38 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 105 | 2329200 | |
| 39 | Meghnaghat 104 MW PP (QPCL) | IPP | 18*5*9 | 104 | 104 | 2336640 | |
| 40 | Manikganj 162MW MPGL | IPP | 9*18 | 162 | 144 | 2856660 | Engine problem |
| 41 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 146052 | |
| Kanchan Purbachal Power Gener: | | | | 55 | 55 | 1199160 | |
| Dhaka Area Total | | | | 5696 | 2463 | 44550570 | |
| 42 | Chattogram TPP-1 | PDB | 1210 | 180 | 0 | 0 | Under maint. |
| 43 | Chattogram TPP-2 | PDB | 1210 | 180 | 0 | 0 | Gas shortage |
| 44 | Razzan 25 MW PP | IPP | 3*8.9 | 25 | 17 | 44731 | Engine problem |
| 45 | Taksoni 20MW PP (SolarTech/Teknaf SolarTech Energ | IPP | 20 | 20 | 0 | 131760 | |
| 46 | Patenga 50MW PP (Baraka) | IPP | 8*6.88 | 50 | 38 | 939840 | Engine problem |
| 47 | Kapla Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 46 | 1082760 | Low water level |
| 48 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 0 | 0 | Under maint. |
| 49 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 0 | 0 | Under maint. |
| 50 | Sikalbaha 105 MW PP (Baraka St) | IPP | 105 MW | 105 | 105 | 1562399 | |
| 51 | Hathazari 100 MW Peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | Under SID |
| 52 | Dohazari-Kalaish 100 MW Peaking | PDB | 6*17 | 102 | 51 | 112871 | Fuel shortage |
| 53 | Juidah 100 MW Unit-1 (Acorn) | ORPP | 8*13.45 | 100 | 10 | 50640 | High Voltage |
| 54 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 76 | 1018560 | Engine problem |
| 55 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 18 | 428784 | Engine problem |
| 56 | Malancha Cig. EP2 (United) | IPP | 5*8.73+3*9.34 | 0 | 10 | 504480 | |
| 57 | Chattogram 108 MW PP (ECPV) | IPP | 18*5.9 | 108 | 95 | 1776000 | Engine problem |
| 58 | Kapla 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 27480 | |
| 59 | Anwara 300 MW PP (United) | IPP | 300 MW | 300 | 268 | 6312873 | Engine problem |
| 60 | Jodiac Power | IPP | 3*18.55+1*3.6 | 54 | 17 | 98008 | High Voltage |
| 61 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 57 | 734324 | High Voltage |
| 62 | Juidah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 70 | 394560 | High Voltage |
| 63 | Anilima Energy Ltd. | IPP | 6*21.2 | 116 | 116 | 2772545 | |
| Chattogram area Total | | | | 2382 | 994 | 18012815 | |
| 64 | Ashuganj TPP Unit-3 | APSCCL | 1150 | 129 | 0 | 0 | Contract Expired |
| 65 | Ashuganj TPP Unit-4 | APSCCL | 1150 | 129 | 0 | 0 | Gas shortage |
| 66 | Ashuganj TPP Unit-5 | APSCCL | 1150 | 134 | 0 | 0 | Gas shortage |
| 67 | Ashuganj 225 MW CCPP | APSCCL | 1*142+1*175 | 221 | 155 | 4308000 | #REF! |
| 68 | Ashuganj 450 MW CCPP(North) | APSCCL | 1*360 | 360 | 220 | 4776800 | Gas shortage |
| 69 | Ashuganj 450 MW CCPP(South) | APSCCL | 1*360 | 360 | 300 | 6942000 | FGMO |
| 70 | Ashuganj 50 MW CCPP | APSCCL | 14*3.968 | 45 | 5 | 153984 | Gas shortage |
| 71 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 5 | 142080 | Gas shortage |
| 72 | Ashuganj 195MW PP (APSCCL-UR) | IPP | 20*9.73+1*16 | 195 | 16 | 334545 | Gas shortage |
| 73 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1206900 | |
| 74 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 140 | 2964072 | Engine problem |
| 75 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 50 | 50 | 550516 | |
| 76 | Chandpur 150 MW Peaking PP | IPP | 1*106+1*57 | 163 | 129 | 3075880 | |
| 77 | Chandpur 200MW (Dash energy) | IPP | 0 | 200 | 142 | 2452320 | High Voltage |
| 78 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 21 | 477864 | |
| 79 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 8 | 183600 | Engine problem |
| 80 | Impport (Tripura) | Imported power | 0 | 160 | 104 | 2190720 | |
| 81 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 25 | 469900 | Engine problem |
| 82 | Jangalia 52 MW PP (Midland) | IPP | 8*6.92 | 52 | 52 | 1194568 | |
| 83 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*9.27 | 25 | 9 | 225770 | Engine problem |
| 84 | Daudkandi 200 MW PP (B. Trac) | IPP | 154*1.4 | 200 | 0 | 0 | Reserve. |
| 85 | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 70 | 956460 | High Voltage |
| 86 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 108 | 796320 | |
| 87 | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 17 | 444960 | 33 kV feeder O/L |
| 88 | Chandpur 115(Doreen) | IPP | 115 | 0 | 0 | 237120 | On test |
| Cumilla Area Total | | | | 2989 | 1627 | 34083979 | |
| 89 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 66 | 1988720 | Gas shortage |
| 90 | Tangal 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 22 | 514044 | |
| 91 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 8 | 0 | 0 | Under maint. |
| 92 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 9450 | |
| 93 | Mymensingh 200 MW PP (Unitec) | IPP | 200 | 200 | 200 | 3897600 | |
| 94 | Jamalpur 115 MW PP (Unitec) | IPP | 115 MW | 115 | 109 | 1767600 | |
| 95 | Srikalahari 50 MW Solar PP | IPP | 50 | 50 | 0 | 1988880 | |
| 96 | Tangal Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 22 | 512160 | |
| Mymensingh Area Total | | | | 622 | 419 | 8896434 | |
| 97 | Fenchugonj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 30 | 715000 | Machine problem |
| 98 | Fenchugonj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 30 | 701552 | Machine problem |
| 99 | Kushara 163 MW CCPP (KP) | IPP | 1*106+1*54 | 163 | 110 | 2913054 | Gas shortage |
| 100 | Shahbazar 330 MW CCPP | PDB | 3*110 | 330 | 137 | 3271000 | Gas shortage |
| 101 | Fenchugonj 51 MW (Barakati) | RPP | 19*2.90 | 51 | 53 | 1083600 | |
| 102 | Fenchugonj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 0 | 0 | 0 | Contract Expired |
| 103 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 11 | 206688 | |
| 104 | Shahbazar GTTP Unit- 8 & 9 | PDB | 2*35 | 66 | 67 | 1406160 | |
| 105 | Shahbazar 96MW PP (Shahbaz) | RPP | 32*2.90 | 86 | 78 | 1761600 | |
| 106 | Shahbazar 100 MW GTTP | PDB | 1*100 | 100 | 0 | 0 | Machine problem |
| 107 | Sylhet 225 MW GTTP | PDB | 1*142+1*89 | 231 | 177 | 4240700 | Machine problem |
| 108 | Sylhet 20 MW GTTP | PDB | 1*20 | 20 | 0 | 0 | Gas shortage |
| 109 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 0 | 0 | 0 | Contract Expired |
| 110 | Shahjahanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 16 | 384966 | Engine problem |
| 111 | Biliana-II 341 MW CCPP (Summit) | IPP | 1*222+1*119 | 341 | 290 | 7060000 | FGMO |
| 112 | Biliana-III 400 MW CCPP | PDB | 400 MW | 400 | 0 | 0 | Under maint. |
| 113 | Sylhet 10MW PP (Dash) | RPP | 8*1.95 | 10 | 10 | 239440 | Line O/L |
| 114 | Biliana South 400 MW | PDB | 400 MW | 383 | 400 | 8922600 | |
| Sylhet Area Total | | | | 2377 | 1409 | 32905960 | |
| 115 | Bheramara GTTP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | Reserve. |
| 116 | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 737 | 17613090 | |
| 117 | Khulna 115 MW (KPCL-2) | ORPP | 7*17 | 0 | 0 | 0 | Contract Expired |
| 118 | Fariapur 50 MW Peaking PP | PDB | 8*6.88 | 54 | 34 | 208800 | Engine problem |
| 119 | Khulna 225 MW CCPP | NWPGCL | 1*150+1*175 | 230 | 0 | 0 | Reserve. |
| 120 | Gopalganj 100 MW Peaking PP | PDB | 16*6.88 | 109 | 0 | 7552 | Reserve. |
| 121 | Bheramara 410 MW CCPP | NWPGCL | 1*278+1*132 | 410 | 0 | 0 | Gas shortage |
| 122 | Noapara 40 MW PP (Khanjahan A) | ORPP | 5*8.5 | 0 | 0 | 0 | Contract Expired |
| 123 | Noapara 100 MW PP (Bangla Tr) | IPP | 70*1.4 | 100 | 70 | 112320 | Low Demand |
| 124 | Rupsha 105 MW PP (Orion rupsh) | IPP | 6*18.445 | 105 | 92 | 1576800 | Engine problem |
| 125 | Madhumati 100 MW PP | NWPGCL | 100 MW | 105 | 0 | 0 | Line O/L |
| 126 | Mongla Orion 100 MW Solar PP | IPP | 100 | 100 | 0 | 390960 | On test |
| Khulna Area Total | | | | 2229 | 933 | 19909522 | |
| 127 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 0 | 0 | Line O/L |
| 128 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 20 | 374816 | Engine problem |
| 129 | Bhola 225 MW CCPP | PDB | 2*63+1*68 | 194 | 91 | 2196358 | Machine problem |
| 130 | Bhola 95 MW PP (Aggreko) | ORPP | 96*1.10 | 95 | 25 | 1654093 | Gas shortage |
| 131 | Payra 1320 MW | BPCL | 2*622 | 1244 | 400 | 10347400 | Line O/L |
| 132 | Bhola Nutan Bidut BD LTD | IPP | 220 | 220 | 220 | 1868536 | |
| 133 | United Payra Power Ltd. | IPP | 8*18.5+1*9.5 | 150 | 0 | 0 | Line O/L |
| Barisal Area Total | | | | 2046 | 756 | 16459503 | |
| 134 | Baghabari 71 MW GTTP | PDB | 1*71 | 71 | 0 | 0 | |