

## EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 4-Feb-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-1	PDB	1760	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1760	180	152	4545000	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Under maint.
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	67954	Gas shortage
7	Harpur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Harpur 412 MW CCGP	EGCB	1273+1139	412	0	0	Gas shortage
9	Harpur 350MW CCGP(HPL)	IPP	1235+1125	360	333	6960000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	200	5094750	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	0	0	Reserve.
15	Karanganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	0	0	Reserve.
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	363024	
17	210 MW Siddhirgonj TPP	PDB	12*10	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCGP	EGCB	12*17+1*18	335	0	0	Gas shortage
21	Sagaura 102 MW PP (Digital Po)	IPP	12*8.924	102	64	236304	Low Demand
22	Katolli 52 MW PP (Sinha)	IPP	7*7.9	51	46	977664	Engine problem
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	942120	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	3360	Reserve.
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	302637	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	0	54265	33 kV feeder problem
27	Bosila 108MW RPCL	IPP	12*9.15+1*3.5	0	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	34	742560	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	16	513900	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	632600	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	0	0	Reserve.
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	150	1109818	Low Demand
34	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	126	406101	Low Demand
35	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.
36	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	0	0	Reserve.
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	1062780	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	1216320	
40	Manikganj 162MW MPGL	IPP	9*18	162	162	2152600	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	40927	
Kanchan Purbachal Power Gener				55	55	55	748440
<b>Dhaka area Total</b>				<b>5696</b>	<b>1705</b>	<b>28172524</b>	
42	Chattogram TPP-1	PDB	1210	180	0	0	Under maint.
43	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	0	86176	Reserve.
45	Takson 20MW PP (Solartech/Teknaf Solar/Energ	IPP	20	20	0	141210	
46	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	39	927360	Engine problem
47	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	46	1056000	Low water level
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	34	433236	Low Demand
51	Hathazari 100 MW Peaking PP	IPP	11*9.9	99	0	0	Under SD
52	Dokhazari-Kalash 100 MW Peaking	PDB	6*17	102	0	0	Reserve.
53	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	0	0	Reserve.
54	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	792000	Engine problem
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	18	432288	Engine problem
56	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	37	783360	
57	Chattogram 108 MW PP (ECPV)	IPP	18*5.74	108	71	1449600	Engine problem
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	28320	
59	Anwara 300 MW PP (Unite)	IPP	300 MW	300	230	3904145	High Voltage
60	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	High Voltage
61	Karnaphuli Power Ltd.	IPP	110	110	0	0	High Voltage
62	Juddah unit-2 (Acorn)	IPP	8*13.6	100	0	108480	High Voltage
63	Anima Energy Ltd.	IPP	6*21.2	116	116	2553000	
<b>Chattogram area Total</b>				<b>2382</b>	<b>681</b>	<b>12897175</b>	
64	Ashuganj TPP Unit-3	APSCCL	1150	129	0	0	Contract Expired
65	Ashuganj TPP Unit-4	APSCCL	1150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCCL	1150	134	0	0	Gas shortage
67	Ashuganj 225 MW CCGP	APSCCL	1*142+1*175	221	226	4520000	#REF!
68	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	0	3157100	
69	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	320	6485000	FGMO
70	Ashuganj 50 MW CCGP	APSCCL	14*3.968	45	29	277848	Gas shortage
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	204960	Gas shortage
72	Ashuganj 195MW PP (APSCCL-UR)	IPP	20*9.73+1*16	195	73	736000	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1005292	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	120	799563	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
76	Chandpur 150 MW CCGP	IPP	1*106+1*157	163	137	3119160	
77	Chandpur 200MW (Dash energy)	IPP	0	200	51	518400	High Voltage
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	501120	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	7	181080	Engine problem
80	** Imoport (Tripura)	Imported power	0	160	72	1741440	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	548400	Engine problem
82	Jangalia 52 MW PP (Ladabnaw)	IPP	8*6.92	52	34	963946	High Voltage
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*9.27	25	9	172190	Engine problem
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	406980	High Voltage
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	65	523320	Low Demand
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	430920	33 kV feeder O/L
88	Chandpur 115(Doreen)	IPP	115	0	0	0	On test
<b>Cumilla Area Total</b>				<b>2899</b>	<b>1179</b>	<b>26297918</b>	
89	RPCL 210MW CCGP	IPP	4*35+1*70	202	121	2516180	Gas shortage
90	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	491328	
91	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	1550	
93	Mymensingh 200 MW PP (Unite)	IPP	200	200	100	1322400	High Voltage
94	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	35	153600	High Voltage
95	Sutkhalhi 50 MW Solar PP	IPP	50	50	0	681330	
96	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	22	410160	
<b>Mymensingh Area Total</b>				<b>622</b>	<b>290</b>	<b>4963328</b>	
97	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	20	664000	Machine problem
98	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	0	511472	Machine problem
99	Kushara 163 MW CCGP (KP)	IPP	1*109+1*54	163	110	2886709	Gas shortage
100	Shahbazari 330 MW CCGP	PDB	3*110	330	132	3163000	Gas shortage
101	Fenchugonj 51 MW (Barakata)	RPP	19*2.90	51	46	1004000	
102	Fenchugonj 44MW (Energyprima)	RPP	12*3.5+5*2	0	0	0	Contract Expired
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	203136	
104	Shahibazar GTTP Unit- 8 & 9	PDB	2*35	66	69	1323840	
105	Shahibazar 96MW PP (Shahibaz)	RPP	32*2.90	86	78	1347840	
106	Shahibazar 100 MW GTTP	PDB	1*100	100	0	0	Machine problem
107	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	177	4110320	Machine problem
108	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
109	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
110	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	385466	Engine problem
111	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	310	6950000	FGMO
112	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.
113	Sylhet 10MW PP (Dash)	ORPP	8*1.95	10	10	289890	Line O/L
114	Bibiyana South 400 MW	PDB	400 MW	383	330	8229300	
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1308</b>	<b>31052563</b>	
115	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
116	** Bheramara (HVDC)	Imported power	2*500	1000	641	16514181	
117	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
118	Farpur 20 MW Peaking PP	PDB	8*6.88	54	0	0	Reserve.
119	Khulna 225 MW CCGP	NWPGCL	1*150+1*175	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
121	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
122	Noapara 40 MW PP (Khanjahan A)	ORPP	5*8.5	0	0	0	Contract Expired
123	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	0	0	Reserve.
124	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	70	558240	High Voltage
125	Madhumati 100 MW PP	PDB	2*52	100	0	0	Reserve.
126	Mongla Orion 100 MW Solar PP	NWPGCL	100	100	0	177840	Line O/L
<b>Khulna Area Total</b>				<b>2229</b>	<b>711</b>	<b>17280261</b>	
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
128	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	8	275100	Engine problem
129	Bhola 225 MW CCGP	PDB	2*63+1*68	194	79	2078759	Machine problem
130	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	0	161819	Gas shortage
131	Payra 130 MW CCGP	BPCL	2*62	124	0	5573590	Tripped at 15:32
132	Bhola Nutan Bidut BD LTD	IPP	220	210	0	4065982	
133	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
<b>Barisal Area Total</b>				<b>2046</b>	<b>297</b>	<b>12155160</b>	
134	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
135	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
136	Baghabari 50 MW Peaking PP	PDB	8*6.9	52	0	0	Reserve.
137	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
138	Amnura 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	Contract expired
139	Katakhalhi 50 MW PP (Northern)	ORPP	6*8.9	50	0	0	Fuel shortage
140	Katakhalhi 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve.
141	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
142	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Gas shortage
143	Sirajgonj 230 MW CCGP	NWPGCL	1*141	230	138	3364945	Gas shortage
144	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	333	7063927	Gas shortage
145	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	0	Engine problem
146	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	489120	
147	Bogra 20 MW PP (Energyprima)	RPP	5*3.5+5*2	0	0	0	Contract Expired
148	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	5	55494	Engine problem
149	Natore 52 MW PP (Barakata)	PDB	8*6.92	52	52	771360	
150	Chapainawabganj 100 MW Peaking	PDB	12*8.924	104	100	319104	
151	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.
152	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	50	198624	Low Demand
153	Confidence Power Bogura Unit-1	IPP	6*18.55	113	70	195744	Low Demand
154	Sirajgonj 6.55 MW Solar	NWPGCL					