

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 9-Feb-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated		Remarks
						MW	KWH	
Unit No. X Capacity								
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1'260	260	0	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	220	5284000	0	Gas shortage
3	Ghorasal 1TP Unit-5	PDB	1'120	190	0	0	0	Under maint.
4	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	0	0	0	Under maint.
5	Ghorasal 78.5 MW PPI(MAX)	QRPP	2'40	0	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	73181	0	Gas shortage
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	282	6572030	0	Gas shortage
9	Haripur 360MW CAPP(PL)	IPP	1'235+1'125	360	0	0	0	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	250	5311700	0	GT-1 S/D due to gas shortage
11	Meghnaghat 100 MW(IEI)	QRPP	12'8.9	0	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	0	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	40	548701	0	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	58	384378	0	Engine problem
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	421776	0	Under maint.
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	0	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	0	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	93	1127088	0	Gas shortage
22	Katpatti 52 MW PP (Simha)	IPP	7'7.9	51	0	0	0	Fuel shortage
23	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	871200	0	High Voltage
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	82	387360	0	High Voltage
25	Maniganj 55 MW PP (Northern)	IPP	3'19.3	55	0	0	0	Engine problem
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	960780	0	Under maint.
27	Bosilia 108MW PP(IEI)	IPP	12'8.775+1'3.5	0	0	0	0	Under maint.
28	Summit Peaking Ashab+Ashulia	SIPP, REB	3'3.67+8.73	80	44	1041900	0	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	631200	0	Engine problem
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	837400	0	Under maint.
31	Gazipur 52 MW PP	RPCL	6'8.9	52	45	333600	0	Under maint.
32	Tongi 80 MW GTPP	PDB	1'105	105	0	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'11.076	300	301	4681998	0	Under S/D
34	Keraniganj 300 MW PP (APR)	IPP	260'1.4	300	106	167341	0	Engine problem
35	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	100	151889	0	High Voltage
36	Aurahali 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	100	143715	0	High Voltage
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1461600	0	High Voltage
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	2077200	0	High Voltage
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	2120640	0	High Voltage
40	Maniganj 162MW PP(MPGL)	IPP	9'18	162	156	2354400	0	High Voltage
41	Spectra Solar Plant Ltd.	IPP	35	35	0	182802	0	High Voltage
42	Kanchan Purbanchal Power Generation Ltd.	IPP	55	55	0	631440	0	High Voltage
Dhaka area Total				5696	2399	38769319		
43	Chattogram TPP-1	PDB	1'210	180	0	0	0	Under maint.
44	Chattogram TPP-2	PDB	1'210	180	0	0	0	Gas shortage
45	Racozan 25 MW PP	IPP	3'8.9	25	17	277617	0	Engine problem
46	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ener	20	20	0	144855	0	Engine problem
47	Pastaga 50MW PP (Baraka)	IPP	8'6.88	50	40	96192	0	Engine problem
48	Kapali Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	46	1042260	0	Low water level
49	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	0	Under maint.
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	105	1115709	0	Under S/D
52	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	0	Engine problem
53	Dohazari-4250 MW Peaking	IPP	6'18	102	51	142615	0	High Voltage
54	Juldah 100 MW Unit-1 (Accorn)	QRPP	8'13.45	100	0	0	0	High Voltage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	0	100	90	1097280	0	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	15	363696	0	Engine problem
57	Malancha, Ctg. EPZ (Uniled)	IPP	5'8.73+3'9.34	0	16	576000	0	Engine problem
58	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	90	2033280	0	Engine problem
59	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	25221	0	Engine problem
60	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	293	5246873	0	Engine problem
61	Jotiack Power	IPP	3'18.55+1'3.6	54	17	261154	0	High Voltage
62	Karnaphuli Power Ltd.	IPP	110	110	68	623088	0	High Voltage
63	Juldah unit-2 (Accorn)	IPP	8'13.6	100	40	318720	0	High Voltage
64	Anlima Energy Ltd.	IPP	6'21.2	116	116	2432564	0	High Voltage
Chattogram area Total				2382	994	15901424		
65	Ashuganj TPP Unit-3	APSCl	1'150	129	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCl	1'150	129	0	0	0	Gas shortage
67	Ashuganj TPP Unit-5	APSCl	1'150	134	0	0	0	Gas shortage
68	Ashuganj 225 MW CAPP	APSCl	1'142+1'175	221	186	4626000	0	#REF!
69	Ashuganj 450 MW CAPP(North)	APSCl	1'360	360	315	6864900	0	Gas shortage
70	Ashuganj 450 MW CAPP(South)	APSCl	1'360	360	300	6930000	0	FGMO
71	Ashuganj 50 MW PP	APSCl	14'3.968	45	5	150768	0	Gas shortage
72	Ashuganj 65 MW PP (Precision)	IPP	15'4	55	5	143040	0	Gas shortage
73	Ashuganj 195MW PP (APSCl-Uniled)	IPP	20'9.73+1'16	195	8	217454	0	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1177152	0	Reserve.
75	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	150	2534170	0	Reserve.
76	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	0	Machine problem
77	Chandpur 150 MW CAPP	PDB	1'106+1'157	163	124	3105880	0	High Voltage
78	Chandpur 200 MW (Desh energy)	IPP	0	200	16	100800	0	High Voltage
79	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	497196	0	Engine problem
80	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	5	131220	0	Engine problem
81	Impoort (Tripura)	Imported power	0	160	110	2205120	0	Engine problem
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	723600	0	Engine problem
83	Jangalia 52 MW PP (Lakdhanw)	IPP	6'8.92	52	52	1026929	0	Engine problem
84	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'9.97	25	20	454620	0	Reserve.
85	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	0	High Voltage
86	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	69540	0	High Voltage
87	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	1242360	0	High Voltage
88	Bhairab 54.5 MW	IPP	3'18.2	54	17	434160	0	33 kV feeder O/L
89	Chandpur 115(Doreen)	IPP	115	0	119	2862720	0	RRT
Cumilla Area Total				2899	1667	35600729		
90	RPCL 210MW CAPP	IPP	4'35+1'70	202	92	2319360	0	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	388692	0	Under maint.
92	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	8	0	0	0	Under maint.
93	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13400	0	Engine problem
94	Mymensingh 200 MW PP (Uniled)	IPP	200	200	200	3530400	0	Engine problem
95	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	109	1404000	0	Engine problem
96	Sutahall 50 MW Solar PP	IPP	50	50	0	308520	0	Engine problem
97	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	22	524640	0	Engine problem
Mymensingh Area Total				622	443	8489012		
98	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	30	715000	0	Machine problem
99	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	43	1000584	0	Machine problem
100	Kushiara 163 MW CAPP (KP)	IPP	1'109+1'54	163	110	2920581	0	Gas shortage
101	Shahbazar 330 MW CAPP	PDB	3'110	330	144	3161000	0	GT-2 S/D due to gas shortage
102	Fenchugonj 51 MW PP (Barkatullah)	IPP	19'2.90	51	48	1174900	0	Contract Expired
103	Fenchugonj 44MW (Energyprima)	RPP	12'3.5+5'2	0	0	0	0	Contract Expired
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	140976	0	Contract Expired
105	Shahbazar GTTP Unit-8 & 9	PDB	2'35	66	40	126736	0	Machine problem
106	Shahbazar 86MW PP (Shahbazar)	RPP	32'2.90	86	61	1422720	0	Gas shortage
107	Shahbazar 100 MW GTTP	PDB	1'100	100	0	0	0	Under maint.
108	Syhet 225 MW CAPP	PDB	1'142+1'189	231	151	3895970	0	Gas shortage
109	Syhet 20 MW GTTP	PDB	1'20	0	0	0	0	Contract Expired
110	Syhet 50MW PP (EPL)	RPP	2'72	0	0	0	0	Contract Expired
111	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	376460	0	Engine problem
112	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	290	7019000	0	FGMO
113	Bibyana-III 400 MW CAPP	PDB	400 MW	400	0	0	0	Under maint.
114	Syhet 10MW PP (Desh)	RPP	6'1.95	10	10	245520	0	Under maint.
115	Bibyana South 400 MW	PDB	400 MW	383	400	8111900	0	Under maint.
Syhet Area Total				2377	1346	31440847		
116	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	0	Reserve.
117	Bheramara (HVDC)	Imported power	2'500	1000	737	17592727	0	Contract Expired
118	Khulina 115 PP MW (KPCL-2)	QRPP	7'17	0	0	0	0	Contract Expired
119	Faridpur 50 MW Peaking PP	PDB	6'8.9	54	17	56130	0	Engine problem
120	Khulina 225 MW CAPP	NWPGCL	1'150+1'175	230	0	0	0	Reserve.
121	Copalganj 100 MW Peaking PP	PDB	16'8.98	109	0	9216	0	High Voltage
122	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	0	0	0	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5'8.5	0	0	0	0	Contract Expired
124	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	49	54720	0	Contract Expired
125	Rupsha 105 MW PP (Orion rupsha)							