

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month February, 2022		Day : Thursday				Date : 10.02.22						
Probable Maximum Demand :		9800 MW				Probable Maximum Generation : 12445 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 92.89 ft		Today = 92.84 ft		Rule Curve = 95.74 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.02.22 (Yesterday)		10.02.22 (Today)		09.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)		Description/Remarks
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	220	220			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maintenance	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	250	262	280	280			
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	10	58	60	60			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93			
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	43	44	50	50			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	45	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	105			
23	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	16	82	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	282	301	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	86	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	106	200	300			
28	Branhangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	156	162	162			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	0	55	55			
36	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	51	51	51			
Dhaka Zone Total				5853	5696	1888	2399	2764	2839	1670	958	
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	46	46	46	184	Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
40	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	40	40	40	40			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	235	283	283	283			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	19	20			
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			6	16	10	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	86	90	90	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	54	54			
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	68	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	40	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	110	116	116	116			
Chattogram Zone Total				2442	2382	741	994	1256	1252	544	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	193	186	200	200			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	285	300	300	300			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	370	315	360	360			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	5	5	5	5	50	Gas Shortage	
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	150	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	125	124	125	130			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	16	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	33	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	16	20			
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	99x1.4+6x1.915+15x1.099	200	200	0	0	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	17	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	34	113	113	113			
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				119	119	115	0		On Test	
**	Import (Tripura)	India		160	160	94	110	138	164			
Cumilla Zone Total				2944	2899	1557	1667	2178	2198	540	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	90	92	100	100	110	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	103	109	110	110			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	191	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
85	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total				717	622	453	443	506	454	110	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.02.22 (Yesterday)		10.02.22 (Today)		09.02.22 (Yesterday)		Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT-1 Under maint.
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	43	43	42	43		47	GT-4 Under maint.
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	45	48	51	51			
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage
90	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	65	66			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	144	144	140	150	186		Gas Shortage
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	59	61	75	80			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	152	151	150	160	80		Gas Shortage
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	16	17		Gas Shortage
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	330	330			
99	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			
100	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work
Sylhet Zone Total					2422	2377	1339	1346	1430	1457	356	87
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	17	0	35			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220			
107	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	49	80	100			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105			
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	737	737	752	752			
Khulna Zone Total					2233	2229	923	908	1037	1352	410	0
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	19	20	24			
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	91	90	92	103		Gas Shortage
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	76	76			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	410	620	620		834	Line Overload
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	163	214	220	220			
Barishal Zone Total					2046	2046	559	745	1136	1292	103	834
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	12	49	50	50			
122	Chapaiwawaganj 100 MW Peaking PI	HFO (PDB)	12x8.524	104	104	50	100	90	100			
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40			
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	24	34	50	50			
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	32			
126	Siraggonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
127	Siraggonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	20	100	120	200		Gas Shortage
128	Siraggonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	126	0	0	0	220		Gas Shortage
129	Siraggonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	312	280	350	360	134		Gas Shortage
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	43	43	43			
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	113	113			
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
135	Siraggonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total					2129	2129	800	938	1212	1288	935	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	107	108	113	113			
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
Rangpur Zone Total					685	605	350	308	321	313	159	85
Sub-total: Plants in operation					21471	20985	8610.0	9748	11840	12445	4827	2437
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					8238	9327	11328	11908				
(B) Plants under long term maintenance/contract expired												
142	Bosila 106MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
143	108Riganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
147	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
148	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired					595	50	0	0	0	0	0	0
Gross Total					22066	21035	8610	9748	11840	12445	4827	2437
(C) Actual data of 09.02.22 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	: 9748.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9327.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9748.00 MW, at = 19:00 hrs	Dhaka	3368	3368	0	Mymensingh	862	862	0		
04.	Minimum Generation (Generation end)	: 5915.00 MW, at = 5:00 hrs	Chattoagram	1040	1040	0	Sylhet	333	333	0		
05.	Day-peak Generation (Generation end)	: 8610.00 MW, at = 12:00 hrs	Khulna	1094	1094	0	Barishal	225	225	0		
06.	Evening-peak Generation (Generation end)	: 9748.00 MW, at = 19:00 hrs	Rajshahi	931	931	0	Rangpur	692	692	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	782	782	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5950.00 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas Limitation	: 4484 MW	13.	Fuel cost :	(a) Gas = 97710090 Taka	(c) Coal = 64417100 Taka						
d)	Coal supply Limitation	: 159 MW		(b) Oil = 378362612 Taka	Total = 540489803 Taka							
b)	Low water level in Kaptai lake	: 184 MW										
c)	Plants under shut down/ maintenance	: 2437 MW	14.	Maximum Temperature in Dhaka was :	26.5° C							
10.	Total Energy (Generation + India Import)	: 190.89 MKWh	15.	Export through East-West interconnections :								
	By Gas = 98.735 MKWh	By Oil = 56.531 MKWh		At evening peak-hour	: -212 MW, at 19:00 hrs							
	By Coal = 13.534 MKWh	By Hydro = 1.042 MKWh		Maximum	: -230 MW, at 18:30 hrs							
	By Solar = 1.250 MKWh			Energy	: 0.444 MKWh							
11.	Total Gas Supplied	: 763.85 MMCFD										
(D) Forecast of 10.02.22 (Today) Thursday :												
01.	Maximum Demand	: 9800 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 12445 MW (Generation end)	05.	Total Generation	: 191.91 MKWh							
03.	Maximum Shortage	: -2645 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	26.8° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation