

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2022				Day : Saturday				Date : 12.02.22					
Probable Maximum Demand : 9600 MW				Probable Maximum Generation : 12787 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 92.78 ft				Today = 92.68 ft					
				Rule Curve = 95.60 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.02.22 (Yesterday)		12.02.22 (Today)		11.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	220	149	220	220				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	111	107	107	-3		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage	
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maintenance	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	253	252	280	280				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		217	118	Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	40	40				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	10	10	60	60				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	48	93	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	15	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	53	55	56				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	22	25	25				
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	0	150	150				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	194	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	65	50	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200	300				
28	Bramhangoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	104	104	104				
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	17	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	51	51				
Dhaka Zone Total				5853	5696	1718	1735	2876	2952	1559	958		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	17	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	40	40	40				
43	Sikalbaha 105 MW PP (Baraka Sikalbe)	HFO (IPP)	6x18.415	105	105	17	34	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	283	249	283	283				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	30	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		98	Environment Issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20				
*	Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34			31	42	15	35				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	65	91	90	90				
53	Sikalbaha 54 MW PP (Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	10	100	100				
56	Chattogram 116 MW PP (Anlima Enerç)	HFO (IPP)	6x21.06	116	116	97	116	116	116				
Chattogram Zone Total				2442	2382	670	752	1261	1257	544	473		
57	a) Ashuganj TPP Unit- 4	Gas (APSCS)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCS)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCS)	14x3.968	53	45	26	26	29	29	19		Gas Shortage	
59	Ashuganj 225 MW CAPP	Gas (APSCS)	1x142+175	221	221	204	200	225	225				
60	Ashuganj 450 MW CAPP(South)	Gas (APSCS)	1x360	360	360	320	265	300	360				
61	Ashuganj 450 MW CAPP(North)	Gas (APSCS)	1x361	360	360	227	237	300	360				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	15	15	15	15	40		Gas Shortage	
63	Ashuganj 195MW PP (APSCS-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	8	8	187		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	10	150	150				
66	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	0	50	50				
67	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	125	125	125	125				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	16	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	16	21				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	51	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	67	68	113	113				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	115	0			On Test	
**	Impoport (Tripura)	India		160	160	88	96	138	164				
Cumilla Zone Total				2944	2899	1336	1281	2177	2313	509	0		
78	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	93	106	170	175	96		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	20	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	45	85	110	110				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	170	181	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0				
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Mymensing Zone Total				717	622	395	414	576	529	96	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.02.22 (Yesterday)		12.02.22 (Today)		11.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
86	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT 1 Under maint.		
87	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	42	43		47	GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	51	51	51					
89	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage		
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	68	65	66					
92	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	144	140	140	150	190		Gas Shortage		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	80	84					
94	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage		
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage		
98	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	300	330	330					
99	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0					
100	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work		
Sylhet Zone Total					2422	2377	1410	1440	1465	1481	326	87		
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40					
106	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	80	100					
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	93	93	93					
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100					
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	70	0	50	0					
**	Bheramara (HVDC)	India		1000	1000	0	738	752	752					
Khulna Zone Total					2233	2229	164	831	1025	1340	410	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	20	20	24					
113	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	183	183	185	185	11		Gas Shortage		
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	310	400	620	620		844	Line Overload		
116	Potuaikhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150					
117	Bhola 220MW CCGP (Nutan Bidyut BD)	Gas/HSD (IPP)	2x75+1x70	220	220	105	112	110	112					
Barishal Zone Total					2046	2046	629	726	1056	1212	11	844		
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	34	34					
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	10	9	50	50					
122	Chapainawabganj 100 MW Peaking PF	HFO (PDB)	12x8.924	104	104	50	100	90	100					
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	21	0	0	40					
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	8	43	43					
125	Santalar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	30	32					
126	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
127	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	198	175	180	180	45		Gas Shortage		
128	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
129	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	330	415	350	400	-1		Gas Shortage		
130	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	50	113	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
Rajshahi Zone Total					2129	2129	840	1063	1294	1390	645	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	113	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
141	Majipara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
	Energypac Power Venture Thakurgaon Ltd.	HFO (IPP)				0	0	0	0					
Rangpur Zone Total					685	605	317	313	321	313	159	85		
Sub-total: Plants in operation					21471	20985	7479.0	8555	12051	12787	4259	2447		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							7127	8152	11483	12185				
(B) Plants under long term maintenance/ contract expired														
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
143	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
146	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
148	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired					595	50	0	0	0	0				
Gross Total					22066	21035	7479	8555	12051	12787	4259	2447		
(C) Actual data of 11.02.22 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	8555.00	MW,	at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	8152.00	MW,	at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8555.00	MW,	at =	19:30 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	5954.00	MW,	at =	5:00 hrs	Dhaka	2663	2663	0	Mymensingh	797	797	0
05.	Day-peak Generation (Generation end)	:	7479.00	MW,	at =	12:00 hrs	Chattogram	950	950	0	Sylhet	318	318	0
06.	Evening-peak Generation (Generation end)	:	8555.00	MW,	at =	19:30 hrs	Khulna	1007	1007	0	Barishal	204	204	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:30 hrs	Rajshahi	903	903	0	Rangpur	617	617	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5534.00	MW,	at =	5:00 hrs	Cumilla	693	693	0				
09.	Generation shortfall at evening peak due to :	:									Total	8152	8152	0
	a) Gas limitation	:	3916	MW			13.	Fuel cost :	(a) Gas = 103226747	Taka	(c) Coal = 64765929	Taka		
	d) Coal supply Limitation	:	159	MW					(b) Oil = 310141902	Taka	Total = 478134578	Taka		
	b) Low water level in Kaptai lake	:	184	MW										
	c) Plants under shut down/ maintenance	:	2447	MW			14.	Maximum Temperature in Dhaka was :	25.8° C					
10.	Total Energy (Generation + India Import)	:	173.34	MKWh			15.	Export through East-West interconnections :						
	By Gas =	98.485	MKWH		By Oil =	47.244	MKWh	At evening peak-hour	40	MW,	at	19:30 hrs		
	By Coal =	13.616	MKWH		By Hydro =	1.074	MKWh	Maximum	-812	MW,	at	8:00 hrs		
	By Solar =	1.028	MKWH					Energy	1.154	MKWh				
11.	Total Gas Supplied	:	801.85	MMCFD										
(D) Forecast of 12.02.22 (Today) Saturday :														
01.	Maximum Demand	:	9600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12787	MW	(Generation end)		05.	Total Generation	:	194.51	MKWh			
03.	Maximum Shortage	:	-3187	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	25.3° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation