

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month February, 2022											Day : Sunday				Date : 13.02.22			
Probable Maximum Demand : 10300 MW											Probable Maximum Generation : 12595 MW				Rule Curve = 95.32 ft			
Water Level of Kaptai Lake at 06:00 AM											Yesterday = 92.68 ft				Today = 92.56 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.02.22 (Yesterday)		13.02.22 (Today)		12.02.22 (Yesterday)		13.02.22 (Today)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date						
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)								
(A) Plants in operation:																		
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work					
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	217	220	220									
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365			Gas Shortage					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	43	0	0	0	108			Gas Shortage					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.					
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360		Under maintenance					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling					
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	15	210	360	360									
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage					
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	43	40	40									
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	45	60	60									
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	93	93	93									
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	22	22	22									
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+4x3.73	80	80	47	33	55	56									
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	25	25									
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33									
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	43	51	51									
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	100	105									
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	150	150									
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54									
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	130	260	300	300									
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	126	119	149	149									
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	217	200	300									
28	Branhanganj 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	100	100									
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	74	100	100									
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	55	55									
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55									
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104									
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162									
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0									
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55									
36	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	51	51	51									
Dhaka Zone Total				5853	5696	1412	2397	2849	2925	1670	958							
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level & maint.					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage					
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0									
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17									
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0									
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	40	40	40	40									
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	18	38	105	105									
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.					
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			HQPI awaiting					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	245	286	283	283									
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100									
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	70	90	90	90									
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51									
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98			Environment issue					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20									
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	3	10	20									
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	52	96	90	90									
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	13	54	54									
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	110	110									
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	70	100	100									
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	100	116	116	116									
Chattogram Zone Total				2442	2382	628	911	1256	1242	544	473							
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage					
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage					
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	29	29	29	16			Gas Shortage					
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	224	154	225	225	67			Gas Shortage					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	365	265	300	360	95			Gas Shortage					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	265	300	360	95			Gas Shortage					
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	15	15	15	15	40			Gas Shortage					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	26	8	8	169			Gas Shortage					
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51									
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	137	150	150									
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50									
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	126	122	125	125									
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	44	200	200									
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21									
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5									
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	23	25	33	33									
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	34	52	52									
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	20	16	21									
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+40x1.915+15x1.958	200	200	0	0	100	200									
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	34	70	114	114									
76	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	55	116	113	113									
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17									
	Chandpur 115(Doreen)	HFO (IPP)				0	0	115	0				On Test					
**	Import (Tripura)	India		160	160	100	102	138	164									
Cumilla Zone Total				2944	2899	1379	1568	2177	2313	745	0							
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	146	149	170	175	53			Gas Shortage					
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22									
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. 8MW					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	75	110	110									
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	191	191	200	200									
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0									
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0									
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22									
Mymensingh Zone Total				717	622	508	457	576	529	53	0							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.02.22 (Yesterday)		13.02.22 (Today)		12.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30			GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	43	43	42	43			GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	48	50	51	51				
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	33	65	66				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	145	143	0	0	187		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	80	84				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	151	177	180	180	54		Gas Shortage	
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	330	330				
99	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	390	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1324	1399	1325	1331	323	87	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	15	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	60	80	100				
108	Rupsaha 105 MW PP (Orion rupsaha)	HFO (IPP)	6x18.445	105	105	94	105	93	93				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	25	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	738	734	752	752				
Khulna Zone Total					2233	2229	947	944	1025	1340	410	0	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	22	20	24				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	172	176	185	185	18		Gas Shortage	
114	Bhola 95 MW PP (Aggreko)	Gas (ORPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	260	420	620	620		824	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	104	100	110	112				
Barishal Zone Total					2046	2046	564	729	1056	1212	18	824	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	50	50				
122	Chapaiwawaganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	50	100	90	100				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40				
124	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	8	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	23	30	32				
126	Siraggonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Siraggonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	160	136	180	180	84		Gas Shortage	
128	Siraggonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
129	Siraggonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	385	240	350	400	174		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	95	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	90	113	113	113				
135	Siraggonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2129	2129	862	956	1294	1390	859	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	106	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	358	306	321	313	159	85	
Sub-total: Plants in operation					21471	20985	7982.0	9667	11879	12595	4781	2427	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					7626	9235	11348	12033					
(B) Plants under long term maintenance/contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	108irganj 100 PP(Dutch Bangla)	HFO (ORPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (ORPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (ORPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPLC-2)	HFO (ORPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Annura 50 MW PP(Sinha)	HFO (ORPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					595	50	0	0	0	0	0	0	
Gross Total					22066	21035	7982	9667	11879	12595	4781	2427	
(C) Actual data of 12.02.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 9667.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9235.40	MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9667.00	MW, at = 19:00 hrs	Dhaka	3313.2	3313.2	0	Mymensingh	843	843	0		
04.	Minimum Generation (Generation end)	: 5534.00	MW, at = 5:00 hrs	Chattoagram	980	980	0	Sylhet	355	355	0		
05.	Day-peak Generation (Generation end)	: 7982.00	MW, at = 12:00 hrs	Khulna	1135.2	1135.2	0	Barishal	220	220	0		
06.	Evening-peak Generation (Generation end)	: 9667.00	MW, at = 19:00 hrs	Rajshahi	994	994	0	Rangpur	689	689	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs	Cumilla	706	706	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6095.00	MW, at = 5:00 hrs					Total	9235	9235	0		
09.	Generation shortfall at evening peak due to:							(a) Gas = 102827674 Taka	(c) Coal = 63673647 Taka				
	a) Gas limitation	: 4438	MW					(b) Oil = 313011905 Taka	Total = 479513225 Taka				
	d) Coal supply Limitation	: 159	MW										
	b) Low water level in Kaptai lake	: 184	MW										
	c) Plants under shut down/ maintenance	: 2427	MW										
10.	Total Energy (Generation + India Import)	: 182.64	MKWh	14.	Maximum Temperature in Dhaka was : 24.6° C								
	By Gas = 101.273 MKWh		By Oil = 46.741 MKWh	15.	Export through East-West interconnections :								
	By Coal = 13.363 MKWh		By Hydro = 1.069 MKWh		At evening peak-hour	: -324	MW, at 19:00 hrs						
	By Solar= 1.195 MKWh				Maximum	: -324	MW, at 19:00 hrs						
11.	Total Gas Supplied	: 772.43	MMCFD		Energy	: 0.443	MKWh						
(D) Forecast of 13.02.22 (Today) Sunday :													
01.	Maximum Demand	: 10300	MW (Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	: 12595	MW (Generation end)	05.	Total Generation	: 194.60	MKWh						
03.	Maximum Shortage	: -2295	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	: 26.7° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation