

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month February, 2022											Day: Thursday		Date: 17.02.22			
Probable Maximum Demand: 10000 MW											Probable Maximum Generation: 12526 MW				Rule Curve = 94.76 ft.	
Water Level of Kaptai Lake at 06:00 AM											Yesterday = 92.20 ft.		Today = 92.09 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.02.22 (Yesterday)		17.02.22 (Today)		16.02.22 (Yesterday)	16.02.22 (Yesterday)	Status of Machines under shut-down/ Maintenance	Probable start-up date				
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening					Day	Evening		
Gen. shortfall for: Gas/water/Coal limitation (MW)											Machines shut down (MW)		Description/ Remarks			
<b>(A) Plants in operation:</b>																
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work				
2	a) Ghorasal TPP Unit-4	Gas (PDB)	1 x 210	210	180	40	0	0	0	240		Gas Shortage				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	240	320	320	320	45		Gas Shortage				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maintenance				
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling				
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	268	307	310	310							
11	Siddhirganj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage				
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage				
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	55	55	55	55							
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	24	28	52	52							
16	Gaganpur 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	92	93	90	93							
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	21	22	22							
18	Summit Power (Madhabd+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	52	55	56	56							
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	25	25							
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33							
21	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	13	51	51	51							
22	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105							
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150							
24	Kamalghat 54 MW PP (Banoo Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54							
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	273	277	300	300							
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149							
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	50	61	200	300							
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	50	100	100							
29	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	50	100	100							
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55							
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55							
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104							
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162							
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	35	0	30	0							
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55	55							
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0							
<b>Dhaka Zone Total</b>			<b>5853</b>	<b>5696</b>	<b>2334</b>	<b>2543</b>	<b>2858</b>	<b>2931</b>	<b>1590</b>	<b>958</b>						
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level & maint.				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage				
39	Kapali 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0							
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	17	25							
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0							
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	40	40	40							
43	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	44	70	105	105							
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.				
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	283	300	300	300							
47	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100							
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90							
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51							
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment Issue				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18							
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	15	5	15							
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	70	76	90	96							
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	54	54							
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	31	60	110	110							
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	50	80	100	100							
56	Chattogram 116 MW PP (Anlima Ene)	HFO (IPP)	6x21.06	116	116	96	116	116	116							
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>812</b>	<b>987</b>	<b>1267</b>	<b>1266</b>	<b>544</b>	<b>473</b>						
57	a) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage				
	b) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	30	30	16		Gas Shortage				
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	0	0	0	0	221		Gas Shortage				
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	315	330	330	45		Gas Shortage				
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	335	360	360	25		Gas Shortage				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	51	51	51							
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	73	102	130	130	93		Gas Shortage				
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51							
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	100	150	150	150							
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	43	50	50							
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	122	124	125	125							
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	21	34	200	200							
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	21	21							
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5							
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33							
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	47	52	52	52							
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	20	20							
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+66x1.55+15x1.058	200	200	0	0	100	200							
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	114	114	114							
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	55	118	113	113							
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17							
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			7	0	115	0			On Test				
**	Impoort (Tipura)	India		160	160	94	106	138	163							
<b>Cumilla Zone Total</b>			<b>2944</b>	<b>2899</b>	<b>1352</b>	<b>1716</b>	<b>2205</b>	<b>2215</b>	<b>663</b>	<b>0</b>						
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	93	100	110	110	102		Gas Shortage				
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22							
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	8	0	0	0	0			Dependable cap. : 9MW				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	56	108	110	110							
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200							
83	Saishahari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0							
84	Sulakhatil 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0							
85	Tangal 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	22	22	22	22							
<b>Mymensingh Zone Total</b>			<b>717</b>	<b>622</b>	<b>446</b>	<b>452</b>	<b>516</b>	<b>464</b>	<b>102</b>	<b>0</b>						

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.02.22 (Yesterday)		17.02.22 (Today)		16.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	43	43		48	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	48	51	51	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	52	68	70	70				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	160	160	160	170		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	176	177	177	177	54		Gas Shortage	
95	Sylhet 20 MW GTPP	Gas (PDB)	1x 20	20	20	0	0	0	0		20	Under HGPI	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
97	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x8.34	25	25	16	14	16	16	11		Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	330	330				
99	Bibyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
<b>Sylhet Zone Total</b>			<b>2422</b>	<b>2377</b>	<b>1436</b>	<b>1457</b>	<b>1494</b>	<b>1494</b>	<b>288</b>	<b>108</b>			
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			Gas Shortage	
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410			
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulina 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	11	0	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	94	105	105				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	723	722	738	738				
<b>Khulina Zone Total</b>			<b>2233</b>	<b>2229</b>	<b>918</b>	<b>849</b>	<b>1023</b>	<b>1338</b>	<b>410</b>	<b>0</b>			
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	21	20	20				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	180	183	185	185	11		Gas Shortage	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	270	410	620	620		834	Line Overload	
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	45	0	54	150				
117	Bhola 220MW CCPP (Nutan Bidyt BE)	Gas/HSD (IPP)	2x75+1x70	220	220	113	110	110	112				
<b>Barishal Zone Total</b>			<b>2046</b>	<b>2046</b>	<b>635</b>	<b>735</b>	<b>1110</b>	<b>1208</b>	<b>11</b>	<b>834</b>			
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	42	50	50				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.524	104	104	50	100	90	100				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	35	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	30	32				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	130	121	130	130	99		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	250	221	350	350	193		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	34	34	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	100	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	80	106	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
<b>Rajshahi Zone Total</b>			<b>2129</b>	<b>2129</b>	<b>736</b>	<b>907</b>	<b>1236</b>	<b>1297</b>	<b>893</b>	<b>0</b>			
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	99	105	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
	Energypac Power Venture Thakurgaon Ltd.	HFO (IPP)				18	0	0	0				
<b>Rangpur Zone Total</b>			<b>685</b>	<b>605</b>	<b>323</b>	<b>305</b>	<b>321</b>	<b>313</b>	<b>159</b>	<b>85</b>			
<b>Sub-total: Plants in operation</b>			<b>21471</b>	<b>20985</b>	<b>8992.0</b>	<b>9951</b>	<b>12030</b>	<b>12526</b>	<b>4660</b>	<b>2458</b>			
<b>Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss</b>			<b>8582</b>	<b>9498</b>	<b>11482</b>	<b>11955</b>							
<b>(B) Plants under long term maintenance/ contract expired</b>													
142	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Siddhanganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Mehenghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulina 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired			595	0	0	0	0	0	0				
<b>Gross Total</b>			<b>22066</b>	<b>20985</b>	<b>8992</b>	<b>9951</b>	<b>12030</b>	<b>12526</b>	<b>4660</b>	<b>2458</b>			
<b>(C) Actual data of 16.02.22 (Yesterday) Wednesday :</b>													
01.	Max. Demand at eve. peak (Generation end)					9951.00	MW, at =	19:00 hrs					
02.	Max. Demand at eve. peak (Sub-station end)					9497.73	MW, at =	19:00 hrs					
03.	Highest Generation (Generation end)					9951.00	MW, at =	19:00 hrs					
04.	Minimum Generation (Generation end)					6239.00	MW, at =	5:00 hrs					
05.	Day-peak Generation (Generation end)					8992.00	MW, at =	12:00 hrs					
06.	Evening-peak Generation (Generation end)					9951.00	MW, at =	19:00 hrs					
07.	Evening Peak Load-shed (Sub-station end)					0.00	MW, at =	19:00 hrs					
08.	Minimum Generation Forecast up to 8:00 hrs.					6343.00	MW, at =	5:00 hrs					
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation					4317	MW						
	d) Coal supply Limitation					159	MW						
	b) Low water level in Kaptai lake					184	MW						
	c) Plants under shut down/ maintenance					2458	MW						
10.	Total Energy (Generation + India Import)					201.79	MKWh						
	By Gas =					106.003	MKWh						
	By Coal =					13.598	MKWh						
	By Solar =					1.415	MKWh						
11.	Total Gas Supplied					765.80	MMCFD						
<b>(D) Forecast of 17.02.22 (Today) Thursday :</b>													
01.	Maximum Demand					10000	MW						
02.	Maximum Generation					12526	MW						
03.	Maximum Shortage					-2526	MW						
04.	Maximum Load-shed					0	MW					At evening peak (Sub-station end)	
05.	Total Generation					202.78	MKWh						
06.	Probable Max. Temperature in Dhaka					26.6°	C						

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation