

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2022										Day : Friday		Date : 18.02.22			
Probable Maximum Demand : 9000 MW										Yesterday = 92.09 ft		Today = 91.98 ft		Rule Curve = 94.62 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.02.22 (Yesterday)		18.02.22 (Today)		17.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)		Description/ Remarks	Probable start-up date		
(A) Plants in operation:															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work				
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240	Gas Shortage				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	320	320	320	320	45	Gas Shortage				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.				
6	Hairipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage				
7	Hairipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	172	0	0	188	Gas Shortage				
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling				
10	Hairipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	309	263	270	270						
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage				
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	45	60	60						
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	58	93	90	93						
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22						
18	Summit Power (Madhabd+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	56	55	56	56						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x7.7	33	33	28	28	25	25						
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x7.7	33	33	33	33	33	33						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.50	52	52	25	51	51	51						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105						
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	133	150	150						
24	Kamalghat 54 MW PP (Banso Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54						
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	281	265	300	300						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	123	138	149	149						
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	71	200	300						
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100						
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	100	100						
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55						
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	102	104	104						
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162						
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0						
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55						
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
Dhaka Zone Total			5853	5696	2247	2727	2826	2899	1778	598					
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	75	72	72	72	158	Low water level & maint.				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
39	Kapali 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0							
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	40	40	40						
43	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	85	70	105	105						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.				
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	288	300	300	300						
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51						
50	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment Issue				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	18	18						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	15	40	40						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	77	88	90	96						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	6	17	54	54						
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	42	34	110	110						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	40	100	100						
56	Chattogram 116 MW PP (Anlima Ene)	HFO (IPP)	6x21.06	116	116	96	115	116	116						
Chattogram Zone Total			2442	2382	919	985	1336	1317	518	473					
57	a) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage				
	b) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	27	22	22	18	Gas Shortage				
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	0	0	100	100	221	Gas Shortage				
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	290	305	330	340	55	Gas Shortage				
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	310	280	330	350	80	Gas Shortage				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	52	20	20						
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	40	92	45	45	103	Gas Shortage				
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	147	150	150	150						
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	50	50	50						
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	123	121	125	125						
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	42	42	200	200						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5						
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	51	52	52	52						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	18	20	20						
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x4+40x1.515+15x1.058	200	200	0	0	100	200						
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	88	114	114						
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	75	119	113	113						
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			0	0	115	0		On Test				
**	Impoort (Tijura)	India		160	160	94	106	138	163						
Cumilla Zone Total			2944	2899	1503	1621	2151	2191	740	0					
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	94	102	110	110	100	Gas Shortage				
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22						
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	8	0	0	0	0		Dependable cap. : 8MW				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	99	110	110						
82	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	174	192	200	200						
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
84	Sutahatli 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0						
85	Tangal 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	19	18	22	22						
Myensingh Zone Total			717	622	456	431	516	464	100	0					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.02.22 (Yesterday)		18.02.22 (Today)		17.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	43	43	48	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	48	51	51	51			
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	69	70	70			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	159	160	160	171	Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	84	84			
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	177	177	54	Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	0	0	0	0	20	Under HGPL	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjihanulla 25 MW PP	Gas (CIPP, REB)	3x8.34	25	25	16	16	16	16	9	Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	330	330			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	380	350	380			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		Under project work	
Sylhet Zone Total					2422	2377	1433	1429	1442	1472	287	108
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	8	38	0	35			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	5	0	40			
106	Khulina 225 MW CCPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	220			
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	45	80	100			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	105	105	105			
109	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	50	100			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	715	722	734	734			
Khulina Zone Total					2233	2229	905	915	1019	1334	410	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	21	20	20			
113	Bhola 225 MW CCPP	Gas (PDB)	2x83+1x68	194	194	183	183	90	90			
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	310	430	620	620	814	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	54	150			
117	Bhola 220MW CCPP (Nutan Bidyt BE)	Gas/HSD (IPP)	2x75+1x70	220	220	107	104	220	220			
Barishal Zone Total					2046	2046	626	749	1125	1221	0	814
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
118	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	43	43	34	34			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	30	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	48	50	50			
122	Chapainabganj 100 MW Peaking PP	HFO (PDB)	12x8.524	104	104	50	98	90	100			
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	0	32			
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	43	43			
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	30	32			
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	133	118	130	130	102	Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	255	215	290	280	199	Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	22	22			
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
132	Natore 52 MW PP (Rajankia)	HFO (IPP)	6x8.92	52	52	43	43	52	52			
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113			
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	94	113	113			
135	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total					2129	2129	738	929	1184	1212	902	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74	Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	113	113	113	113			
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode	
141	Majpara, Tabula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgaon Ltd.)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
Rangpur Zone Total					695	605	318	313	321	313	159	85
Sub-total: Plants in operation					21471	20985	9145.0	10099	11920	12423	4894	2078
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					8723	9633	11370	11850				
(B) Plants under long term maintenance/ contract expired												
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Forced Outage	
143	Siddhanganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
146	Mehnegahat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021	
147	Khulina 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					595	0	0	0	0	0	0	0
Gross Total					22066	20985	9145	10099	11920	12423	4894	2078
(C) Actual data of 17.02.22 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	: 10099.00 MW, at = 19:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 9633.47 MW, at = 19:00 hrs										
03.	Highest Generation (Generation end)	: 10099.00 MW, at = 19:00 hrs										
04.	Minimum Generation (Generation end)	: 6343.00 MW, at = 5:00 hrs	Dhaka	3504.27	3504.27	0	0	0	0	Mymensingh	894	894
05.	Day-peak Generation (Generation end)	: 9145.00 MW, at = 12:00 hrs	Chattogram	1034	1034	0	0	0	0	Sylhet	337	337
06.	Evening-peak Generation (Generation end)	: 10099.00 MW, at = 19:00 hrs	Khulina	1141	1141	0	0	0	0	Barishal	247	247
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Rajshahi	1033.2	1033.2	0	0	0	0	Rangpur	696	696
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6364.00 MW, at = 5:00 hrs	Cumilla	747	747	0	0	0	0			
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation	: 4577 MW										
d)	Coal supply Limitation	: 159 MW										
b)	Low water level in Kaptai lake	: 158 MW										
c)	Plants under shut down/ maintenance	: 2078 MW										
10.	Total Energy (Generation + India Import)	: 200.68 MKWh										
	By Gas =	102.700 MKWh										
	By Coal =	14.025 MKWh										
	By Solar =	1.379 MKWh										
11.	Total Gas Supplied	: 765.82 MMCFD										
13.	Fuel cost :											
(a)	Gas =	105512587 Taka										
(b)	Oil =	430155211 Taka										
(c)	Coal =	66591277 Taka										
Total =		602259075 Taka										
14.	Maximum Temperature in Dhaka was :	27.8° C										
15.	Export through East-West interconnections :											
At evening peak-hour		: -374 MW, at 19:00 hrs										
Maximum		: -390 MW, at 21:00 hrs										
Energy		: 1.751 MKWh										
04.	Maximum Load-shed	: 0 MW										
05.	Total Generation	: 178.84 MKWh										
06.	Probable Max. Temperature in Dhaka :	27.0° C										
* Captive Power ** Imported Power												

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation