

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2022												Day: Monday		Date: 21.02.22	
Probable Maximum Demand: 9200 MW				Probable Maximum Generation: 12555 MW				Rule Curve = 94.20 ft.							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.74 ft.		Today = 91.51 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.02.22 (Yesterday)		21.02.22 (Today)		20.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:						
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)		Description/ Remarks	Probable start-up date		
(A) Plants in operation:															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work				
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240	Gas Shortage				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	320	320	320	320	45	Gas Shortage				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	250	250	360	Gas Shortage				
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling				
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	273	246	0	0						
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage				
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55						
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	12	60	60						
16	Gangnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	93	93	90	93						
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22						
18	Summit Power (Madhabd+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	55	55	55	55						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	30	30						
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	17	33	33						
21	Gasipur 52 MW PP	HFO (RPCL)	6x8.50	52	52	36	18	51	51						
22	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105						
23	Kooda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	150	150						
24	Kamalghat 54 MW PP (Banso Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54						
25	Kooda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	280	281	300	300						
26	Kooda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149						
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200	300						
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	100	100						
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	35	35	35						
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104						
33	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	144	162	162	162						
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	21	0	30	0						
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55						
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
Dhaka Zone Total			5853	5696	2202	2253	2790	2863	1950	598					
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	64	60	60	60	170	Low water level & maint.				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
39	Kapali 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	40	40	40						
43	Sikalbaha 105 MW PP (Baraka Sikalbat)	HFO (IPP)	6x18.415	105	105	105	68	105	105						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.				
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300						
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	74	90	90	90						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment Issue				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	23	10	30						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	47	96	90	96						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54						
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	41	51	110	110						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	30	60	100	100						
56	Chattogram 116 MW PP (Anlima Ene)	HFO (IPP)	6x21.06	116	116	95	112	116	116						
Chattogram Zone Total			2442	2382	869	994	1294	1295	530	473					
57	a) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage				
	b) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	6	6	6	6	39	Gas Shortage				
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	177	188	200	225	33	Gas Shortage				
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	305	265	320	320	95	Gas Shortage				
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	260	260	350	360	100	Gas Shortage				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50	Gas Shortage				
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187	Gas Shortage				
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	145	150	150	150						
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	42	50	50						
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	124	123	125	125						
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	200	200						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	11						
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	33	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	48	52	52	52						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21						
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+66x1.515+15x1.058	200	200	0	0	100	200						
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	98	98	98						
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	108	113	113						
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			18	0	115	0		On Test				
**	Impoort (Tijura)	India		160	160	102	106	138	163						
Cumilla Zone Total			2944	2899	1423	1579	2180	2229	767	0					
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	104	102	130	140	100	Gas Shortage				
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	8	0	0	0	0		Dependable cap. : 8MW				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	84	115	110	115						
82	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	183	192	200	200						
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	1.6	0	0						
84	Sulakhatil 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0						
85	Tangal 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	22	22	22	22						
Myensingh Zone Total			717	622	447	453	536	499	100	0					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.02.22 (Yesterday)		21.02.22 (Today)		20.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40		GT-1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42	48		GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	48	48	51	51				
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	5	5				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	69	66	66				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	161	160	160	160	170		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	84	84				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	177	171	177	177	60		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Under HGPI	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x8.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	330	330				
99	Bibyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	381	390	300	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1405	1399	1381	1481	292	108	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	40	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	60	90	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	56	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	719	716	734	734				
Khulna Zone Total					2233	2229	835	886	1019	1339	410	0	
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	27	25	30				
113	Bhola 225 MW CAPP	Gas (PDB)	2x83+1x68	194	194	91	91	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	390	620	620	854		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150				
117	Bhola 220MW CAPP (Nutan Bidyt BE)	Gas/HSD (IPP)	2x75+1x70	220	220	226	220	220	220				
Barishal Zone Total					2046	2046	632	739	1127	1232	0	854	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	40	43				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	14	38	40	40				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	100	90	100				
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	37	0	37				
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	29	30	30				
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	145	131	130	150	89		Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	238	204	350	350	210		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	112	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total					2129	2129	836	933	1240	1304	900	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	106	106	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Maipara, Tabula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgan Ltd.	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	353	306	321	313	159	85	
Sub-total: Plants in operation					21471	20985	9002.0	9542	11888	12555	5108	2118	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					8496	9006	11220	11850					
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			Contract Expired on 07/05/2021	
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Mehenghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 31/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					595	0	0	0	0	0	0	0	
Gross Total					22066	20985	9002	9542	11888	12555	5108	2118	
(C) Actual data of 20.02.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 9542.00 MW, at = 19:30 hrs			Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9006.00 MW, at = 19:30 hrs			Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	: 9542.00 MW, at = 19:30 hrs				MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	: 6317.00 MW, at = 5:00 hrs			Dhaka	3095	3095	0	Mymensingh	801	801	0	
05.	Day-peak Generation (Generation end)	: 9002.00 MW, at = 12:00 hrs			Chattogram	1003	1003	0	Sylhet	337	337	0	
06.	Evening-peak Generation (Generation end)	: 9542.00 MW, at = 19:30 hrs			Khulna	1086	1086	0	Barishal	245	245	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs			Rajshahi	998	998	0	Rangpur	682	682	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6020.00 MW, at = 5:00 hrs			Cumilla	759	759	0					
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 4779 MW			13.	Fuel cost :	(a) Gas = 99914362 Taka		(c) Coal = 62513423 Taka		Taka		
	d) Coal supply Limitation	: 159 MW					(b) Oil = 415494288 Taka		Total = 577922073 Taka		Taka		
	b) Low water level in Kaptai lake	: 170 MW											
	c) Plants under shut down/ maintenance	: 2118 MW			14.	Maximum Temperature in Dhaka was : 27.6° C							
10.	Total Energy (Generation + India Import)	: 197.46 MKWh			15.	Export through East-West interconnections :							
	By Gas = 101.972 MKWh		By Oil = 60.818 MKWh		At evening peak-hour		: -340 MW, at 19:30 hrs						
	By Coal = 13.105 MKWh		By Hydro = 1.477 MKWh		Maximum		: -442 MW, at 8:00 hrs						
	By Solar = 0.886 MKWh				Energy		: 1.0915 MKWh						
11.	Total Gas Supplied	: 737.74 MMCFD											
(D) Forecast of 21.02.22 (Today) Monday :													
01.	Maximum Demand	: 9200 MW (Generation end)			04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 12555 MW (Generation end)			05.	Total Generation : 190.39 MKWh							
03.	Maximum Shortage	: -3355 MW (Generation end)			06.	Probable Max. Temperature in Dhaka : 29° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation