

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month February, 2022				Day : Thursday				Date : 24.02.22				
Probable Maximum Demand : 10500 MW				Probable Maximum Generation : 12650 MW				Rule Curve = 93.75 ft				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.12 ft		Today = 91.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.02.22 (Yesterday)		24.02.22 (Today)		23.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable shut-up date
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	340	340	340	340	25	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	343	337	350	350			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	6	30	30			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93			
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	19	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	55	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	30	30			
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
23	Kodda 150MW PP	HFO (BPD-RPCL)	9x17.06	149	149	150	150	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	278	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	298	200	300			
28	Branhangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	95	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
36	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
<b>Dhaka Zone Total</b>				<b>5853</b>	<b>5696</b>	<b>2403</b>	<b>2912</b>	<b>2903</b>	<b>2973</b>	<b>1982</b>	<b>598</b>	
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	68	72	72	162	Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0				
40	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	26	13	40	40			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	78	88	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	283	300	300	300			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	60	100	100			
48	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
*	Malancha, City EPZ (United)	Gas	5x8.73+3x9.34			4	14	15	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	78	85	90	96			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54			
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	50	51	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	100	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113			
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>835</b>	<b>1093</b>	<b>1308</b>	<b>1304</b>	<b>522</b>	<b>473</b>	
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	29	29	16	Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	194	124	221	221			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	310	320	320			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	295	315	340	350			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	15	5	5	40	Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	42	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	145	150	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	123	123	125	125			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	21	50	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	8	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	12	21	21			
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+60x1.95+15x1.95	200	200	0	0	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	109	34	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	15	8	8	8			
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			0	0	115	115			
**	Impport (Tripura)	India		160	160	112	120	138	163			
<b>Cumilla Zone Total</b>				<b>2944</b>	<b>2899</b>	<b>1514</b>	<b>1484</b>	<b>2127</b>	<b>2265</b>	<b>506</b>	<b>0</b>	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	113	121	160	155	81	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	113	90	110	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	181	191	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
<b>Mymensingh Zone Total</b>				<b>717</b>	<b>622</b>	<b>499</b>	<b>444</b>	<b>566</b>	<b>514</b>	<b>81</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.02.22 (Yesterday)		24.02.22 (Today)		23.02.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22-1x33	97	70	30	30	30	30		40	GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	45	45	45	45			Gas Shortage	
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53			
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	67	66	66				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	277	248	270	270	82		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	81	81	81				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage	
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	305	330	330				
99	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
<b>Sylhet Zone Total</b>					<b>2422</b>	<b>2377</b>	<b>1375</b>	<b>1359</b>	<b>1408</b>	<b>1408</b>	<b>375</b>	<b>108</b>	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	150	330	330	260		Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	70	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	94	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	720	719	722	722				
<b>Khulna Zone Total</b>					<b>2233</b>	<b>2229</b>	<b>904</b>	<b>1073</b>	<b>1337</b>	<b>1657</b>	<b>260</b>	<b>0</b>	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	23	25	30				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	90	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	82	82	81	81				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	440	620	620	804		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	(IPP)	2x75+1x70	220	220	111	110	110	110				
<b>Barishal Zone Total</b>					<b>2046</b>	<b>2046</b>	<b>624</b>	<b>745</b>	<b>1087</b>	<b>1192</b>	<b>0</b>	<b>804</b>	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	43	43				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	60	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	7	39	40	40				
122	Chapaiawabganj 100 MW Peaking PI	HFO (PDB)	12x8.524	104	104	50	98	100	100				
123	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	35	0	37				
124	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	30	30				
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	192	193	220	220	27		Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	112	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2129</b>	<b>2129</b>	<b>632</b>	<b>847</b>	<b>993</b>	<b>1024</b>	<b>1042</b>	<b>0</b>	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	99	105	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Talula 8 MW Solar (Sympa Power Energy)ac Power Venture Thakurganj Ltd.	Solar (IPP)	1 x 8	8	8	6	0	8	0				
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>304</b>	<b>305</b>	<b>321</b>	<b>313</b>	<b>159</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>21471</b>	<b>20985</b>	<b>9090.0</b>	<b>10262</b>	<b>12050</b>	<b>12650</b>	<b>4927</b>	<b>2068</b>	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8708	9831	11544	12119			
<b>(B) Plants under long term maintenance contract expired</b>													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	108irganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance contract expired					895	0	0	0	0				
<b>Gross Total</b>					<b>22066</b>	<b>20985</b>	<b>9090</b>	<b>10262</b>	<b>12050</b>	<b>12650</b>	<b>4927</b>	<b>2068</b>	
<b>(C) Actual data of 23.02.22 (Yesterday) Wednesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 10262.00 MW, at = 19:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 9831.00 MW, at = 19:00 hrs											
03.	Highest Generation (Generation end)	: 10262.00 MW, at = 19:00 hrs											
04.	Minimum Generation (Generation end)	: 6502.00 MW, at = 5:00 hrs											
05.	Day-peak Generation (Generation end)	: 9090.00 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 10262.00 MW, at = 19:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6544.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
	a) Gas Limitation	: 4606 MW											
	d) Coal supply Limitation	: 159 MW											
	b) Low water level in Kaptai lake	: 162 MW											
	c) Plants under shut down/ maintenance	: 2068 MW											
10.	Total Energy (Generation + India Import)	: 203.38 MKWh											
	By Gas = 105.368 MKWh	By Oil = 61.222 MKWh											
	By Coal = 14.258 MKWh	By Hydro = 1.650 MKWh											
	By Solar = 1.289 MKWh												
11.	Total Gas Supplied	: 793.86 MCFD											
						<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>							
						<b>Demand</b>	<b>Supply</b>	<b>Load Shed</b>	<b>Zone</b>	<b>Demand</b>	<b>Supply</b>	<b>Load Shed</b>	
						<b>MW</b>	<b>MW</b>	<b>MW</b>		<b>MW</b>	<b>MW</b>	<b>MW</b>	
						Dhaka	3566	3566	0	Mymensingh	910	910	
						Chattoagram	1076	1076	0	Sylhet	338	338	
						Khulna	1140	1140	0	Barishal	252	252	
						Rajshahi	1061	1061	0	Rangpur	678	678	
						Cumilla	810	810	0				
									<b>Total</b>	<b>9831</b>	<b>9831</b>	<b>0</b>	
						13.	Fuel cost :	(a) Gas = 102952342 Taka	(c) Coal = 68012221 Taka				
								(b) Oil = 434153248 Taka	Total = 605117811 Taka				
						14.	Maximum Temperature in Dhaka was :	28.7° C					
						15.	Export through East-West interconnections :						
							At evening peak-hour	: -350 MW, at					