

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month February, 2022				Day : Friday				Date : 25.02.22				
Probable Maximum Demand : 9300 MW				Probable Maximum Generation : 12248 MW				Rule Curve = 93.60 ft				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.00 ft				Today = 90.88 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.02.22 (Yesterday)		25.02.22 (Today)		24.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)		
					Day	Evening	Day	Evening			Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	340	340	340	340	25	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Hariপুর GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	347	331	350	350			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	11	11	30	30			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	55	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	30	30			
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	36	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	283	281	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	30	200	300			
28	Branhangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	28	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	53	55	55			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
Dhaka Zone Total				5853	5696	2330	2633	2903	2973	1982	598	
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	73	46	72	72	184	Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	26	0	40	40			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HQPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	20	100	100			
48	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	16	20	40			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	76	90	90	96			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54			
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	28	71	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	90	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113			
Chattogram Zone Total				2442	2382	856	1052	1313	1314	544	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	8	8	29	29	37	Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	223	187	221	221			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	275	320	320			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	260	340	350			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50	Gas Shortage	
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	145	150	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	50	50	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	123	121	125	125			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	83	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	8	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	20	25	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	46	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21			
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	96x1.4+60x1.95+15x1.958	200	200	0	19	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	89	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'13.1	113	113	0	8	8	8			
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			0	0	115	115		On Test	
**	Impport (Tripura)	India		160	160	106	116	138	163			
Cumilla Zone Total				2944	2899	1547	1569	2127	2265	537	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	104	103	130	150		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	21	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	110	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	182	190	200	200			
83	Sarisahani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0			
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	18	22	22	22			
Mymensingh Zone Total				717	622	462	451	536	509	99	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.02.22 (Yesterday)		25.02.22 (Today)		24.02.22 (Yesterday)		Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT 1 Under main.
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under main.
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	50	45	45			Gas Shortage
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	8	8			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	67	66	66			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	245	243	270	270	87		Gas Shortage
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	110	100	110	121		Gas Shortage
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
98	Bibianna-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	330	330			
99	Bibianna-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			
100	Bibianna South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	398	400	400	400			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work
Sylhet Zone Total					2422	2377	1343	1460	1508	270	108	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	310	245	330	330	165		Gas Shortage
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	33	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220			
107	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	20	80	100			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	105	105	105			
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	709	706	715	715			
Khulna Zone Total					2233	2229	1205	1109	1330	1650	165	0
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	21	25	30			
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	88	91	91			
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	30	11	81	81			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	380	0	0		864	Line Overload
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150			
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	127	221	220	220			
Barishal Zone Total					2046	2046	561	721	577	682	0	864
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	33	43	43	43			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	20	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	12	40	40	40			
122	Chapaiwawaganj 100 MW Peaking PI	HFO (PDB)	12x8.524	104	104	50	98	100	100			
123	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	35	0	37			
124	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	43	43			
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	30	30			
126	Siraggonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
127	Siraggonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	195	190	220	220	30		Gas Shortage
128	Siraggonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
129	Siraggonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414		Gas Shortage
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11			
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52			
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113			
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
135	Siraggonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
Rajshahi Zone Total					2129	2129	649	803	993	1024	1045	0
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	96	107	113	113			
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgon Ltd)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
Rangpur Zone Total					685	605	301	427	441	313	159	85
Sub-total: Plants in operation					21471	20985	9254.0	10225	11728	12248	4801	2128
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					8878	9810	11252	11751				
(B) Plants under long term maintenance contract expired												
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
143	108irganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
147	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
148	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance contract expired					595	0	0	0	0			
Gross Total					22066	20985	9254	10225	11728	12248	4801	2128
(C) Actual data of 24.02.22 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	: 10225.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9810.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 10225.00 MW, at = 19:00 hrs	Dhaka	3546	3546	0	Mymensingh	870	870	0		
04.	Minimum Generation (Generation end)	: 6544.00 MW, at = 5:00 hrs	Chattoagram	1104	1104	0	Sylhet	347	347	0		
05.	Day-peak Generation (Generation end)	: 9254.00 MW, at = 12:00 hrs	Khulna	1184	1184	0	Barishal	252	252	0		
06.	Evening-peak Generation (Generation end)	: 10225.00 MW, at = 19:00 hrs	Rajshahi	1019	1019	0	Rangpur	686	686	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	802	802	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6215.00 MW, at = 5:00 hrs					Total	9810	9810	0		
09.	Generation shortfall at evening peak due to :											
	a) Gas limitation	: 4458 MW	13.	Fuel cost :	(a) Gas = 101785185 Taka	(c) Coal = 65152421 Taka						
	d) Coal supply Limitation	: 159 MW			(b) Oil = 419604395 Taka	Total = 586542001 Taka						
	b) Low water level in Kaptai lake	: 184 MW										
	c) Plants under shut down/ maintenance	: 2128 MW	14.	Maximum Temperature in Dhaka was :	30.3° C							
10.	Total Energy (Generation + India Import)	: 202.82 MKWh	15.	Export through East-West interconnections :								
	By Gas = 105.477 MKWh	By Oil = 62.047 MKWh		At evening peak-hour	: -188 MW, at 19:00 hrs							
	By Coal = 13.612 MKWh	By Hydro = 1.411 MKWh		Maximum	: -400 MW, at 24:00							
	By Solar = 1.235 MKWh			Energy	: 1.0585 MKWh							
11.	Total Gas Supplied	: 788.84 MMCFD										
(D) Forecast of 25.02.22 (Today) Friday :												
01.	Maximum Demand	: 9300 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 12248 MW (Generation end)	05.	Total Generation	: 184.47 MKWh							
03.	Maximum Shortage	: -2948 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	30.5° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation