

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month March, 2022		Day : Monday				Date : 21.03.22					
Probable Maximum Demand :		13300 MW				Probable Maximum Generation : 14622 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 87.50 ft		Today = 87.50 ft		Rule Curve = 89.96 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.03.22 (Yesterday)		21.03.22 (Today)		20.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :		
								Gas/Water/Coal limitation MW	Machines shut down (MW)	Description/Remarks	Probable shut-up date
						Day	Evening	Day	Evening		
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
a)	Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	200	40	Gas Shortage
b)	Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	101	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	330	330	330	330	120	Dirty in gas
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	207	214	229	229	118	STG Under maint.
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	285	265	300	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93		
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22		
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	51	51	52	52		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	50	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150		
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	296	300	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	149	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	210	200	300		
28	Bramharangan 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100		
29	Aurath 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100		
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	90	92	92		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	126	148	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0		
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	45	55	55	55		
36	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
Dhaka Zone Total				5853	5696	2825	3254	3391	3475	580	1370
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	81	35	35	70	195	Low water level
a)	Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
b)	Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30	Gas Shortage
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
40	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	47	50	50	50		
43	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	138	130	150	150		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	281	281	300	300		
47	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	100	100	100	100		
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	76	90	90	90		
49	Dohazani-Kalaisah 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51		
50	Hafazzani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	9	0	0		
51	Baralkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
*	Melanchar, Ctg EPZ (United)	Gas (IPP)	5x8.73+3x8.34	55	55	5	15	10	25		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.07	108	108	4	6	6	6		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
56	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	94	113	113	113		
Chattogram Zone Total				2442	2382	1359	1424	1474	1499	405	150
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
b)	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	29	29		
59	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1x75	221	221	212	215	220	220		
60	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	320	305	330	330		
61	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	330	310	330	330		
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	51	52	55	55		
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	26	26	26	26		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	138	150	150		
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	18	32	50		
67	Chandipur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	89	90	90	130		
68	Chandipur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	81	200	200	200		
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	28	31	33	33		
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	40	43	52	52		
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	22	22	22		
74	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.51+15x1.258	200	200	0	150	100	200		
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	98	114	98	98		
76	Chowmuhani 113 MW	HFO (IPP)	12x9.79+2x3.1	113	113	97	97	113	113		
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	80	90	100	100		
**	Impoprt (Tripura)	India		160	160	128	162	138	163		
Cumilla Zone Total				3059	3014	1849	2187	2219	2402	263	0
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	136	121	70	100	81	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. 8MW
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	107	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	170	170	200	200		
84	Sarisabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0		
86	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22		
Mymensingh Zone Total				717	622	499	437	454	454	81	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.03.22 (Yesterday)		21.03.22 (Today)		20.03.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22-1x33	97	70	30	30	30	30		40	GT1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x25-1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			163	Under maintenance
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
91	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	55	60	60				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	115	265	265	265	65			Gas Shortage
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	86	86	86				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0			231	Under maint.
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0			20	Under HGPI
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	21	22	23				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	125	275	300	300				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	402	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	375	384	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work
Sylhet Zone Total					2422	2377	1310	1619	1664	1665	65	514	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	270	250	360	360	160			Gas shortage
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	40				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	120	226	158	225				
108	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	20	100	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	94	105	105				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	717	716	729	729				
Khulna Zone Total					2233	2229	1295	1502	1599	160	0		
112	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	0	0				
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	23	29	25	27				
114	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0				
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0				
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	650	660	660			594	Line Overload
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
118	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	104	105	110	110				
Barishal Zone Total					2046	2046	697	832	795	797	0	594	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	34	43	43				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	100	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	28	40	40				
123	Chapaiwawaganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	54	93	90	92				
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40				
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	25	30				
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	3	3	10	10	207			Gas Shortage
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	146	180	220	220				
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	131	158	210	220	62			Gas Shortage
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	43	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2129	2129	1101	1425	1512	1663	440	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	79	80	80	6			Coal shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74			Coal shortage
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				Condenser mode
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	96	111	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				Condenser mode
142	Majpara, Talula 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	6	0	8	0				
143	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	115	115	115	115				
Rangpur Zone Total					800	720	495	505	516	508	80	85	
Sub-total: Plants in operation					21701	21215	11430.0	13038	13549	14062	2074	2713	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10964	12507	12997	13489			
(B) Plants under long term maintenance/contract expired													
144	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage
145	Doddiganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
148	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
149	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired					595	0	0	0	0				
Gross Total					22296	21215	11430	13038	13549	14062	2074	2713	
(C) Actual data of 20.03.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 13038.00	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 12507.00	MW, at = 19:30 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 13038.00	MW, at = 19:30 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	: 9095.00	MW, at = 5:00 hrs		Dhaka	4618	4618	0	Mymensingh	934	934	0	
05.	Day-peak Generation (Generation end)	: 11430.00	MW, at = 12:00 hrs		Chattoagram	1299	1299	0	Sylhet	453	453	0	
06.	Evening-peak Generation (Generation end)	: 13038.00	MW, at = 19:30 hrs		Khulna	1467	1467	0	Barishal	317	317	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:30 hrs		Rajshahi	1402	1402	0	Rangpur	900	900	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9572.00	MW, at = 5:00 hrs		Cumilla	1117	1117	0					
09.	Generation shortfall at evening peak due to :								Total	12507	12507	0	
a)	Gas Limitation	: 1799	MW		13.	Fuel cost :	(a) Gas = 143121392	Taka	(c) Coal = 106420025	Taka			
d)	Coal supply Limitation	: 80	MW				(b) Oil = 619612314	Taka	Total = 869153731	Taka			
b)	Low water level in Kaptai lake	: 195	MW										
c)	Plants under shut down/ maintenance	: 2713	MW		14.	Maximum Temperature in Dhaka was :	35.6° C						
10.	Total Energy (Generation + India Import)	: 266.76	MKWh		15.	Export through East-West interconnections :							
	By Gas = 139.486	MKWh	By Oil = 81.872	MKWh		At evening peak-hour	: -162	MW, at 19:30 hrs					
	By Coal = 22.405	MKWh	By Hydro = 1.035	MKWh		Maximum	: -174	MW, at 7:00 hrs					
	By Solar= 1.482	MKWh				Energy	: 0.258	MKWh					
11.	Total Gas Supplied	: 1099.96	MMCFD										
(D) Forecast of 21.03.22 (Today) Monday :													
01.	Maximum Demand	: 13300	MW (Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	: 14062	MW (Generation end)	05.	Total Generation	: 272.12	MKWh						
03.	Reserve / Shortage	: 762	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	34.5° C							