

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month March, 2022		Day : Wednesday			Date : 23.03.22							
Probable Maximum Demand :		13500 MW			Probable Maximum Generation : 13755 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 87.28 ft			Today = 86.94 ft							
		Rule Curve = 89.64 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.03.22 (Yesterday)		23.03.22 (Today)		22.03.22 (Yesterday) Gen. shortfall for :	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
a)	Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	200	40	Gas Shortage	
b)	Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 36S MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	250	250	250			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	95	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Hariapur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariapur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	240	240	240	210	Dirty in gas	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		Under Overhauling	
10	Hariapur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	217	213	220	220	118	STG Under maint.	
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	150	150	150			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	43	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93			
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	54	55	52	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x3.73	33	33	33	33	33	33			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x3.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	70	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	296	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	116	133	133			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	129	306	200	300			
28	Bramarganjan 100 MW PP (Aggrak)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100			
29	Aurahi 100MW PP (Aggrak)	HSD (IPP)	23x0.85+91x.959	100	100	97	99	100	100			
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	91	90	91			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	144	144			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	25	55	55	55			
36	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
Dhaka Zone Total				5853	5696	2936	3058	3070	3144	670	1370	
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	71	70	70	70	160	Low water level	
a)	Chattoogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
b)	Chattoogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	12	25	25	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	48	45	50	50			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	131	131	130	130			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	281	290	300	300			
47	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100			
48	Juldah 100 MW Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
49	Dohazari -Kalaisah 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Haftazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	24	0	24			
51	Barakbunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malanchara, Ctg EPZ (United)	Gas (IPP)	5x8.73+3x8.34			5	26	10	25			
52	Chattoogram 108 MW PP (ECPV)	HFO (IPP)	16x7.07	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54			
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	77	100	100	100			
56	Chattoogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113			
Chattoogram Zone Total				2442	2382	1328	1484	1483	1497	370	150	
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
b)	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	29	29	29			
59	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1175	221	221	152	217	220	220			
60	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	290	260	300	300			
61	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	290	270	300	300			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	30	55	55			
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	147	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	41	32	50			
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	136	137	130	137			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	129	200	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	41	43	43	43			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	22	22			
74	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	96'1.4+8'15'+15'1.08	200	200	20	200	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+11'9.78	114	114	80	99	98	99			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.79+2'3.1	113	113	99	105	113	113			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	20	35	35	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	97	100	100			
**	Impport (Tripura)	India		160	160	142	160	138	163			
Cumilla Zone Total				3059	3014	1883	2213	2190	2341	450	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	68	81	80	100	121	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. 8MW	
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	108	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	173	180	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0			
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	20	22	22			
Mymensingh Zone Total				717	622	428	406	486	454	121	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.03.22 (Yesterday)		23.03.22 (Today)		22.03.22 (Yesterday)		Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT1 Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30		60	GT-4 Under maint.
89	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maintenance
91	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	60	60	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	264	279	265	280	51		Gas Shortage
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	89	86	86			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	14	16	22	24			
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	300			
100	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	404	400	400			
101	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	396	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
Sylhet Zone Total					2422	2377	1647	1659	1664	1681	51	514
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	220	235	300	300	175		Gas shortage
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	0	40			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30			
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	120	155	158	225			
108	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	3	100	100	100			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	93	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	712	715	729	729			
Khulna Zone Total					2233	2229	1253	1345	1442	1529	175	0
112	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	80			
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	30	25	30			
114	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	0	65	65	65			
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0			
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	650	660	660		594	Line Overload
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			
118	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	190	220	180	220			
Barishal Zone Total					2046	2046	731	965	930	1055	0	594
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	34	34	34			
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	177	100	200			
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	6	36	40	40			
123	Chapaiawalganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	54	90	90	90			
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	0	40			
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	42	43			
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	25	31			
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	143	135	170	180	85		Gas Shortage
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	162	162	170	180	58		Gas Shortage
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	393	414	414	414			
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	22	22			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	95	95			
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	93	113	113	113			
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
Rajshahi Zone Total					2129	2129	1088	1443	1384	1545	524	0
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	81	80	81			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	17	0	0			Condenser mode
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	96	110	113	113			
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
142	Majpara, Talula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
143	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	100	115	115	115			
Rangpur Zone Total					800	720	479	523	516	509	74	85
Sub-total: Plants in operation					21701	21215	11773.0	13096	13165	13755	2435	2713
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11306	12576	12642	13209		
(B) Plants under long term maintenance contract expired												
144	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
145	Dindiganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
148	Meghnath 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
149	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired					895	0	0	0	0	0		
Gross Total					22296	21215	11773	13096	13165	13755	2435	2713
(C) Actual data of 22.03.22 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)			13096.00 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)			12576.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)			13096.00 MW, at = 21:00 hrs	Dhaka	4617	4617	0	Mymensingh	940	940	0
04.	Minimum Generation (Generation end)			9683.00 MW, at = 5:00 hrs	Chattoagram	1390	1390	0	Sylhet	452	452	0
05.	Day-peak Generation (Generation end)			11773.00 MW, at = 12:00 hrs	Khulna	1470	1470	0	Barishal	336	336	0
06.	Evening-peak Generation (Generation end)			13096.00 MW, at = 21:00 hrs	Rajshahi	1426	1426	0	Rangpur	845	845	0
07.	Evening Peak Load-shed (Sub-station end)			0.00 MW, at = 21:00 hrs	Cumilla	1100	1100	0				
08.	Minimum Generation Forecast up to 8:00 hrs.			10247.00 MW, at = 5:00 hrs	Total				Total	12576	12576	0
09.	Generation shortfall at evening peak due to :				13.	Fuel cost : (a) Gas = 135080801 Taka (c) Coal = 101238112 Taka (b) Oil = 943548821 Taka Total = 1179867734 Taka						
a)	Gas limitation			2201 MW	14.	Maximum Temperature in Dhaka was : 35.1° C						
d)	Coal supply Limitation			74 MW	15.	Export through East-West interconnections :						
b)	Low water level in Kaptai lake			160 MW	At evening peak-hour					-12 MW, at 21:00 hrs		
c)	Plants under shut down/ maintenance			2713 MW	Maximum					-20 MW, at 22:00 hrs		
10.	Total Energy (Generation + India Import)			286.38 MKWh	Energy					0.052 MKWh		
	By Gas = 134.609 MKWh			By Oil = 106.920 MKWh								
	By Coal = 21.221 MKWh			By Hydro = 1.755 MKWh								
	By Solar= 1.310 MKWh											
11.	Total Gas Supplied			1072.12 MMCFD								
(D) Forecast of 23.03.22 (Today) Wednesday :												
01.	Maximum Demand			13500 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation			13755 MW (Generation end)	05.	Total Generation : 295.22 MKWh						
03.	Reserve / Shortage			255 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 36.9° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation