

Bangladesh Power Development Board

DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2022										Day : Friday		Date : 25.03.22			
Probable Maximum Demand :										12600 MW		Probable Maximum Generation : 13846 MW			
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 86.73 ft		Today = 86.49 ft		Rule Curve = 89.16 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.22 (Yesterday)		25.03.22 (Today)		24.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date			
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation (MW)	Machines shut down (MW)	Day	Evening			Day	Evening	
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	200	40		Gas Shortage			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	180	180						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	100	100	100						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Hariapur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage			
7	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maint.			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170		Dirty in gas			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Hariapur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	215	220	220		118	STG Under maint.			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	150	150	150	185		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Karaniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0						
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93						
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22						
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+0x7.3	80	80	45	45	52	55						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33						
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	33	33						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	51	51						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105						
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.08	149	149	150	150	150	150						
24	Kanshalga 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54						
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	151	300	300						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149						
27	Karanganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	244	301	200	300						
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100						
29	Arahal 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	95	99	100	100						
30	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	35	55	55						
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	91	90	91						
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	144	162						
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0						
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	24	55	55	55						
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
37	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0						
38	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0						
39	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	30	100	100						
Dhaka Zone Total				6155	5696	2747	3077	3156	3248	815	1370				
40	Kamaghulji Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160		Low water level			
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30		Gas Shortage			
42	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0						
43	Ricoan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25						
44	Teknaf 20MW PP (Sartech)	Solar (IPP)	1x20	20	20	18	0	20	0						
45	Patenga 50MW PP (Saraka)	HFO (IPP)	8x6.89	50	50	44	0	25	25						
46	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105						
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.			
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	130	131	130	130						
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	280	281	300	300						
50	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	50	100	100	100						
51	Juldah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90						
52	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51						
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	0	0						
54	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0						
*	Malanha, City EPZ (United)	Gas	5x8.73+3x9.34			3	12	15	30						
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	100	100						
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	55	54	54	54						
57	Kamaghulji Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	93	92	110	110						
58	Juldah unit 2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100						
59	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	113	113	113	113						
Chattogram Zone Total				2442	2382	1331	1414	1563	1553	370	150				
60	a) Ashuganj TPP Unit-4	Gas (AFSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage			
	b) Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage			
61	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	29	29	29	29						
62	Ashuganj 225 MW CCPP	Gas (AFSCL)	1x142+1*75	221	221	185	197	220	220						
63	Ashuganj 450 MW CCPP(South)	Gas (AFSCL)	1x360	360	360	310	320	320	340						
64	Ashuganj 450 MW CCPP(North)	Gas (AFSCL)	1x361	360	360	310	330	320	340						
65	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	54	55	55						
66	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	45	26	26	45	169		Gas Shortage			
67	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
68	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	150	150	150						
69	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	41	32	50						
70	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	137	137	137						
71	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200						
72	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19						
73	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	8	11	11						
74	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25						
75	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	35	43	43	43						
76	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	14	22	22						
77	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	89x1.4+80x1.95+15x1.95	200	200	80	200	100	200						
78	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	99	99	99	99						
79	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	105	115	113	113						
80	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35						
81	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	98	100	100						
**	Impoort (Tripura)	India		160	160	88	106	138	163						
Cumilla Zone Total				3059	3014	2086	2297	2245	2447	432	0				
82	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	98	100	100	104		Gas Shortage			
83	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	17	17						
84	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW			
85	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	97	98	98						
86	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	191	200	200	200						
87	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
88	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.22 (Yesterday)		25.03.22 (Today)		24.03.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
90	Fenchugoni CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30			GT1 Under maint.	
91	Fenchugoni CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30			GT4 Under maint.	
92	Fenchugoni 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	44	50	50				
93	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	0	0	40	163				
94	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
95	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	57	60	60				
96	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	110	270	220	270	60		Gas Shortage	
97	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	87	86	86				
98	Sylhet 225 MW CAPP	Gas (PDB)	1x142-1x89	231	231	0	0	0	0			231 Under maint.	
99	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			20 Under HGPI	
100	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
101	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	15	22	24				
102	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	300	300				
103	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	413	417	400	400				
104	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	385	398	0	0				
105	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
	Sylhet 50MW PP (EPL)	Gas (RPP)	2x27			0	0	0	0				
	Fenchugani 44MW (Energyprima)	Gas (RPP)	12x3.3+5*2			0	3	0	0				
Sylhet Zone Total					2422	2377	1494	1662	1259	1434	60	451	
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	210	220	225	225	190		Gas shortage	
108	Fairdipanj 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	35	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	30				
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	210	215	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	96	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	50	0				
115	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	15	0	0				
	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5*8.5			0	17	0	0				
**	Bheramara (HVDC)	India		1000	1000	712	712	725	725				
Khulna Zone Total					2348	2229	1336	1425	1430	1450	190	0	
116	Bansail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	80				
117	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	30	25	30				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	40	61	65	65				
119	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	270	460	660	660			784 Line overload	
121	Potashali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	201	220	180	220				
Barishal Zone Total					2046	2046	530	803	930	1055	0	784	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71 Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	43	34	34	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	40	172	100	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	7	29	40	40				
127	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	45	87	90	90				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	43	42	43				
130	Santabar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	25	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	128	213	220	220				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	127	210	220	220				
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	123	148	148	148	72		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	330	360	350	350				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	22	22				
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	43	52	52				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.56	113	113	95	95	95	95				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.56	113	113	113	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2129	2129	1204	1644	1568	1713	243	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	81	80	81				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85 Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	14	0	0			Condenser mode	
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	104	109	113	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	0			Condenser mode	
146	Majpara, Tatala 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 119MW PP (Energytac)	HFO (IPP)	6*20	115	115	97	115	115	115				
Rangpur Zone Total					800	720	484	527	516	509	74	85	
Sub-total: Plants in operation					22118	21215	11630	13284	13156	13846	2288	2840	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11274	12877	12753	13422			
(B) Plants under long term maintenance/contract expired													
148	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					178	0	0	0	0				
Gross Total					22296	21215	11630	13284	13156	13846	2288	2840	

(C) Actual data of 24.03.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 13284.00 MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12877.42 MW, at = 19:30 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 13284.00 MW, at = 19:30 hrs		4847	4847	0	Mymensingh	973	973	0			
04.	Minimum Generation (Generation end)	: 10558.00 MW, at = 8:00 hrs		1276	1276	0	Sylhet	449	449	0			
05.	Day-peak Generation (Generation end)	: 11630.00 MW, at = 12:00 hrs		1565	1565	0	Barishal	344	344	0			
06.	Evening-peak Generation (Generation end)	: 13284.00 MW, at = 19:30 hrs		1426	1426	0	Rangpur	843	843	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs		Cumilla	1154	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9849.00 MW, at = 5:00 hrs					Total	12877	12877	0			
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2054 MW		Fuel cost :	(a) Gas = 138634560 Taka	(c) Coal = 83525805 Taka							
d)	Coal supply Limitation	: 74 MW		(b) Oil = 912218463 Taka	Total = 1134378828 Taka								
b)	Low water level in Kapali lake	: 160 MW											
c)	Plants under shut down/ maintenance	: 2840 MW		14.	Maximum Temperature in Dhaka was :	33.7° C							
10.	Total Energy (Generation + India Import)	: 286.01 MCKWh		15.	Export through East-West interconnections :								
	By Gas = 137.303 MCKWh	By Oil = 108.803 MCKWh			At evening peak-hour	: 50 MW, at 19:30 hrs							
	By Coal = 17.181 MCKWh	By Hydro = 1.661 MCKWh			Maximum	: -338 MW, at 7:00 hrs							
	By Solar= 1.257 MCKWh				Energy	: 0.234 MCKWh							
11.	Total Gas Supplied	: 1070.85 MMCFD											

(D) Forecast of 25.03.22 (Today) Friday :												
01.	Maximum Demand	: 12860 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 13846 MW (Generation end)	05.	Total Generation	: 269.55 MCKWh							
03.	Reserve / Shortage	: 1246 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	37.3° C							

*Capable Power: ** Imported Power
 #Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00
 (Md. Helalur Rahman)
 Deputy Secretary, Generation