

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-Apr-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity MW	Present	Peak	Energy	Remarks
				Capacity MW	Hour Generation	Generated KWH	
<b>Unit No. X Capacity</b>							
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1120	180	100	3172000	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	PDB	1210	190	0	0	Gas shortage
4	Ghorasal 78.5 MW PP(MAX)	ORPP	1243+1122	365	220	5214127	Gas shortage
5	Ghorasal 108MW PP (Regent)	IPP	2*40	0	0	0	Contract Expired
6	Haripur GTPP	SBU, PDB	34*3.35	108	62	1607909	Engine problem
7	Haripur 412 MW CCGP	EGCB	2*32	20	0	0	Under maint.
8	Haripur 360MW CCGP(HPL)	IPP	1*273+1138	412	0	0	Under maint.
9	Meghnaghat 450 MW CCGP(MPL)	IPP	1*235+1125	360	89	2578000	Gas shortage
10	Meghnaghat 100 MW(LEL)	ORPP	2*150+1150	450	0	0	Under maint.
11	Meghnaghat CCGP(Summit)	IPP	12*8.9	0	100	2016000	
12	Madanganj 102 PP(Summit)	IPP	2*110+1110	335	110	2515113	GT-2 Under maint.
13	Madanganj-55 MW PP(Summit)	ORPP	6*17	0	80	1535088	Engine problem
14	Karaganj 100 MW PP (Powerpac)	IPP	3*17.08+111.3	55	55	1261198	Gas shortage
15	Narsingdi 22 MW PP (Doreen)	SI PP, REB	8*13.5	100	0	0	Contract Expired
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	98	2070720	
19	Siddhirgonj 335 MW CCGP	IPP	1*217+118	335	0	1511728	ST under maint.
20	Saagaraj 102 MW PP (Digital Po	IPP	12*8.924	102	93	2127744	Engine problem
21	Kaptoli 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	922680	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	3515040	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	995014	Engine problem
25	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	35	781746	Engine problem
26	Basila 108MW PP(CLC)	IPP	12*9.75+113.5	0	0	0	
27	Summit Power (Madhabdidi Ashuli)	SI PP, REB	3*3.67+4*8.73	80	48	1115160	Engine problem
28	Maona 33 MW PP(Summit)	SI PP, REB	4*8.73	33	23	636500	Engine problem
29	Rupganj 33 MW PP(Summit)	SI PP, REB	4*8.73	33	21	451300	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	49	1183200	#REF!
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.06	300	300	7205100	
33	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	303	4148355	
34	Bramhangonj 100 MW PP (Aggr	IPP	114*0.959	100	100	1213168	
35	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	1363007	
36	Kodda 149 MW PP Unit-1 (Summ	IPP	8*18.45+8.97	149	149	3648960	
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2293200	
38	Meghnaghat 104 MW PP (GPCL)	IPP	18*5.6	104	104	2570980	
39	Manikganj 162MW (MFGCL)	IPP	9*18	162	144	1972800	Engine problem
40	Spectra Solar Plant Ltd.	IPP	35	35	0	173617	
<b>Dhaka area Total</b>							
41	Kanchan Purbachal Power Gener	IPP	18.4*3	55	0	0	Engine problem
				<b>5696</b>	<b>2749</b>	<b>60293806</b>	
42	Chattogram TPP-1	PDB	1*210	180	0	0	Under maint.
43	Chattogram TPP-2	PDB	1*210	180	150	3700000	
44	Razzan 25 MW PP	IPP	3*8.9	25	25	491929	
45	Teknaf 20MW PP (Solartech/Teknaf Solartech Energ	IPP	2*0	20	0	98765	
46	Patenga 50MW PP (Baraka)	IPP	6*8.98	50	30	733520	Engine problem
47	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1580509	Low water level
48	Sikalbaha 225MW	PDB	1*150+1*175	225	217	4754789	
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka S	IPP	6*17.5	105	105	2501552	
51	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	24	337776	Engine problem
52	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	375309	Fuel shortage
53	Jaldah 100 MW Unit-1 (Acorn)	ORPP	8*13.5	100	0	0	Contract Expired
54	Jaldah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	90	284160	Engine problem
55	Barabkunda 22 MW PP (Regent)	SI PP, PDB	8*2.90	22	0	0	Engine problem
**	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	36	513120	
56	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	96	2262720	Engine problem
57	Kaptai 7 MW Solar PP	PDB	7*4	7	0	0	
58	Anwara 300 MW PP (United)	IPP	17*17.24	300	217	6681709	Engine problem
59	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1343238	
60	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2662133	
61	Jaldah unit-2 (Acorn)	IPP	8*13.6	100	100	2349120	
62	Anima Energy Ltd.	IPP	6*21.2	116	113	2677200	
				<b>2382</b>	<b>1488</b>	<b>33488949</b>	
<b>Chattogram area Total</b>							
63	Ashuganj TPP Unit-3	APSCCL	1*150	129	0	0	Contract Expired
64	Ashuganj TPP Unit-4	APSCCL	1*150	129	0	0	Gas shortage
65	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
66	Ashuganj 225 MW CCGP	APSCCL	1*142+1*75	221	192	4080000	#REF!
67	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	280	7483000	FGMO
68	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	265	6599000	FGMO
69	Ashuganj 50 MW PP	APSCCL	14*3.988	45	28	538392	Gas shortage
70	Ashuganj 55 MW PP (Precision)	RPP	5*15.4	55	5	480960	Gas shortage
71	Ashuganj 195MW PP (APSCCL-UR)	IPP	20*9.73+1*16	195	8	234181	Gas shortage
72	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1177268	
73	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	140	3076145	Engine problem
74	Titas 50 MW Peaking PP	PDB	6*8.92	52	39	509496	Engine problem
75	Chandpur 150 MW CCGP	IPP	1*108+1*157	163	51	1078930	Machine problem
76	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	200	4308960	
77	Feni 22MW PP (Doreen)	SI PP, PDB	8*2.90	22	22	489232	
78	Feni 11 MW PP (Doreen)	SI PP, REB	4*2.90	11	11	244900	
**	Import (Tripura)	Imported power	0	160	158	3614400	
79	Jangalia 33MW PP (Summit)	SI PP, PDB	4*8.73	33	23	544400	Engine problem
80	Jangalia 52 MW PP (Kadawan)	IPP	6*8.92	52	41	936778	Engine problem
81	Cumilla 25 MW PP (Summit)	SI PP, PDB	3*3.67+2*9.27	25	20	469810	Engine problem
82	Daudkandi 200 MW PP (B.Trac	IPP	154*1.4	200	200	2107776	
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	98	1855920	Engine problem
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	114	2607360	
85	Bhairab 54.5 MW	IPP	3*18.2	54	35	887040	33 kV feeder O/L
86	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	101	2404800	Engine problem
				<b>3014</b>	<b>2080</b>	<b>4578548</b>	
<b>Cumilla Area Total</b>							
87	RPCL 210MW CCGP	IPP	4*35+1*70	202	6	401760	Gas shortage
88	Tangail 22 MW PP (Doreen)	SI PP, PDB	8*2.90	22	20	401760	
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8900	
91	Mymensingh 200 MW PP (Unite	IPP	9*78.21	200	182	3600000	Engine problem
92	Jamalpur 115 MW PP (Unite)	IPP	9*78.12	115	105	1675200	Engine problem
93	Saitakhali 50 MW Solar PP	IPP	5*0	50	0	234000	
94	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	590160	
				<b>622</b>	<b>337</b>	<b>7188930</b>	
<b>Mymensingh Area Total</b>							
95	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	70	20	489000	Machine problem
96	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	21	663504	Machine problem
97	Kushaura 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3821973	
98	Shahbazar 330 MW PP	PDB	3*110	330	159	3773000	Machine problem
99	Fenchuganj 51 MW PP (Barakati	RPP	19*2.90	51	0	318000	Line O/L
100	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	3	52200	Gas shortage
101	Hobiganj 11MW PP Confidence-E	SI PP, REB	4*2.90	11	11	248976	
102	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	55	1324992	Machine problem
103	Shahbazar 86MW PP (Shahbaz	RPP	32*2.90	86	88	2096640	
104	Shahbazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
105	Sylhet 225 MW CCGP (Barakati)	PDB	1*142+1*89	231	218	529580	
106	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
107	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	380	Gas shortage
108	Shahjanulla 25 MW PP	SI PP, REB	3*9.34	25	23	544872	
109	Bibiana-II 341 MW CCGP (Summ	IPP	1*222+1*119	341	310	7229500	FGMO
110	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	403	9526000	
111	Sylhet 10MW PP (Dash)	RPP	6*1.85	10	10	244900	
112	Bibiyana South 400 MW	PDB	400 MW	383	395	783200	
				<b>2377</b>	<b>1879</b>	<b>43145377</b>	
<b>Sylhet Area Total</b>							
**	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	913	22058181	
113	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	96	1961280	Engine problem
114	Fanchpur 50 MW Peaking PP	PDB	6*8.99	54	34	281760	Engine problem
115	Khulna 225 MW Peaking PP	NWPQCL	1*150+1*75	220	200	4209600	Engine problem
116	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	0	5504	Line O/L
117	Bheramara 410 MW CCGP	NWPQCL	1*278+1*132	410	155	4276224	Gas shortage
118	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	40	802125	
119	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	98	676480	
120	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	94	2059680	Engine problem
121	Madhumati 100 MW PP	NWPQCL	6*18	105	15	149472	Line O/L
122	Mongla Orion 100 MW Solar PP	IPP	100	100	0	536400	
				<b>2229</b>	<b>1645</b>	<b>37208066</b>	
<b>Khulna Area Total</b>							
123	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	32	425856	Line O/L
124	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	38	765488	
125	Bhola 225 MW CCGP	PDB	2*63+1*68	194	65	1810000	Gas shortage
126	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	0	0	Contract Expired
127	Payra 1320 MW PP (Barakati)	BPCL	2*1222	1244	622	1354300	
128	Bhola Nujan Bidit BD LTD	IPP	2*20	220	222	5065855	
129	United Payra Power Ltd.	IPP	8*18.5+1*9				