

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 4-Apr-22

Page 2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|-------------------------------|------------------------------------|------------------|--------------------|------------------|----------------------|------------------|------------------|
| | | | | | | | |
| 1 | Ghorasal Repowered CCPP Unit-1 | PDB | 1*260 | 260 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCPP Unit-2 | PDB | 1*210 | 180 | 100 | 2338000 | Gas shortage |
| 3 | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 0 | 0 | Gas shortage |
| 3 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 70 | 4898573 | Gas shortage |
| 4 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 0 | 0 | 0 | Contract Expired |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 343.35 | 108 | 63 | 1355954 | Gas shortage |
| 5 | Haripur GTPP | SBU_PDB | 2*32 | 20 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CCPP | EGCB | 1*273+1*139 | 412 | 0 | 0 | Under maint. |
| 7 | Haripur 360MW CCPP(HPL) | IPP | 1*235+1*125 | 360 | 98 | 2160000 | Gas shortage |
| 8 | Meghnaghat 450 MW CCPP(MP) | IPP | 2*150+1*150 | 450 | 0 | 0 | Under maint. |
| 9 | Meghnaghat 100 MW(EL) | QRPP | 12*8.9 | 9 | 94 | 2053440 | |
| 10 | Meghnaghat CCPS(Summit) | IPP | 2*110+1*110 | 335 | 0 | 1680756 | Gas shortage |
| 11 | Madanganj 102 PP(Summit) | QRPP | 6*17 | 0 | 65 | 1433496 | Engine problem |
| 12 | Madanganj-55 MW PP(Summit) | (IPP) | 3*17.08+1*11.3 | 55 | 55 | 1341561 | |
| 13 | Keraniganj 100 MW PP (Powerpa) | QRPP | 8*13.45 | 100 | 0 | 0 | Contract Expired |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP_REB | 8*2.90 | 22 | 19 | 268884 | |
| 15 | 210 MW Siddhirganj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 16 | Siddhirganj 2*120 MW GTTP | EGCB | 2*105 | 210 | 0 | 0 | Gas shortage |
| 17 | Siddhirganj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 0 | 98 | 2048640 | |
| 18 | Siddhirganj 335 MW CCPP | EGCB | 1*217+1*118 | 335 | 0 | 0 | Gas shortage |
| 19 | Gagnagar 102 MW PP (Digital P) | IPP | 12*8.924 | 102 | 93 | 2192400 | Engine problem |
| 20 | Katpott 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 0 | 0 | Fuel shortage |
| 21 | Kamatnagar 54 MW PP(Banco E) | IPP | 3*18 | 54 | 54 | 702000 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 150 | 3521760 | |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 779107 | |
| 24 | Nababganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 35 | 672740 | Engine problem |
| 25 | Bosila 108MW PP(ELC) | IPP | 12*8.75+1*3.5 | 0 | 0 | 0 | |
| 26 | Summit Power Plant(Summit) | SIPP_REB | 3*9.67+1*8.73 | 80 | 45 | 1071240 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | IPP | 4*8.73 | 33 | 16 | 529900 | Engine problem |
| 27 | Ruganjan 33 MW PP(Summit) | SIPP_REB | 4*8.73 | 33 | 16 | 429300 | Engine problem |
| 29 | Gazipur 52 MW PP | RPCL | 6*8.9 | 52 | 41 | 1118880 | #REF! |
| 30 | Tongi 80 MW GTTP | PDB | 1*105 | 105 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 298 | 5811052 | |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 25*11.4 | 300 | 303 | 3582741 | |
| 33 | Bramhangonj 100 MW PP (Agg) | IPP | 114*0.959 | 100 | 97 | 1441406 | |
| 34 | Aurahat 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 100 | 1354731 | |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 8*18.45+8.97 | 149 | 149 | 3615696 | |
| 36 | Gazipur 100 MW PP | RPCL | 6*17.5 | 105 | 105 | 2493600 | |
| 37 | Meghnaghat 104 MW PP (OPCL) | IPP | 18*5.76 | 104 | 91 | 2157120 | Engine problem |
| 38 | Manikganj 162MW PP(MPGL) | IPP | 9*18 | 162 | 162 | 1868240 | |
| 39 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 175078 | |
| 40 | Kanchan Purbachal Power Gener | IPP | 18.4*3 | 55 | 0 | 0 | Engine problem |
| Dhaka area Total | | | | 5696 | 2474 | 53054275 | |
| 41 | Chattoogram TPP-1 | PDB | 1*210 | 180 | 0 | 0 | Under maint. |
| 41 | Chattoogram TPP-2 | PDB | 1*210 | 180 | 150 | 3700000 | |
| 42 | Razzan 25 MW PP | IPP | 3*8.9 | 25 | 25 | 468281 | |
| 43 | Teknaf 20MW PP (SolarTech) | SolarTech Energy | 20 | 20 | 0 | 109800 | |
| 44 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 42 | 796320 | Engine problem |
| 45 | Kapila Hydro Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 75 | 1771844 | Low water level |
| 46 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 217 | 5031104 | |
| 47 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 0 | 0 | Under maint. |
| 48 | Sikalbaha 105 MW PP (Baraka S) | IPP | 6*17.5 | 105 | 105 | 2542534 | |
| 49 | Hathazari 100 MW peaking PP | PDB | 1*118.9 | 98 | 34 | 283200 | Engine problem |
| 50 | Dohazari -Kalaish 100 MW Peak | PDB | 6*17 | 102 | 85 | 505190 | Fuel shortage |
| 51 | Juldah 100 MW Unit-1 (Accom) | QRPP | 8*13.45 | 100 | 0 | 0 | Contract Expired |
| 52 | Juldah 100 MW PP Unit-3 (Accom) | IPP | 8*13.5 | 100 | 90 | 2027520 | Engine problem |
| 53 | Barakunda 22 MW PP (Regent) | SIPP_PDB | 8*2.90 | 22 | 0 | 0 | Engine problem |
| ** | Malancha_Clg_EPZ (Unitted) | | 5*8.73+3*9.34 | 0 | 30 | 465120 | |
| 54 | Chattoogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 96 | 2203200 | Engine problem |
| 55 | Kapila 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 27121 | |
| 56 | Anwara 300 MW PP (Unitted) | IPP | 17*17+24 | 300 | 300 | 6892473 | |
| 57 | Jodiac Power | IPP | 3*18.35+1*3.6 | 54 | 54 | 1333159 | |
| 58 | Karnahuli Power Ltd. | IPP | 18.415*6+6.5 | 110 | 110 | 2654696 | |
| 59 | Juldah unit-2 (Accom) | IPP | 8*13.6 | 100 | 100 | 2235940 | |
| 60 | Anlima Energy Ltd. | IPP | 6*21.2 | 116 | 113 | 2659636 | |
| Chattoogram area Total | | | | 2382 | 1626 | 35704228 | |
| 61 | Ashuganj TPP Unit- 3 | APSCL | 1*150 | 0 | 0 | 0 | Contract Expired |
| 61 | Ashuganj TPP Unit- 4 | APSCL | 1*150 | 129 | 0 | 0 | Gas shortage |
| 61 | Ashuganj TPP Unit- 5 | APSCL | 1*150 | 134 | 0 | 0 | Gas shortage |
| 62 | Ashuganj 225 MW CCPP | APSCL | 1*142+1*75 | 221 | 210 | 4378000 | #REF! |
| 63 | Ashuganj 450 MW CCPP(North) | APSCL | 1*360 | 360 | 270 | 7407200 | FGMO |
| 64 | Ashuganj 450 MW CCPP(South) | APSCL | 1*360 | 360 | 260 | 6544000 | FGMO |
| 65 | Ashuganj 50 MW PP | APSCL | 14*3.988 | 45 | 5 | 445536 | Gas shortage |
| 66 | Ashuganj 55 MW PP (Precision) | RPP | 6*9.52 | 55 | 5 | 145440 | Gas shortage |
| 67 | Ashuganj 195MW PP (APSCL-U) | IPP | 20*9.73+1*116 | 195 | 8 | 217454 | Gas shortage |
| 68 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1207537 | |
| 69 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 143 | 3191563 | Engine problem |
| 70 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 18 | 536840 | Engine problem |
| 71 | Chandpur 150 MW CCPP | PDB | 1*106+1*57 | 163 | 40 | 1101890 | Machine problem |
| 72 | Chandpur 200MW (Desh energy) | IPP | 12*18 | 200 | 200 | 3255440 | |
| 73 | Feni 22MW PP (Doreen) | SIPP_PDB | 8*2.90 | 22 | 22 | 443556 | |
| 74 | Feni 11 MW PP (Doreen) | SIPP_REB | 4*2.90 | 11 | 11 | 221400 | |
| ** | Impoport (Tripura) | Imported power | 0 | 160 | 166 | 3463680 | |
| 75 | Jangalia 33MW PP (Summit) | SIPP_PDB | 4*8.73 | 33 | 15 | 483900 | Engine problem |
| 76 | Jangalia 52 MW PP (Lakdattav) | IPP | 6*8.92 | 52 | 42 | 1017749 | Engine problem |
| 77 | Cumilla 25 MW PP (Summit) | SIPP_PDB | 3*9.67+2*9.67 | 25 | 29 | 1174110 | Engine problem |
| 78 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 200 | 1953216 | |
| 79 | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 98 | 1932300 | Engine problem |
| 80 | Chowmuhan 113 MW | IPP | 12*9.78+2*3.1 | 113 | 114 | 2561160 | |
| 81 | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 35 | 710280 | 33 kV feeder O/L |
| 82 | Chandpur 115 (Doreen) | IPP | 4*18.5+2*22.5 | 115 | 101 | 1704880 | Engine problem |
| Cumilla Area Total | | | | 3014 | 2034 | 42348511 | |
| 83 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 20 | 251520 | Gas shortage |
| 84 | Tangail 22 MW PP (Doreen) | SIPP_PDB | 8*2.90 | 22 | 20 | 438912 | |
| 85 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 8 | 0 | 0 | Under maint. |
| 86 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 12650 | |
| 87 | Mymensingh 200 MW PP (Unitted) | IPP | 9*78*21 | 200 | 179 | 3552800 | Engine problem |
| 88 | Jamalpur 115 MW Solar PP (Unitted) | IPP | 9*78*12 | 115 | 106 | 1899200 | Engine problem |
| 89 | Sutialkhal 50 MW Solar PP | IPP | 50 | 50 | 0 | 295770 | |
| 90 | Tangail Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 24 | 585600 | |
| Mymensingh Area Total | | | | 622 | 336 | 6876452 | |
| 91 | Fenchugonj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 30 | 716000 | Machine problem |
| 92 | Fenchugonj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 29 | 682940 | Machine problem |
| 93 | Kushara 163 MW CCPP (KP) | IPP | 1*108+1*54 | 163 | 163 | 3695890 | |
| 94 | Shahjibazar 330 MW CCPP | PDB | 3*110 | 330 | 240 | 5299000 | Machine problem |
| 95 | Fenchugonj 51 MW PP (Barakat) | RPP | 19*2.90 | 51 | 11 | 624000 | Gas shortage |
| 95 | Fenchugonj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 0 | 41 | 804384 | Gas shortage |
| 96 | Hobgiganj 11MW PP (Confidence-E) | SIPP_REB | 4*2.90 | 11 | 11 | 181536 | |
| 97 | Shahjibazar GTPP (8 & 9) | PDB | 2*35 | 66 | 50 | 2307156 | Machine problem |
| 98 | Shahjibazar 86MW PP (Shahjiba) | RPP | 32*2.90 | 86 | 85 | 2005440 | |
| 99 | Shahjibazar 100 MW GTTP | PDB | 1*100 | 100 | 0 | 0 | Under maint. |
| 100 | Sylhet 225 MW CCPP | PDB | 1*142+1*89 | 231 | 219 | 4992300 | |
| 101 | Sylhet 20 MW GTTP | PDB | 1*20 | 20 | 0 | 0 | Gas shortage |
| 101 | Sylhet 50MW PP (EL) | RPP | 2*72 | 0 | 24 | 477600 | Gas shortage |
| 102 | Shahjahanilla 25 MW PP | SIPP_REB | 3*9.24 | 25 | 24 | 526668 | |
| 103 | Bibiana-II 341 MW CCPP (Summit) | IPP | 1*222+1*119 | 341 | 310 | 7142500 | FGMO |
| 104 | Bibyana-III 400 MW CCPP | PDB | 400 MW | 400 | 402 | 9412000 | |
| 105 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 250560 | |
| 106 | Bibyana South 400 MW | PDB | 400 MW | 383 | 390 | 9360500 | |
| Sylhet Area Total | | | | 2327 | 2039 | 47468354 | |
| 107 | Bheramara GTPP Unit-3 | PDB | 1*20 | 10 | 0 | 0 | Reserve. |
| ** | Bheramara (HVDC) | Imported power | 2*900 | 1000 | 922 | 22261090 | |
| 108 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 0 | 115 | 1684800 | |
| 109 | Faridpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 38 | 353760 | Engine problem |
| 110 | Khulna 225 MW CCPP | NWP/PGCL | 1*150+1*75 | 230 | 200 | 4093440 | |
| 111 | Cosalganj 100 MW Peaking PP | PDB | 16*16 | 109 | 0 | 16256 | Line O/L |
| 112 | Bheramara 410 MW CCPP | NWP/PGCL | 1*278+1*132 | 410 | 140 | 3694464 | Gas shortage |
| 113 | Noapara 40 MW PP (Khanjahan) | QRPP | 5*8.5 | 40 | 40 | 574125 | |
| 114 | Noapara 100 MW PP (Bangla Tr) | IPP | 70*1.4 | 100 | 85 | 954240 | Low Demand |
| 114 | Rupsha 105 MW PP (Orion rupsa) | IPP | 6*18.445 | 105 | 94 | 2178720 | Engine problem |
| 115 | Madhumati 100 MW PP | NWP/PGCL | 6*18 | 105 | 15 | 146018 | Line O/L |
| 116 | Montga Onon 100 MW Solar PP | IPP | 100 | 100 | 0 | 478600 | |
| Khulna Area Total | | | | 2229 | 1649 | 36435711 | |
| 117 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 32 | 422784 | Line O/L |
| 118 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 37 | 672152 | |
| 119 | Bhola 225 MW CCPP | PDB | 2*63+1*68 | 94 | 65 | 1575000 | Gas shortage |
| 120 | Bhola 95 MW PP (Aggreko) | QRPP | 96*1.10 | 95 | 0 | 0 | Contract Expired |
| 121 | Payra 1320 MW | BCPCL | 2*622 | 1244 | 622 | 13201000 | |
| 122 | Bhola Nutan Biddut BD LTD | IPP | 220 | 220 | 222 | 4941655 | |
| 123 | United Payra Power Ltd. | IPP | 8*18.5+1*9.5 | 150 | 35 | 154800 | Line O/L |
| Barisal Area Total | | | | 2046 | 1013 | 20967391 | |
| 124 | Baghabari 71 MW GTTP | PDB | 1*71 | 71 | 0 | 0 | Gas shortage |
| 124 | Baghabari 100 MW GTTP | PDB | 1*100 | 100 | 0 | 0 | Gas shortage |
| 125 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 43 | 677504 | Engine problem |
| 126 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 28 | 313373 | Engine problem |
| 127 | Amra 50 MW PP(Sinha) | QRPP | 7*7.9 | 0 | 0 | 0 | Contact expired |
| 128 | Katakhal 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 43 | 251629 | Engine problem |
| 129 | Katakhal 50 MW Peaking PP | PDB | 6*8.7 | 50 | 40 | 404200 | Engine problem |
| 130 | Sirajgonj Unit-1 225MW | NWP/PGCL | 1*150+1*75 | 210 | 0 | 0 | Gas shortage |
| 131 | Sirajgonj Unit-2 225MW | NWP/PGCL | 1*150+1*75 | 220 | 213 | 4430836 | Running on HSD |
| 132 | Sirajgonj Unit-3 225MW | NWP/PGCL | 1*141 | 220 | 116 | 3035700 | Gas shortage |
| 133 | Sirajgonj 400 MW CCPP Unit-4 | SNW/PGCL | 1*282+1*132 | 414 | 202 | 5280800 | Gas shortage |
| 134 | Santahar 50 MW Peaking PP | PDB | 6*8.7 | 50 | 32 | 475630 | Engine problem |
| 135 | Bogra 22 MW PP (GBB) | RPP | 6*4 | 22 | 22 | 435600 | |
| 136 | Bogra 20 MW PP (Energyprima) | RPP | 5*3.3+5*2 | 0 | 0 | 0 | Contract Expired |
| 137 | Ullapara 11 MW PP (Summit) | SIPP_REB | 4*2.90 | 11 | 11 | 228978 | |
| 138 | Natore 52 MW PP (Rajanka) | IPP | 6*8.92 | 52 | 43 | 349440 | |
| 139 | Chapainawabganj 100 MW Peak | PDB | 12*8.924 | 104 | 90 | 861784 | Engine problem |
| 140 | Baghabari 200 MW PP (Paramou) | IPP | | | | | |