

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022		Day : Tuesday				Date : 05.04.22						
Probable Maximum Demand :		14600 MW				Probable Maximum Generation : 14048 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 84.12 ft				Today = 83.88 ft						
		Rule Curve = 87.20 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.04.22 (Yesterday)		05.04.22 (Today)		04.04.22 (Yesterday)		Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100	140	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	220	70	200	230			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	60	63	60	60			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	80	98	115	135	262	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	110	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	110	118	STG Under maint.
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	115	0	0	0	165	110	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		Contract expired	
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x7.13	80	80	47	45	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	16	33	33			
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	18	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	41	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	94	105	90	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.08	149	149	150	150	150	150			
24	Kamalgahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	160	298	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (AR)	HSD (IPP)	25x12.4	300	300	295	303	300	300			
28	Bramhanagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	97	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	99	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	91	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	72	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	0	0	0			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
37	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	80	98	100	100			
38	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	92	94	100	100			
39	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	63	65	65	65			
Dhaka Zone Total				6155	5696	2384	2474	2621	2746	997	1680	
40	Kamaghulji Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	69	75	75	75	155	Low water level	
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30	Gas Shortage	
42	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	10	25	25	25			
44	Teknaf 20MW PP (Sartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	30	42	42	42			
46	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
48	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	231	217	200	210			
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300			
50	Julidah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		Contract expired	
51	Julidah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
52	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	51			
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	34	0	50			
54	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malanha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	30	5	30			
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	86	96	100	102			
56	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
57	Kamaghulji Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
58	Julidah unit 2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
59	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	94	113	113	113			
Chattogram Zone Total				2442	2382	1437	1626	1545	1607	365	150	
60	a) Ashuganj TPP Unit-4	Gas (AFSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
61	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	26	5	26	26	40	Gas Shortage	
62	Ashuganj 225 MW CCGP	Gas (AFSCL)	1x142+175	221	221	173	210	210	200			
63	Ashuganj 450 MW CCGP(South)	Gas (AFSCL)	1x360	360	360	260	260	300	310	100	Gas Shortage	
64	Ashuganj 450 MW CCGP(North)	Gas (AFSCL)	1x361	360	360	310	270	300	310	90	Gas Shortage	
65	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	25	25	50	Gas Shortage	
66	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
67	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
68	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	143	145	145			
69	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	41	18	32	42			
70	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	40	40	50	123	Gas Shortage	
71	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	48	200	200	200			
72	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
73	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
74	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	15	31	31			
75	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	42	43	43			
76	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	25	22	22	22			
77	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	8x1+4x31.315+1x1.056	200	200	0	200	100	200			
78	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	80	98	80	80			
79	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	105	114	113	113			
80	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	10	35	35	35			
81	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	101	100	100			
**	Impport (Tripura)	India		160	160	140	166	143	166			
Cumilla Zone Total				3059	3014	1543	2034	2037	2190	853	0	
82	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	8	7	10	10	195	Gas Shortage	
83	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
84	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. :8MW	
85	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	106	106	107			
86	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	143	179	106	190			
87	Sarikhaba 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
88	Sutakhaba 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0			
89	Tangal 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total				717	622	267	336	316	349	195	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.04.22 (Yesterday)		05.04.22 (Today)		04.04.22 (Yesterday)		Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
90	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	20	20		40	GT1 Under maint.
91	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	29	29	20	30		61	GT4 Under maint.
92	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	11	50	51			
93	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	163	163	163	163			
94	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
95	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	50	55	55			
96	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	238	240	240	240			
97	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	85	86	88			
98	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220			
99	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage
100	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
101	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24			
102	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	300	300			
103	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	399	402	400	400			
104	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	390	400	400			
105	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
	Sylhet 50MW PP (EPL)	Gas (RPP)	2x27			18	24	24	25			
	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5*2			32	41	41	41			
	Sylhet Zone Total			2422	2377	2021	2039	2064	2078	20	201	
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278-1 x 132	410	410	140	140	160	160	270		Gas shortage
108	Fairdipanj 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	38	0	42			Line Overload
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30			Line Overload
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	155	200	225	225			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	1	85	100	100			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	75	94	94	94			
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	100	100			Line Overload
114	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	48	0	50	0			
115	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	62	115	16	115			
	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5*8.5			24	40	32	40			
**	Bheramara (HVDC)	India		1000	1000	921	922	934	934			
	Khulna Zone Total			2348	2229	1426	1649	1711	1840	270	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	110			Line Overload
117	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	37	25	35			
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	64	65	65	90			
119	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	622	660	660	622		Line Overload
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	100			Line Overload
122	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220			
	Barisal Zone Total			2046	2046	676	1013	1002	1215	0	622	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	20	43	34	43			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	172	100	200			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	28	40	45			
127	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	90	90	93			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	40	50			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	36	36			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	139	213	220	220			Running on HSD
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	117	116	120	120	104		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	196	202	280	280	212		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22			
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	43	52			
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113			
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
	Rajshahi Zone Total			2129	2129	765	1261	1268	1438	697	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	77	80	80			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Coal shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	109	110	113	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	10			
146	Majpara, Tatala 8 MW Solar PP (Sympha Powe)	Solar (IPP)	1 x 8	8	8	2	0	8	0			
147	Thakurgaon 119MW PP (Energytac)	HFO (IPP)	6*20	115	115	100	115	115	115			
	Rangpur Zone Total			800	720	539	560	566	585	0	85	
	Sub-total: Plants in operation			22118	21215	11058.0	13012	13130	14048	3397	2738	
	Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					11230	12514	13334	14266			
	(B) Plants under long term maintenance/contract expired											
148	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
150	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
	Sub-Total: Plants under long term maintenance/contract expired			178	0	0	0	0	0			
	Gross Total			22296	21215	11058	13012	13130	14048	3397	2738	

(C) Actual data of 04.04.22 (Yesterday) Monday :				Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
Sl. No.	Parameter	Value	Unit	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
01.	Max. Demand at eve. peak (Generation end)	13712.00	MW, at = 21:00 hrs								
02.	Max. Demand at eve. peak (Sub-station end)	13214.25	MW, at = 21:00 hrs								
03.	Highest Generation (Generation end)	13144.00	MW, at = 22:00 hrs								
04.	Minimum Generation (Generation end)	9875.00	MW, at = 7:00 hrs	Dhaka	4875	4825	50	Mymensingh	1163	863	300
05.	Day-peak Generation (Generation end)	11058.00	MW, at = 12:00 hrs	Chattoagram	1303	1283	20	Sylhet	478	478	0
06.	Evening-peak Generation (Generation end)	13012.00	MW, at = 21:00 hrs	Khulna	1645	1525	120	Barishal	401	401	0
07.	Evening Peak Load-shed (Sub-station end)	700.00	MW, at = 21:00 hrs	Rajshahi	1314	1134	180	Rangpur	745	715	30
08.	Minimum Generation Forecast up to 8:00 hrs.	10597.00	MW, at = 5:00 hrs	Cumilla	1291	1291	0				
09.	Generation shortfall at evening peak due to :							Total	13214	12514	700
a)	Gas limitation	3242	MW	13.	Fuel cost :	(a) Gas = 115477897 Taka	(c) Coal = 103131667 Taka				
c)	Coal supply Limitation	0	MW			(b) Oil = 1020389931 Taka	Total = 1238999495 Taka				
b)	Low water level in Kaptai lake	155	MW								
c)	Plants under shut down/ maintenance	2738	MW								
10.	Total Energy (Generation + India Import)	280.16	MKWh	14.	Maximum Temperature in Dhaka was :	33.4° C					
	By Gas = 114.963 MKWh				Export through East-West interconnections :						
	By Coal = 21.327 MKWh				At evening peak-hour	530 MW, at 21:00 hrs					
	By Solar= 1.149 MKWh				Maximum	310 MW, at 18:30 hrs					
					Energy	0 MKWh					
11.	Total Gas Supplied	915.03	MMCFD	15.	Probable Max. Temperature in Dhaka :	37.2° C					

(D) Forecast of 05.04.22 (Today) Tuesday :							
01.	Maximum Demand	14600	MW (Generation end)	04.	Maximum Load-shed	560.58969	MW At evening peak (Sub-station end)
02.	Maximum Generation	14048	MW (Generation end)	05.	Total Generation	311.20	MKWh
03.	Reserve / Shortage	-552	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	37.2° C	

* Captive Power: ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation