

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022		Day : Wednesday				Date : 06.04.22						
Probable Maximum Demand :		14600 MW				Probable Maximum Generation : 14251 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 83.88 ft		Today = 83.64 ft		Rule Curve = 87.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.04.22 (Yesterday)		06.04.22 (Today)		05.04.22 (Yesterday)		Status of Machines under shut-down Maintenance	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation (MW)	Machines shut down (MW)	Description/ Remarks			
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100	140	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	220	220	200	220			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	88	90	90			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	128	142	150	150	218	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.	
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	165	110	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		Contract expired	
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+6x3.33	80	80	49	53	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	33	33	33			
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	21	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	49	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	90	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.08	149	149	150	150	150	150			
24	Kamalgahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	298	300	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	147	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x12.4	300	300	301	304	300	300			
28	Bramhanagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	95	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	35	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	0	0	0			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
37	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	88	99	100	100			
38	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	83	100	100	100			
39	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	65	65	78	78			
Dhaka Zone Total				6155	5696	2547	2738	2699	2794	1178	1562	
40	Kamaghulji Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	72	75	75	158	Low water level	
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30	Gas Shortage	
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
44	Teknaf 20MW PP (Sartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	42	42	42	42			
46	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	87	105	105	105			
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
48	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	213	229	230	230			
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	280	300	300	300			
50	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		Contract expired	
51	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
52	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85			
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	51	0	50			
54	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malanchar, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	35	5	35			
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	77	95	100	100			
56	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
57	Kamaghulji Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	93	110	110	110			
58	Juldah unit 2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
59	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113			
Chattogram Zone Total				2442	2382	1416	1656	1575	1664	368	150	
60	a) Ashuganj TPP Unit-4	Gas (AFSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
61	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	23	0	26	26	45	Gas Shortage	
62	Ashuganj 225 MW CCGP	Gas (AFSCL)	1x142+175	221	221	139	146	210	200	75	Gas Shortage	
63	Ashuganj 450 MW CCGP(South)	Gas (AFSCL)	1x360	360	360	260	250	300	300	110	Gas Shortage	
64	Ashuganj 450 MW CCGP(North)	Gas (AFSCL)	1x361	360	360	270	280	300	300	80	Gas Shortage	
65	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	5	25	25	50	Gas Shortage	
66	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
67	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
68	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	147	145	145			
69	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	32	42			
70	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	30	79	40	80	84	Gas Shortage	
71	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
72	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22			
73	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
74	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	8	31	31			
75	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43			
76	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	19	22	22			
77	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	89x1.4+40x1.015+15x1.059	200	200	150	200	100	200			
78	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	80	80	80	80			
79	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	95	113	113	113			
80	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54			
81	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	59	101	100	100			
**	Import (Tripura)	India		160	160	148	162	143	166			
Cumilla Zone Total				3059	3014	1781	2020	2037	2219	894	0	
82	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	8	20	10	10	182	Gas Shortage	
83	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20			
84	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
85	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	90	115	106	107			
86	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	106	190	106	190			
87	Sarikhaba 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
88	Sutakhaba 50 MW Solar PP	Solar (

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.04.22 (Yesterday)		06.04.22 (Today)		05.04.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
90	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	20	20			GT1 Under maint.	
91	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	20	31	20	30			GT4 Under maint.	
92	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	51				
93	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	110	140	163	163				
94	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
95	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	55	55	55				
96	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	239	239	240	240				
97	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	88	86	88				
98	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
99	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
100	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
101	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	23	24	24				
102	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	305	305	305				
103	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	392	403	400	400				
104	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	392	395	400	400				
105	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
	Sylhet 50MW PP (EPL)	Gas (RPP)	2x27			25	28	27	28				
	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5*2			38	40	41	41				
Sylhet Zone Total					2422	2377	1989	2071	2072	2086	20	199	
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	140	170	170	170	270		Gas shortage	
108	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	13	15	0	42			Line Overload	
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30			Line Overload	
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	225	230	200	200	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	54	99	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	76	94	94	94				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	100	100			Line Overload	
114	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	77	0	50	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	16	115	16	115				
	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5*8.5			16	40	32	40				
**	Bheramara (HVDC)	India		1000	1000	914	917	940	940				
Khulna Zone Total					2348	2229	1506	1635	1727	1856	270	0	
116	Bansail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	32	110			Line Overload	
117	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	37	25	35				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	89	90	90				
119	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	600	660	660	644		Line Overload	
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	100			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	221	220	220				
Barisal Zone Total					2046	2046	772	1012	1027	1215	0	644	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	169	171	100	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	6	22	40	45				
127	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	93				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	14	40	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	40	50				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	36	36				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	211	213	220	220			Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	114	114	120	120	106		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	263	255	325	325	159		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22				
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	52	43	52				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total					2129	2129	1068	1330	1313	1483	646	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80				
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Coal shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	15	0	15				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	102	109	113	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	10				
146	Majpara, Tatala 8 MW Solar PP (Sympha Powe)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon 119MW PP (Energytac)	HFO (IPP)	6*20	115	115	115	115	115	115				
Rangpur Zone Total					800	720	550	577	566	585	0	85	
Sub-total: Plants in operation					22118	21215	11914.0	13406	13332	14251	3558	2640	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11942	12858	13363	14285			
(B) Plants under long term maintenance/contract expired													
148	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
150	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					178	0	0	0	0	0	0	0	
Gross Total					22296	21215	11914	13406	13332	14251	3558	2640	

(C) Actual data of 05.04.22 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)	: 13966	MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 13438	MW, at = 20:00 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 13431	MW, at = 22:00 hrs		Dhaka	4947	4902	45	Mymensingh	1096	926	170
04.	Minimum Generation (Generation end)	: 10597	MW, at = 7:00 hrs		Chattoagram	1326	1281	45	Sylhet	513	493	20
05.	Day-peak Generation (Generation end)	: 11914	MW, at = 12:00 hrs		Khulna	1654	1554	100	Barisal	381	381	0
06.	Evening-peak Generation (Generation end)	: 13406	MW, at = 20:00 hrs		Rajshahi	1407	1297	110	Rangpur	827	757	70
07.	Evening Peak Load-shed (Sub-station end)	: 580	MW, at = 20:00 hrs		Cumilla	1287	1267	20				
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10715	MW, at = 5:00 hrs						Total	13438	12858	580
09.	Generation shortfall at evening peak due to :				13.	Fuel cost :						
a)	Gas limitation	: 3400	MW		(a) Gas =	117217674	Taka	(c) Coal =	103798284	Taka		
d)	Coal supply Limitation	: 0	MW		(b) Oil =	1182903612	Taka	Total =	1403919570	Taka		
b)	Low water level in Kapali lake	: 158	MW		14.	Maximum Temperature in Dhaka was : 34.2° C						
c)	Plants under shut down/ maintenance	: 2640	MW		15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import)	: 296.48	MKWh		At evening peak-hour	: 346	MW, at	20:00	hrs			
	By Gas = 116.504 MKWh		By Oil = 129.990 MKWh		Maximum	: 198	MW, at	18:30	hrs			
	By Coal = 21.526 MKWh		By Hydro = 1.718 MKWh		Energy	: 0	MKWh					
	By Solar= 1.333 MKWh											
11.	Total Gas Supplied	: 917.74	MMCFD									

(D) Forecast of 06.04.22 (Today) Wednesday :												
01.	Maximum Demand	: 14600	MW (Generation end)	04.	Maximum Load-shed	: 371.79577	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	: 14251	MW (Generation end)	05.	Total Generation	: 322.29	MKWh					
03.	Reserve / Shortage	: -349	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 37.3° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation