

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month April, 2022		14400 MW				Day: Thursday				Date: 07.04.22	
Probable Maximum Demand :		14400 MW				Probable Maximum Generation : 14400 MW				Rule Curve = 86.80 ft	
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 83.64 ft				Today = 83.35 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.04.22 (Yesterday)		07.04.22 (Today)		06.04.22 (Yesterday)		Status of Machines under shut-down Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall : 0		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	130	130	130	110	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	240	250	250	250		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	91	81	90	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	166	118	150	200	242	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under maint.
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	110
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		Contract expired
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	76	84	80	84		
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
18	Summit Power (Madhabdi+Asthula)	Gas (SIPP, REB)	6x3.67+3x7.13	80	80	54	54	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.7	33	33	33	33	33	33		
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.7	33	33	24	23	33	33		
21	Govipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	48	51	51		
22	Govipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	70	70	70		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.08	149	149	150	150	150	150		
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	298	298	300	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	145	149	149	149		
27	Karanganj 300 MW PP (AR)	HSD (IPP)	25x11.4	300	300	148	303	300	300		
28	Bramhangon 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	70	97	100	100		
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	70	100	100	100		
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	144	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0		
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	28	40	54		
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
37	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	100	100	100	100		
38	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	90	100	100	100		
39	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	78	80	78	80		
Dhaka Zone Total			6155	5696	2471	2783	2858	2926	1754	1040	
40	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	72	70	72	70	158	Low water level
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30	Gas Shortage
42	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
44	Teknaf 20MW PP (Sartech)	Solar (IPP)	1x20	20	20	17	0	20	0		
45	Palenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	36	30	36		
46	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	88	105	105	105		
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	203	230	230		
49	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300		
50	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	0	0		Contract expired
51	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	90	90		
52	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85		
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	2	51	0	50		
54	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
*	Malanha, Ctg, EPZ (Uniled)	Gas	5x8.73+3x9.34			2	30	5	30		
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	88	96	100	100		
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	46	54	54	54		
57	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
58	Juldah unit 2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
59	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113		
Chattogram Zone Total			2442	2382	1447	1620	1558	1650	368	150	
60	a) Ashuganj TPP Unit-4	Gas (AFSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	b) Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
61	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	0	17	17	17	28	Gas Shortage
62	Ashuganj 225 MW CCPP	Gas (AFSCL)	1x142+1*75	221	221	71	181	180	200	40	Gas Shortage
63	Ashuganj 450 MW CCPP(South)	Gas (AFSCL)	1x360	360	360	215	260	300	300	100	Gas Shortage
64	Ashuganj 450 MW CCPP(North)	Gas (AFSCL)	1x361	360	360	270	280	300	300	80	Gas Shortage
65	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	5	5	5	50	Gas Shortage
66	Ashuganj 195MW PP (AFSCL-Uniled)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	8	195	Gas Shortage
67	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
68	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	132	130	132		
69	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	32	42		
70	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	85	65	60	85	98	Gas Shortage
71	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	190	200	200	200		
72	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
73	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
74	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	12	8	25	25		
75	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43		
76	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
77	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	89x1.4+40x1.05+15x1.05	200	200	120	200	100	200		
78	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	62	47	50	60		
79	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	89	115	113	113		
80	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	35	36		
81	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	59	101	100	100		
**	Impport (Tripura)	India		160	160	144	166	143	166		
Cumilla Zone Total			3059	3014	1618	2001	1945	2136	854	0	
82	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	54	72	100	120	130	Gas Shortage
83	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20		
84	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. :8MW
85	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	107	115	106	115		
86	Myensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	106	172	150	190		
87	Sarsikabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
88	Sutakthali 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0		
89	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	22	0	22	22		
Myensingh Zone Total			717	622	318	379	450	467	130	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.04.22 (Yesterday)		07.04.22 (Today)		06.04.22 (Yesterday)		Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
90	Fenchugonj CPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT1 Under maint.
91	Fenchugonj CPP Phase-2	Gas (PDB)	2x35-1x35	104	90	31	31	30	30		59	GT4 Under maint.
92	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	39	52	50	51			
93	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109-1x54	163	163	163	163	163	163			
94	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
95	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	50	50	50			
96	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	245	244	240	250			
97	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	88	89	86	86			
98	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220			
99	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage
100	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
101	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	23	24	24			
102	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	315	305	320			
103	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	402	400	400			
104	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	393	400	400			
105	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
	Sylhet 50MW PP (EPL)	Gas (RPP)	2x27			24	27	27	27			
	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12*3.3+5*2			0	0	20	30			
Sylhet Zone Total				2422	2377	1993	2060	2066	2102	20	199	
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	175	205	200	210	205		Gas shortage
108	Fairdighat 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	39	0	40			Line Overload
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30			Line Overload
110	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 150+1x75	225	230	200	200	225	225			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	26	99	100	100			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	95	95	94	95			
113	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	15	100	100			Line Overload
114	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	82	0	50	0			
115	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	16	83	83	83			
	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5*8.5			16	32	31	40			
**	Bheramara (HVDC)	India		1000	1000	923	923	940	940			
Khulna Zone Total				2348	2229	1533	1691	1823	1863	205	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	110			Line Overload
117	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	27	38	25	35			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	89	88	90	90			
119	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	610	660	660	634		Line Overload
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	100			Line Overload
122	Barisal 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	221	220	220		634	
Barisal Zone Total				2046	2046	786	1006	1027	1215	0	634	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	43			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	170	170	150	170			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	6	29	40	40			
127	Chapainawaabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	90	90			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	40	43			
130	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	30			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	214	213	220	220			Running on HSD
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	124	150	120	150	70		Gas Shortage
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	310	414	350	414			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22			
136	Lillaipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	43	52			
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.56	113	113	113	113	113	113			
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.56	113	113	113	113	113	113			
140	Sirajgonj 6.56 MW Solar	Solar (NWP/CGCL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total				2129	2129	1143	1524	1382	1551	451	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	79	80	80			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Coal shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	12	0	12			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	106	107	113	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	10			
146	Majpara, Tatala 8 MW Solar PP (Sympha Powe	Solar (IPP)	1 x 8	8	8	2	0	8	0			
147	Thakurgaon 119MW PP (Energytac)	HFO (IPP)	6*20	115	115	115	115	115	115			
Rangpur Zone Total				800	720	547	571	566	580	0	85	
Sub-total: Plants in operation				22118	21215	11856.0	13635	13675	14490	3782	2108	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						11666	13011	13455	14257			
(B) Plants under long term maintenance/contract expired												
148	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3-5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired				178	0	0	0	0	0			
Gross Total				22296	21215	11856	13635	13675	14490	3782	2108	

(C) Actual data of 06.04.22 (Yesterday) Wednesday :											
01.	Max. Demand at eve. peak (Generation end)	: 14040 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 13416 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	: 13687 MW, at = 22:00 hrs		Dhaka	4897	4865	32	Mymensingh	1076	981	95
04.	Minimum Generation (Generation end)	: 10715 MW, at = 7:00 hrs		Chattoogram	1279	1279	0	Sylhet	549	539	10
05.	Day-peak Generation (Generation end)	: 11856 MW, at = 12:00 hrs		Khulna	1679	1594	85	Barishal	402	402	0
06.	Evening-peak Generation (Generation end)	: 13635 MW, at = 21:00 hrs		Rajshahi	1506	1445	61	Rangpur	766	736	30
07.	Evening Peak Load-shed (Sub-station end)	: 405 MW, at = 21:00 hrs		Cumilla	1263	1171	92	Total	13416	13011	405
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10537 MW, at = 5:00 hrs		Fuel cost :	(a) Gas = 133097349 Taka		(c) Coal = 103474195 Taka				
09.	Generation shortfall at evening peak due to :				(b) Oil = 1139300657 Taka		Total = 1375872200 Taka				
	a) Gas limitation	: 3624 MW		14.	Maximum Temperature in Dhaka was : 34.1° C						
	c) Coal supply Limitation	: 0 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kapail lake	: 158 MW			At evening peak-hour : 386 MW, at 21:00 hrs						
	c) Plants under shut down/ maintenance	: 2108 MW			Maximum : 10 MW, at 3:00 hrs						
10.	Total Energy (Generation + India Import)		: 305.07 MKWh		Energy : 0.005 MKWh						
	By Gas =	128.328 MKWh	By Oil =	126.520 MKWh							
	By Coal =	21.458 MKWh	By Hydro =	1.735 MKWh							
	By Solar=	1.166 MKWh									
11.	Total Gas Supplied	: 968.76 MMCFD									

(D) Forecast of 07.04.22 (Today) Thursday :					
01.	Maximum Demand	: 14400 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)
02.	Maximum Generation	: 14490 MW (Generation end)	05.	Total Generation	: 320.96 MKWh
03.	Reserve / Shortage	: 90 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	: 37.7° C

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation