

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month April, 2022			Day : Sunday		Date : 10.04.22							
Probable Maximum Demand :			14500 MW		Probable Maximum Generation : 14751 MW							
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 82.76 ft	Today = 82.39 ft	Rule Curve = 86.20 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.04.22 (Yesterday)		10.04.22 (Today)		09.04.22 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	(Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	234	232	240	240			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	70	250	250	250			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	101	104	105	105			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	327	325	325			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	32	404	352	412			
11	Siddhirganj 55 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	110	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	145	150	150	190	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	84	93			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.7+1x7.7	80	80	53	53	55	55			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.7	33	33	33	33	33	33			
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.7	33	33	33	24	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	49	51	51			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	90	90	90			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150			
23	Kamalahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	283	281	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
26	Karawang 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	100	304	300	300			
27	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	100	100	100			
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	35	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	144	162			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	54			
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirganj 100 PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	98	100	100			
37	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	82	100	100	100			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	45	68	78	80			
Dhaka Zone Total				6055	5898	2577	3585	3699	3757	1295	590	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	69	70	72	161	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Telrafi 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	44	42	42			
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	205	225	230	230			
48	Anwara 300 MW PP (Unitec)	HFO (IPP)	17x17.076+3x8.94	300	300	281	300	300	300			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	42	0	42			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
	* Malancha, Ctg.EPZ (Unitec)	Gas	5x8.73+3x9.34			2	30	30	40			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	80	81	100	100			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113			
Chattogram Zone Total				2342	2282	1281	1473	1445	1508	521	150	
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	29	30	16	Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	160	166	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	300	300	260	300	300	100	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x360	360	290	280	300	300	300	80	Gas Shortage	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50	Gas Shortage	
64	Ashuganj 198MW PP (APSCL-Unitec)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	135	130	135			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	86	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	21	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	42	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	21	21			
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.40+1.015+15x1.056	200	200	140	200	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	80	80	80	80			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	105	115	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	36	78	78			
**	Impport (Tripura)	India		160	160	146	166	143	166			
Cumilla Zone Total				3059	3014	1899	1944	1963	2092	696	0	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	120	129	160	160	73	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	20	20	20			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	49	97	96	98			
84	Mymensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	57	107	150	190			
85	Santahani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	15	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total				717	622	287	375	500	4			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.04.22 (Yesterday)		10.04.22 (Today)		09.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	0	0	0	0		70	GT1 Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	0	22	20	22		68	GT4 Under maint.
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	0	53	50	51			
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	120	120	120	120			
92	Hobgonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	55	52	52			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Gas Shortage
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142-1x89	231	231	140	140	200	220			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24			
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222-1x119	341	341	300	315	305	320			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	371	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	391	391	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	26	28	29	24		Gas Shortage
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	44		Gas Shortage
Sylhet Zone Total					2522	2477	1565	1627	1706	1745	418	238
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	250	240	285	285	170		Gas shortage
108	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	40			Line Overload
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30			Line Overload
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	125	200	200	210			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	98	100	100			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	88	94	94	95			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	80	100	100			Line Overload
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	50	0			
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	76	91	115	115			
116	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5*8.5	40	40	16	32	31	40			
**	Bheramara (HVDC)	India		1000	1000	913	914	932	932			
Khulna Zone Total					2388	2384	1582	1785	1907	1947	170	0
117	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	110			Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	40	25	35			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	87	90	90			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	622	400	660	622		Line Overload
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	100			Line Overload
122	Bhola 220MW CAPP (Nutan Bidyt Bl)	Gas/HSD (IPP)	2x75-1x70	220	220	215	220	220	220			
Barishal Zone Total					1958	1958	822	1018	784	1215	0	622
a)	Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage
b)	Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100			Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	43			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	171	150	170			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	7	21	40	40			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	91	90	92			
128	Katakahi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	8	40	0	40			
129	Katakahi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	40	43			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	30	30			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	136	212	220	220			Running on HSD
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	183	168	150	160	52		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	415	350	414			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
137	Natore 52 MW PP (Rajarjani)	HFO (IPP)	6x8.92	52	52	34	43	43	52			
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113			
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
Rajshahi Zone Total					2129	2129	1084	1523	1412	1563	433	0
a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	77	76	80	84			
b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	0	100			Coal shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	17	0	12			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	104	110	113	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	10			
146	Majpara, Tataba 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0			
147	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	115	115	115	115			
Rangpur Zone Total					800	720	545	576	316	434	0	85
Sub-total: Plants in operation					21970	21484	11642.0	13906	13732	14751	3606	1685
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					11145	13313	13146	14122				
(B) Plants under long term maintenance/ contract expired												
148	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
149	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired
150	Juddha 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
152	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					378	0	0	0	0			
Gross Total					22348	21484	11642	13906	13732	14751	3606	1685
(C) Actual data of 09.04.22 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)		13906 MW, at = 21:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)		13313 MW, at = 21:00 hrs									
03.	Highest Generation (Generation end)		13963 MW, at = 22:00 hrs									
04.	Minimum Generation (Generation end)		10153 MW, at = 6:00 hrs	Dhaka	4973	4973	0	Mymensingh	902	902	0	
05.	Day-peak Generation (Generation end)		11642 MW, at = 12:00 hrs	Chattogram	1274	1274	0	Sylhet	528	528	0	
06.	Evening-peak Generation (Generation end)		13906 MW, at = 21:00 hrs	Khulna	1763	1763	0	Barishal	414	414	0	
07.	Evening Peak Load-shed (Sub-station end)		0 MW, at = 21:00 hrs	Rajshahi	1479	1479	0	Rangpur	682	682	0	
08.	Minimum Generation Forecast up to 8:00 hrs.		10122 MW, at = 5:00 hrs	Cumilla	1298	1298	0					
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation		3445 MW									
d)	Coal supply Limitation		0 MW									
b)	Low water level in Kaptai lake		161 MW									
c)	Plants under shut down/ maintenance		1685 MW									
10.	Total Energy (Generation + India Import)		291.27 MKWh									
	By Gas = 130.373 MKWh			By Oil = 110.444 MKWh								
	By Coal = 22.023 MKWh			By Hydro = 1.582 MKWh								
	By Solar = 1.185 MKWh											
11.	Total Gas Supplied		975.15 MMCFD									
(D) Forecast of 10.04.22 (Today) Sunday :												
01.	Maximum Demand		14500 MW (Generation end)									
02.	Maximum Generation		14751 MW (Generation end)									
03.	Reserve / Shortage		251 MW (Generation end)									
04.	Maximum Load-shed		0 MW (Generation end)									
05.	Total Generation		302.48 MKWh									
06.	Probable Max. Temperature in Dhaka		33.6° C									

#Remarks: Highest Generation 14008 MW on 07-04-2022 at 22:00

(Md. Helalur Rahman)
Deputy Secretary, Generation