

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1120	180	232	557000	
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	250	4900218	Gas shortage
5	Ghorasal 78.5 MW PP(MAX)	ORPP	240	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	102	1152090	
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1273+1138	412	396	712740	
9	Haripur 360MW CCPP(HPL)	IPP	1235+1125	360	324	748800	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150	450	350	7988750	Gas shortage
11	Meghnaghat 100 MW(IEI)	ORPP	1278.9	100	91	2282880	Engine problem
12	Meghnaghat CCPP(Summit)	IPP	2110+1110	335	250	6347665	FGMO
13	Madanganj 102 PP(Summit)	ORPP	617	102	78	1838304	Engine problem
14	Madanganj-55 MW PP(Summit)	(IPP)	317.08+111.3	55	55	953053	
15	Karanganj 100 MW PP (Poweres)	ORPP	813.45	0	0	0	Contract Expired
16	Narsingh 22 MW PP (Doreen)	SIPP, REB	812.90	22	22	464292	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 212 MW GTTP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	1278.9	100	100	1065600	
20	Siddhirgonj 335 MW CCPP	EGCB	1217+118	335	333	7892140	
21	Saagaraj 102 MW PP (Digital Po)	IPP	1218.924	102	92	1666676	Engine problem
22	Katpali 52 MW PP (Sinha)	IPP	77.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En)	IPP	318	54	54	1307160	
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	150	1977120	
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	1121733	
26	Nabaganj 55 MW PP (Southern)	IPP	319.3	55	55	1002000	
27	Basila 108MW PP(ULCL)	IPP	1278.75+113.5	0	0	0	
28	Summit Power (Madhabdidi Ashuli)	SIPP, REB	313.67+478.73	80	51	1144380	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	478.73	33	33	778700	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	478.73	33	33	800200	
31	Gazipur 52 MW PP	RPCL	617.5	52	50	1007040	#REF!
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	273	4385889	Engine problem
34	Keranganj 300 MW PP (APRI)	IPP	2561.4	300	255	7711102	low demand.
35	Bramhangonj 100 MW PP (Aggr)	IPP	1147.959	100	100	307412	
36	Auraahat 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	80	240849	low demand.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	149	3178656	
38	Gazipur 100 MW PP	RPCL	617.5	105	90	1525200	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	183.5	104	104	2330680	
40	Manikganj 162 MW (MPGL)	IPP	9118	162	162	3074400	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	143314	
42	Kanchan Purbachal Power Gener	IPP	18.43	55	55	1067760	
<b>Dhaka area Total</b>				<b>5898</b>	<b>4424</b>	<b>8289403</b>	
43	Chattogram TPP-1	PDB	1210	180	0	0	Under maint.
44	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Razzan 25 MW PP	IPP	378.9	25	25	285946	
46	Teknar 20MW PP (Solartech/Teenal Solartech Energ	IPP	20	20	0	120860	
47	Patenga 50MW PP (Baraka)	IPP	816.98	50	37	741120	Engine problem
48	Kaptai Hydro: Unit-1,2,3,4,5	PDB	240+3150	230	69	1660844	Low water level
49	Sikalbaha 225MW	PDB	1150+1175	225	204	483693	
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka St)	IPP	617.5	105	105	2387854	
52	Halahazi 100 MW peaking PP	PDB	1118.9	98	34	183301	Engine problem
53	Dohazari -Kalash 100 MW Peakin	PDB	817	102	85	473283	
54	Judha 100 MW Unit-1 (Acorn)	ORPP	813.45	0	0	0	Contract Expired
55	Judha 100 MW PP Unit-3 (Acorn)	IPP	813.5	100	90	2007360	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	812.90	22	0	0	Engine problem
57	Malancha Cig. EP2 (United)	IPP	578.73+379.34	0	25	400320	
58	Chattogram 108 MW PP (ECPPV)	IPP	167	108	81	1982700	Engine problem
59	Kaptai 7 MW Solar Plant	PDB	7.4	7	0	28439	
60	Anwara 300 MW PP (United)	IPP	1717+24	300	300	6739418	
61	Jodiac Power	IPP	318.55+13.6	54	54	1330236	
62	Karnaphuli Power Ltd.	IPP	18.415+6+6.5	110	110	2668834	
63	Judha unit-2 (Acorn)	IPP	813.6	100	100	2031360	
64	Anima Energy Ltd.	IPP	621.2	116	113	2594400	
<b>Chattogram area Total</b>				<b>2282</b>	<b>1432</b>	<b>30492891</b>	
65	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCL	1150	129	0	0	Gas shortage
67	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
68	Ashuganj 225 MW CCPP	APSCL	1142+175	221	212	5004000	#REF!
69	Ashuganj 450 MW CCPP(North)	APSCL	1360	360	280	7745000	Gas shortage
70	Ashuganj 450 MW CCPP(South)	APSCL	1360	360	0	322800	Under S/D due to gas shortage
71	Ashuganj 50 MW PP	APSCL	1433.968	45	26	582706	Gas shortage
72	Ashuganj 55 MW PP (Precision)	RPP	15.4	55	54	1151040	
73	Ashuganj 195MW PP (APSCL-UR)	IPP	2079.73+116	195	8	1053818	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	619.34	51	51	1192295	
75	Ashuganj 150MW PP (Midland)	IPP	237.015	150	140	1975490	
76	Titas 50 MW Peaking PP	PDB	618.92	52	42	381400	
77	Chandpur 150 MW CCPP	IPP	11108+1157	163	0	0	Machine problem
78	Chandpur 200MW (Dash energy)	IPP	1218.4	200	200	2952480	
79	Feni 22MW PP (Doreen)	SIPP, PDB	812.90	22	20	136656	
80	Feni 11 MW PP (Doreen)	SIPP, REB	412.90	11	11	228060	
81	Imported (Tripura)	Imported power	0	160	164	3504960	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	478.73	33	33	672000	
83	Jangalia 52 MW PP (Kishore)	IPP	818.92	43	43	917935	Engine problem
84	Comilla 25 MW PP (Summit)	SIPP, PDB	313.67+218.97	25	20	420930	
85	Daudkandi 200 MW PP (B.Trac)	IPP	15411.4	200	100	161472	low demand.
86	Feni Lanka Power	IPP	718.415+19.78	114	80	1882200	Engine problem
87	Chowmuhani 113 MW	IPP	1219.78+23.1	113	116	1935600	
88	Bhairab 54.5 MW	IPP	318.2	54	36	776520	33 kV feeder problem.
89	Chandpur 115(Doreen)	IPP	418.5+222.5	115	101	1946880	Engine problem
<b>Comilla Area Total</b>				<b>3014</b>	<b>1737</b>	<b>3782934</b>	
90	RPCL 210MW CCPP	IPP	4135+1170	202	108	2836960	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIPP, PDB	812.90	22	20	406260	
92	Jamalpur 95 MW PP(Powerpac)	IPP	1278.924	8	0	0	Under maint.
93	Sarishabari 3 MW Solar Plant	IPP	1.3	3	0	11200	
94	Mymensingh 200 MW PP (Unites)	IPP	978.21	200	179	3376800	Engine problem
95	Jamalpur 115 MW PP (Unites)	IPP	978.12	115	106	2226000	
96	Saitakhal 50 MW Solar PP	IPP	50	50	0	233440	
97	Tangail Pali Power Gen 22 MW	IPP	476.7	22	22	513960	
<b>Mymensingh Area Total</b>				<b>622</b>	<b>435</b>	<b>9661120</b>	
98	Fenchugonj CCPP Phase-1	PDB	232+133	70	0	0	Machine problem
99	Fenchugonj CCPP Phase-2	PDB	235+135	90	40	950544	Machine problem
100	Kushaura 163 MW CCPP (KP)	IPP	1109+154	163	163	3782454	
101	Shajibazar 330 MW PP	PDB	3110	330	264	1676000	Machine problem
102	Fenchugonj 51 MW PP (Barakati)	RPP	192.90	51	10	245400	
103	Fenchugonj 44MW (Energyprima)	RPP	123.3+51.2	50	3	66600	Gas shortage
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	412.90	11	11	157488	
105	Shahjibazar GTTP Unit- 8 & 9	PDB	235	66	55	1417920	Gas shortage
106	Shahjibazar 86MW PP (Shahjibaz)	RPP	322.90	86	86	2031360	
107	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP (Barakati)	PDB	1142+189	219	219	5221410	
109	Sylhet 20 MW GTTP	PDB	120	20	0	0	Gas shortage
110	Sylhet 50MW PP (EPL)	RPP	27.2	50	27	618840	
111	Shahjahanulla 25 MW PP	SIPP, REB	319.34	25	23	458016	
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1222+1119	341	290	7015000	FGMO
113	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	370	8970000	
114	Sylhet 10MW PP (Dash)	RPP	81.85	10	10	246880	
115	Bibiyana South 400 MW	PDB	400 MW	383	382	9260200	
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1953</b>	<b>42054292</b>	
116	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
117	Bheramara (HVDC)	Imported power	2500	1000	922	22315636	
118	Khulna 115 PP MW (KPCL-2)	ORPP	717	115	97	1003200	Engine problem
119	Fandpur 50 MW Peaking PP	PDB	818.99	54	36	270240	Engine problem
120	Khulna 225 MW CCPP	NWPQCL	1150+175	230	210	3742690	
121	Gopalganj 100 MW Peaking PP	PDB	1616.98	109	0	0	Line O/L
122	Bheramara 410 MW CCPP	NWPQCL	1278+1132	410	405	9817344	
123	Noapara 40 MW PP (Khanjahan)	ORPP	578.5	40	40	631500	
124	Noapara 100 MW PP (Bangla Tr)	IPP	701.4	100	16	44160	low demand.
125	Rupsha 105 MW PP (Orion rupsh)	IPP	618.445	105	105	1955520	
126	Bibiyana-III 100 MW PP	NWPQCL	618	105	105	105112	
127	Mongla Orion 100 MW Solar PP	IPP	100	100	0	457920	
<b>Khulna Area Total</b>				<b>2384</b>	<b>1936</b>	<b>41295712</b>	
128	Barisal 110 MW PP (Summit)	IPP	717.076	110	32	1000512	Line O/L
129	Bhola 33 MW PP (Venture)	RPP	134.50	40	39	700442	
130	Bhola 225 MW CCPP	PDB	2763+168	194	86	2113779	Gas shortage
131	Bhola 95 MW PP (Aggreko)	ORPP	961.10	0	0	0	Contract Expired
132	Payra 1320 MW	BCPL	2122	124	420	1044200	Transformer O/L
133	Bhola Nutan Bidut BD LTD	IPP	220	170	170	5133600	
134	United Payra Power Ltd.	IPP	818.5+19.5	150	35	612000	Line O/L
<b>Barisal Area Total</b>				<b>1958</b>	<b>782</b>	<b>20000233</b>	
135	Baghabari 71 MW GTTP</						