

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation		Energy Generated	Remarks
					MW	KWH		
Unit No. X Capacity								
			MW	MW	MW	KWH		
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.	
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	232	5562000		
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	270	6306136	Gas shortage	
5	Ghorasal 78.5 MW PP(MAX)	ORPP	240	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	104	2338681		
7	Hariapur GTPP	SBU, PDB	232	20	0	0	Under maint.	
8	Hariapur 412 MW CCGP	EGCB	1273+1139	412	396	9574890		
9	Hariapur 350MW CCGP(HPL)	IPP	1235+1125	360	312	6100000	Gas shortage	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	225	4866750	Gas shortage	
11	Meghnaghat 100 MW(EL)	ORPP	128.9	100	94	2274240		
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	140	3370211	FGMO	
13	Madangan 102 PP(Summit)	ORPP	617	102	64	1812216	Engine problem	
14	Madangan-55 MW PP(Summit)	ORPP	317.08+111.3	55	55	1156260		
15	Karanganj 102 MW PP (Powerpac)	ORPP	813.45	0	0	0	Contract Expired	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	19	426636		
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.	
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	65	614000	Gas shortage	
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	128.9	100	96	1445760		
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	320	4087520		
21	Sagaura 102 MW PP (Digital Po)	IPP	128.924	102	92	1843776	Engine problem	
22	Katohli 52 MW PP (Sinha)	IPP	77.9	51	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco En)	IPP	318	54	35	987840	Engine problem	
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	150	2922240		
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	1110607		
26	Nabaganj 55 MW PP (Southern)	IPP	319.3	55	55	1145625		
27	Basila 108MW RPCL	IPP	128.924	102	92	2032880	Engine problem	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	318.87+418.73	80	53	1183920	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	48.73	33	33	811900		
30	Rupganj 33 MW PP(Summit)	SIPP, REB	48.73	33	33	769900		
31	Gazipur 52 MW PP	RPCL	68.9	52	49	1114080	#REF!	
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.	
33	Koinda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	278	5813562	Engine problem	
34	Karanganj 300 MW PP (APR)	IPP	2561.4	300	204	1346789	Low demand.	
35	Bramhangan 100 MW PP (Aggr)	IPP	1147.959	100	100	710288		
36	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	100	706938		
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	149	3596400		
38	Gazipur 100 MW PP	RPCL	67.75	105	105	1807200		
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	104	2140800	Gas shortage	
40	Manikganj 162MW PP (MPL)	IPP	918	162	162	2918860		
41	Spectra Solar Plant Ltd.	IPP	35	35	0	182476		
42	Kanchan Purbachal Power Gener	IPP	18.43	55	55	1128600		
				5898	4204	82203721		
Dhaka area Total								
43	Chattogram TPP-1	PDB	1210	180	0	0	Under maint.	
44	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage	
45	Razzan 25 MW PP	IPP	38.9	25	25	426474		
46	Talsind 20MW PP (Solartech/Teknaf Solar)	IPP	20	20	0	120560		
47	Patenga 50MW PP (Baraka)	IPP	86.88	50	38	870240	Engine problem	
48	Kapla Hydro: Unit-1,2,3,4, 5	PDB	240+350	230	69	1577198	Low water level	
49	Sikalbaha 225MW	PDB	1150+1175	225	203	5019754		
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.	
51	Sikalbaha 105 MW PP (Baraka St)	IPP	617.5	105	105	1896028		
52	Hathazari 100 MW Peaking PP	IPP	119.9	98	40	2814468	Engine problem	
53	Dohazari-Kalash 100 MW Peaking	PDB	617	102	84	450318	Engine problem	
54	Juldah 100 MW Unit-1 (Acorn)	ORPP	813.45	0	0	0	Contract Expired	
55	Juldah 100 MW Unit-3 (Acorn)	IPP	813.5	100	90	2067840	Engine problem	
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	0	0	Engine problem	
57	Malancha Cig. EP2 (United)	IPP	58.73+9.34	0	28	405600		
58	Chattogram 108 MW PP (ECPV)	IPP	18.97	108	82	2032880	Engine problem	
59	Kapla 7 MW Solar PP	PDB	7.4	7	0	29160		
60	Anwara 300 MW PP (United)	IPP	1717+24	300	300	6970255		
61	Jodiac Power	IPP	318.55+13.6	54	54	1331804		
62	Karnaphuli Power Ltd.	IPP	18.415+6+6.5	110	110	2658798		
63	Juldah unit-2 (Acorn)	IPP	813.6	100	100	2140800		
64	Anlima Energy Ltd.	IPP	621.2	116	113	2608200		
				2282	1441	3084717		
Chattogram area Total								
65	Ashuganj TPP Unit-3	APSCCL	1150	129	0	0	Contract Expired	
66	Ashuganj TPP Unit-4	APSCCL	1150	129	0	0	Gas shortage	
67	Ashuganj TPP Unit-5	APSCCL	1150	134	0	0	Gas shortage	
68	Ashuganj 225 MW CCGP	APSCCL	1142+1175	221	215	4745000	#REF!	
69	Ashuganj 450 MW CCGP(North)	APSCCL	1360	360	280	7477000		
70	Ashuganj 450 MW CCGP(South)	APSCCL	1360	360	0	0	Gas shortage	
71	Ashuganj 50 MW Peaking PP	APSCCL	143.968	45	26	598464	Gas shortage	
72	Ashuganj 55 MW PP (Precision)	RPP	154	55	30	1091520	Gas shortage	
73	Ashuganj 195MW PP (APSCCL-UR)	IPP	2079.73+1116	195	8	217454	Gas shortage	
74	Ashuganj 51 MW PP (Midland)	IPP	67.34	51	51	1226843		
75	Ashuganj 150MW PP (Midland)	IPP	237.015	150	150	2862036		
76	Titas 50 MW Peaking PP	PDB	67.92	52	49	588408		
77	Chandpur 150 MW Peaking PP	IPP	1108+1157	163	0	0	Under maint.	
78	Chandpur 200MW (Dash energy)	IPP	1218.4	200	200	3709440		
79	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	21	442548		
80	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	11	204480		
81	** Imoport (Tripura)	Imported power	0	160	166	3619200		
82	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	33	751800		
83	Jangalia 52 MW PP (Midland)	IPP	87.92	52	38	820666	Engine problem	
84	Umitia 25 MW PP (Summit)	SIPP, PDB	318.87+218.97	25	20	4179697	Gas shortage	
85	Daudkandi 200 MW PP (B. Trac)	IPP	154+14	200	100	697536	Low demand.	
86	Feni Lanka Power	IPP	718.415+19.78	114	62	1532160	Engine problem	
87	Chowmuhani 113 MW	IPP	129.78+23.1	113	115	2012640		
88	Bhairob 54.5 MW	IPP	318.2	54	36	888120	33 kV feeder problem.	
89	Chandpur 115(Doreen)	IPP	418.5+222.5	115	101	2126400	Engine problem	
				3074	1712	3691975		
Cumilla Area Total								
90	RPCL 210MW CCGP	IPP	435+1170	202	133	2897850	Gas shortage	
91	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	20	438804		
92	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	8	0	0	Under maint.	
93	Sarishabari 3 MW Solar Plant	IPP	13	3	0	7150		
94	Mymensingh 200 MW PP (Unitec)	IPP	9.78+21	200	170	3902400	Engine problem	
95	Jamalpur 115 MW PP (Unitec)	IPP	9.78+21	115	105	2366000		
96	Sultkhal 50 MW Solar PP	IPP	50	50	0	227640		
97	Tangal Pali Power Gen 22 MW	IPP	46.7	22	10	220080		
				622	438	9832234		
Mymensingh Area Total								
98	Fenchugonj CCGP Phase-1	PDB	232+133	70	0	0	Machine problem	
99	Fenchugonj CCGP Phase-2	PDB	235+135	90	40	950544	Machine problem	
100	Kushaura 163 MW CCGP (KP)	IPP	1109+1154	163	163	3558518		
101	Shajibazar 330 MW Peaking PP	PDB	3110	330	158	5298000	Machine problem	
102	Fenchugonj 51 MW PP (Barakati)	RPP	192.90	51	51	245400	Gas shortage	
103	Fenchugonj 44MW (Energyprima)	RPP	123.3+52	50	3	69480	Gas shortage	
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	222144		
105	Shajibazar GTTP Unit- 8 & 9	PDB	235	66	60	1291392		
106	Shajibazar 96MW PP (Shajibaz)	RPP	322.90	86	84	2024640		
107	Shajibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.	
108	Sylhet 225 MW GTTP	PDB	1142+1189	231	140	4955630	ST tripped at 19.54.	
109	Sylhet 20 MW GTTP	PDB	120	20	0	0	Gas shortage	
110	Sylhet 50MW PP (EPL)	RPP	272	50	27	607200	Gas shortage	
111	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	23	502968		
112	Biliana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	270	7148000	FGMO	
113	Biliana-III 400 MW CCGP	PDB	400	400	371	8924000		
114	Sylhet 10MW PP (Esh)	RPP	81.95	10	10	246780		
115	Biliana South 400 MW	PDB	400	383	394	7148000		
				2477	1764	43190696		
Sylhet Area Total								
116	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.	
117	** Bheramara (HVDC)	Imported power	2500	1000	922	22310545		
118	Khulna 115 MW (KPCL-2)	ORPP	717	115	96	977280	Engine problem	
119	Feni 20 MW Peaking PP	PDB	87.92	54	38	215040	Engine problem	
120	Khulna 225 MW CCGP	NWPGCL	1150+1175	230	200	3557371		
121	Gopalganj 100 MW Peaking PP	PDB	166.98	109	40	282880	Line O/L	
122	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	255	8161056	Gas shortage	
123	Noapara 40 MW PP (Khanjahan A)	ORPP	58.5	40	40	492000		
124	Noapara 100 MW PP (Bangla Tr)	IPP	701.4	100	10	110400	Low demand.	
125	Rupsha 105 MW PP (Orion rupsh)	IPP	618.445	105	105	2154720		
126	Madhumati 100 MW PP	NWPGCL	1141	105	89	1174032	Engine problem	
127	Mongla Orion 100 MW Solar PP	IPP	100	100	0	619200		