

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022			Day : Saturday				Date : 23.04.22				
Probable Maximum Demand :			12000 MW				Probable Maximum Generation : 15004 MW				
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 78.74 ft				Today = 78.28 ft				
			Rule Curve = 83.60 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.04.22 (Yesterday)		23.04.22 (Today)		22.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :				
							Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
Day	Evening	Day	Evening								
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	231	240	240	240		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	270	270	270		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	40	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Harijpur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	253	253	300	320		
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	260	260		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Harijpur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	401	389	400	412		
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	140	150	150	195	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55		
15	Gaganpur 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	7	84	85		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	0	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.7+1x7.73	80	80	53	54	55	55		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	0	33	33		
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	25	52	52		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	105	105		
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	132	132		
23	Kamaighat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	60	45	280	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	26	17	149	149		
26	Karangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300		
27	Branganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	17	55	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	44	17	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	104	104		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	95	22	144	144		
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0		
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	35	0	55	55		
35	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	16	100	100		
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	80	27	90	90		
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	78	75	80	80		
Dhaka Zone Total			6055	5898	2486	2150	3987	4010	740	590	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	55	53	60	60	177	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
43	Telraaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	7	12	35	37		
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	34	105	105	105		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	203	215	215		
48	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+3x8.94	300	300	270	283	300	300		
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	42	50	51		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg.EPZ (Uniled)	Gas	5x8.73+3x9.34			2	39	10	30		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	59	43	95	95		
54	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	97	110	110	110		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	35	21	100	100		
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	51	37	113	113		
Chattogram Zone Total			2342	2282	1009	1190	1460	1458	357	330	
58	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	27	28	30	30		
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	206	223	225	225		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	235	180	330	330	180	Gas Shortage
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	55	55	55		
64	Ashuganj 198MW PP (APSCCL-Uniled)	Gas (IPP)	20'9.73+1'16	195	195	26	8	8	8	187	Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	27	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	10	150	150		
67	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50		
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	88	90	90	92		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	90	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	0	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	9	20	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.401+01x.015+19x1.058	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	17	75	81		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	39	25	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	36	35	36		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	17	101	101		
**	Impport (Tripura)	India		160	160	122	126	143	166		
Cumilla Zone Total			3059	3014	978	982	1885	2018	630	0	
80	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	81	104	110	120	98	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		
83	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	55	115	115	115		
84	Mymensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	40	70	190	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	3	0	50	0	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	24	22	22		
Mymensingh Zone Total			717	622	221	333	509	477	98	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.04.22 (Yesterday)		23.04.22 (Today)		22.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	0	0	0	0				
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	41	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	130	163	163	163				
92	Hobgonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	6	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	60	60	60				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	142	168	160	160	162		Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142-1x89	231	231	218	164	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	265	300	310	330				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	364	365	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	380	360	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total					2522	2477	1680	1714	1846	1867	282	148	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	185	195	300	300	215		Gas Shortage	
108	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	38				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	40	0	200	200				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	10	76	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	105	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	59	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	80	94				
116	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	32	32				
**	Bheramara (HVDC)	India		1000	1000	922	922	936	936				
Khulna Zone Total					2388	2384	1223	1127	1959	1979	215	0	
117	Barsail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	16	50	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	5	33	37				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	92	90	90				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	280	620	620				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
122	Bhola 220MW CAPP (Nutan Bidyt Bl)	Gas/HSD (IPP)	2x75+1x70	220	220	216	162	220	220				
Barishal Zone Total					1958	1958	738	555	1163	1227	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	100			Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	36	43				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	70	92	93				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40				
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	38				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	133	162	150	170				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	414	400	410				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
136	Lillapera 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
137	Natore 52 MW PP (Rajarjika)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	50	90	90				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	39	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total					2129	2129	617	899	1196	1346	611	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	80	76	80				
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	53	110	110				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
146	Majpara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
147	Thakurgaon 119MW PP (Energyac)	HFO (IPP)	6*20	115	115	0	34	115	115				
Rangpur Zone Total					800	720	311	367	509	532	0	85	
Sub-total: Plants in operation					21970	21484	9263.0	9317	14514	14914	2933	1153	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8853	8904	13947	14339			
(B) Plants under long term maintenance/ contract expired													
148	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
150	Juddha 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	0	0	0	80	90				
151	Bogra 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					378	0	0	0	80	90			
Gross Total					22348	21484	9263	9317	14594	15004	2933	1153	
(C) Actual data of 22.04.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 9317 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 8904 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 12096 MW, at = 1:00 hrs											
04.	Minimum Generation (Generation end)	: 8612 MW, at = 8:00 hrs	Dhaka	3419	3419	0				Mymensingh	750	750	
05.	Day-peak Generation (Generation end)	: 9263 MW, at = 12:00 hrs	Chattogram	1076	1076	0				Sylhet	443	443	
06.	Evening-peak Generation (Generation end)	: 9317 MW, at = 21:00 hrs	Khulna	810	810	0				Barishal	125	125	
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs	Rajshahi	959	959	0				Rangpur	649	649	
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7281 MW, at = 5:00 hrs	Cumilla	674	674	0						0	
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2756 MW											
d)	Coal supply Limitation	: 0 MW											
b)	Low water level in Kaptai lake	: 177 MW											
c)	Plants under shut down/ maintenance	: 1153 MW											
10.	Total Energy (Generation + India Import)	: 231.22 MKWh											
	By Gas = 131.506 MKWh	By Oil = 54.851 MKWh											
	By Coal = 17.321 MKWh	By Hydro = 1.310 MKWh											
	By Solar = 0.883 MKWh												
11.	Total Gas Supplied	: 979.60 MMCFD											
(D) Forecast of 23.04.22 (Today) Saturday :													
01.	Maximum Demand	: 12000 MW (Generation end)											
02.	Maximum Generation	: 15004 MW (Generation end)											
03.	Reserve / Shortage	: 3004 MW (Generation end)											
04.	Maximum Load-shed	: 0 MW (Sub-station end)											
05.	Total Generation	: 229.39 MKWh											
06.	Probable Max. Temperature in Dhaka	: 38.8° C											

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation