

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 10-May-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCPP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1210	180	0	0	
3	Ghorasal TPP Unit-5	PDB	1210	190	170	4158000	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	0	Gas shortage
5	Ghorasal 78.5 MW PP(MAX)	ORPP	240	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	101	2121227	
7	Harijpur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Harijpur 412 MW CCPP	EGCB	1273+1139	412	388	9244680	Gas shortage
9	Harijpur 350MW CCPP(HPL)	IPP	1235+1125	360	332	7622000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	225	5221750	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	100	93	2047680	
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	115	3080495	Gas shortage & FGMO
13	Madanganj 102 PP(Summit)	ORPP	6*17	102	48	605304	Engine problem
14	Madanganj-55 MW PP(Summit)	ORPP	3*17.08+1*11.3	55	55	1062308	
15	Karanganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	285588	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	100	1492800	
20	Siddhirgonj 335 MW CCPP	EGCB	1217+118	335	300	7639140	
21	Sagaura 102 MW PP (Digital Po)	IPP	12*8.924	102	48	501552	Low Demand
22	Katobli 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1082160	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	32	654240	Transformer O/L
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	562976	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	547980	Engine problem
27	Bosila 108MW RPCL	IPP	12*9.15+13.5	0	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	50	1083840	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	524160	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	683700	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	51	624960	#REF!
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW Unit-2 (Summit)	IPP	18*17.076	300	105	742691	Low Demand
34	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
35	Bramhangonj 100 MW PP (Aggr)	IPP	114*0.959	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	149	2101680	
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2209200	
39	Meghnaghat 104 MW PP (QPCL)	IPP	18*5.6	104	104	1829760	
40	Manikganj 162MW (MPL)	IPP	9*18	162	126	2730240	Low Demand
41	Spectra Solar Plant Ltd.	IPP	35	35	0	0	
42	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	977040	
Dhaka Area Total				5898	2976	61437151	
43	Chattogram TPP-1	PDB	1210	180	100	2300000	Gas shortage
44	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Razzan 25 MW PP	RPCL	2*9.29	25	16	75544	Transformer O/L
46	Teknaf 20MW PP (SolarTech/Teknaf SolarTech Energ	IPP	20	20	0	57510	
47	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	37	816480	33 kV feeder problem.
48	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	30	705480	Low water level.
49	Sikalbaha 225MW	PDB	1*150+1*175	225	202	4881305	
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka St)	IPP	6*17.5	105	68	1853452	High voltage
52	Hathazari 100 MW Peaking PP	PDB	11*9.9	99	51	212600	Engine problem
53	Dokhazari-Kalaish 100 MW Peakin	PDB	6*17	102	51	222376	Fuel shortage
54	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	0	40	513120	
55	Juddah 100 MW Unit-3 (Acorn)	IPP	8*13.5	100	75	861120	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	522288	
57	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	35	427200	
58	Chattogram 108 MW PP (ECPV)	IPP	18*5.74	108	97	1800000	Engine problem
59	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	16680	
60	Anwara 300 MW PP (United)	IPP	17*17+24	300	283	5728255	Engine problem
61	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1279460	
62	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	88	2121845	Engine problem
63	Juddah unit-2 (Acorn)	IPP	8*13.6	100	83	1099200	
64	Anilma Energy Ltd.	IPP	6*21.2	116	99	2200473	Engine problem
Chattogram Area Total				2282	1431	27784418	
65	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCCL	1*150	129	0	0	Gas shortage
67	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
68	Ashuganj 225 MW CCPP	APSCCL	1*142+1*175	221	192	4367000	#REF!
69	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	270	7055800	Gas shortage
70	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	360	0	0	Gas shortage
71	Ashuganj 50 MW PP	APSCCL	14*3.968	45	31	652032	Gas shortage
72	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	319200	Gas shortage
73	Ashuganj 195MW PP (APSCCL-UR)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1213770	
75	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	2064145	
76	Titas 50 MW Peaking PP	PDB	6*8.92	52	33	72272	Low Demand
77	Chandpur 150 MW Peaking PP	PDB	1*108+1*157	163	135	3239550	
78	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	51	364800	Low Demand
79	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	422892	
80	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	145440	Engine problem
81	Import (Tripura)	Imported power	0	160	112	2380800	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	8	367900	Engine problem
83	Jangalia 52 MW PP (Ladmanav)	IPP	8*6.92	52	43	511402	Engine problem
84	Umitia 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*9.29	25	20	467880	Reserve.
85	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	
86	Feni Lanka Power	IPP	7*18.415+1*9.78	114	70	353600	Low Demand
87	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	114	1880760	
88	Bhairab 54.5 MW	IPP	3*18.2	54	17	563400	33 kV feeder problem.
89	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	17	104840	Low Demand
Cumilla Area Total				3074	1354	26936737	
90	RPCL 210MW CCPP	IPP	4*35+1*70	202	107	3001820	Gas shortage
91	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	382752	Engine problem
92	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
93	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8500	
94	Mymensingh 200 MW PP (Unitec)	IPP	9.78*21	200	129	1864800	Low Demand
95	Ashuganj 115 MW PP (Unitec)	IPP	9.78*12	115	100	2325600	Engine problem
96	Suitkhal 50 MW Solar PP	IPP	50	50	0	89840	
97	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	24	581520	
Mymensingh Area Total				622	380	8259032	
98	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	30	646000	Machine problem
99	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	959008	Machine problem
100	Kushara 163 MW CCPP (KP)	IPP	1*109+1*154	163	163	3652609	
101	Shahbazar 330 MW CC (Barakat)	PDB	3*110	330	267	5032000	
102	Fenchugonj 51 MW PP (Energyprima)	RPP	19*2.90	51	22	1038600	
103	Fenchugonj 44MW (Energyprima)	RPP	12*3.5+5*2	50	50	1049760	
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	230832	
105	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	60	1341888	
106	Shahbazar 96MW PP (Shahbaz)	RPP	32*2.90	86	0	1347840	Under S/D
107	Shahbazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	219	5076290	
109	Sylhet 20 MW GTTP	PDB	1*20	20	19	444000	
110	Sylhet 50MW PP (EPL)	RPP	27*2	50	39	891360	
111	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	349920	Engine problem
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
113	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	241	6279000	Gas shortage
114	Sylhet 10MW PP (Dash)	RPP	8*1.95	10	10	257040	
115	Bibiyana South 400 MW	PDB	400 MW	383	400	9161300	
Sylhet Area Total				2477	1589	37751147	
116	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
117	Bheramara (HVDC)	Imported power	2*500	1000	898	21885818	
118	Khulna 115 MW PP (KPCL-2)	ORPP	7*17	115	94	1667520	Fuel shortage
119	Farijpur 50 MW Peaking PP	PDB	8*6.89	50	0	0	Reserve.
120	Khulna 225 MW CCPP	NWPGCL	1*150+1*175	230	0	0	Reserve.
121	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
122	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	210	4709376	Gas shortage
123	Noapara 40 MW PP (Khanjahan A)	ORPP	5*8.5	40	0	25875	Reserve.
124	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	0	0	Reserve.
125	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	0	0	Reserve.
126	Madhumati 100 MW PP	NWPGCL	6*18	105	50	428256	Low Demand
127	Mongla Orion 100 MW Solar PP	IPP	100	100	0	478540	
Khulna Area Total				2384	1252	29193485	
128	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	32	522336	Line O/L
129	Bhola 33 MW PP (Venture)	RPP	1*34.50	40	34	607138	Engine problem
130	Bhola 225 MW CCPP	PDB	2*63+1*68	194	52	1425340	Gas shortage
131	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	0	0	0	Contract Expired
132	Payra 1320 MW PP	BPCL	2*622	1244	840	1979800	Line O/L
133	Bhola Nutan Bidut BD LTD	IPP	220	220	121	3566673	Line O/L
134	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				1958	1079	25912287	
135	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
136	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
137	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve.
138	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Contract Expired
139	Amnura 50 MW PP(Sinha)	ORPP	7*7.79	0	0	0	Contract Expired
140	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	50	217447	
141	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	24	71229	Low Demand
142	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
143	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	
144	Sirajgonj Unit-3 225MW	NWPGCL	1*141	230	129	3420355	Gas shortage
145	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	416	8550400	
146	Santahar 50 MW Peaking PP	PDB	6*8.7	50	31	120627	Engine problem
147	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	491520	
148	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	
149	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	123842	
150	Natore 52 MW PP (Baraka)	IPP	8*6.92	52	52	613980	
151	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	54	187656	Low Demand
152	Baghabari 200 MW PP (Paramou)	IPP	135*1.6	200	0		