

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 11-May-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1210	180	0	0	
3	Ghorasal TPP Unit-5	PDB	1210	190	170	4126500	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	65	341400	Gas shortage
5	Ghorasal 78.5 MW PPI(MAX)	QRPP	240	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	90	2085682	Engine problem
7	Hairipur GTTP	SBU, PDB	232	20	0	0	Under maint.
8	Hairipur 412 MW CCPP	EGCB	1273+1139	412	407	9226240	
9	Hairipur 360MW CCPP(HPL)	IPP	1236+1125	360	338	7510000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150	450	225	5169250	Gas shortage
11	Meghnaghat 100 MW(EL)	QRPP	128.9	100	93	1882560	Engine problem
12	Meghnaghat CCPP(Summit)	IPP	2110+1110	335	120	3105920	Gas shortage & FGMO
13	Madanganj 102 PP(Summit)	QRPP	617	102	100	1180968	
14	Madanganj-55 MW PP(Summit)	(IPP)	317.06+111.3	55	15	434497	Low Demand
15	Karanagaj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	19	397476	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	128.9	100	40	359040	Low Demand
20	Siddhirgonj 335 MW CCPP	EGCB	1217+118	335	335	7662349	
21	Chattogram 102 MW PP (Digital Power)	IPP	128.924	102	40	495936	Low Demand
22	Kalipothi 52 MW PP (Sinha)	IPP	77.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318	54	54	920880	
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	100	395520	Low Demand
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	17	503159	Low Demand
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	55	873604	
27	Bostia 108MW RPCL	IPP	128.9+113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	313.67+418.73	80	43	1102380	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	48.73	33	25	560880	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	48.73	33	33	713500	
31	Gazipur 52 MW PP	RPCL	68.9	52	50	516960	
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	145	1711199	Low Demand
34	Karanagaj 300 MW PP (APR)	IPP	2561.4	300	0	0	Reserve.
35	Bramhangonj 100 MW PP (Aggreko)	IPP	1140.959	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	88	1854000	Low Demand
38	Gazipur 100 MW PP	RPCL	617.5	105	105	1767600	
39	Meghnaghat 100 MW PP (OPCL)	IPP	16.376	104	104	1491840	
40	Manikganj 162MW PP(MRCL)	IPP	91.16	162	162	2691360	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	0	
42	Kanchan Furibachal Power Generation Ltd.	IPP	18.43	55	55	1117440	
Dhaka area Total				5898	3093	60198140	
43	Chattoogram TPP-1	PDB	1210	180	100	2400000	Gas shortage
44	Chattoogram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raizhan 25 MW PP	RPCL	378.9	25	8	64101	Low Demand
46	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	59285	
47	Patenga 50MW PP (Baraka)	IPP	86.98	50	40	846240	33 kV feeder problem.
48	Kapali Hydro Unit-1,2,3,4, 5	PDB	240+350	230	30	716000	Low water level
49	Sikalbaha 225MW	PDB	1150+1175	225	203	4906338	
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	105	1766392	
52	Hathazari 100 MW Peaking PP	PDB	1119.9	98	0	0	Reserve.
53	Dhazari-Kalash 100 MW Peaking	PDB	617	102	34	130272	Fuel shortage
54	Juldah 100 MW Unit-1 (Acorn)	QRPP	813.45	0	30	548760	
55	Juldah 100 MW PP Unit-3 (Acorn)	IPP	813.5	100	76	1171200	Engine problem
56	Barakunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	22	469920	
57	Malancha Cig. EPZ (United)	IPP	587.3+39.34	0	19	485280	
58	Chattoogram 108 MW PP (ECPV)	IPP	1617	108	89	1454960	Engine problem
59	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	24961	
60	Anwara 300 MW PP (United)	IPP	1717+24	300	300	6410727	
61	Jodiad Power	IPP	318.55+13.6	54	54	1367768	
62	Karnaphuli Power Ltd.	IPP	18.415+6.5	110	106	2508244	
63	Juldah unit-2 (Acorn)	IPP	813.6	100	100	1217280	
64	Anlima Energy Ltd.	IPP	621.2	116	109	2450127	
Chattoogram area Total				2282	1425	2907835	
65	Ashuganj TPP Unit- 3	APSCCL	1150	0	0	0	Contract Expired
66	Ashuganj TPP Unit- 4	APSCCL	1150	129	0	0	Gas shortage
67	Ashuganj TPP Unit- 5	APSCCL	1150	134	0	0	Gas shortage
68	Ashuganj 225 MW CCPP	APSCCL	1142+1175	221	168	4611000	#REF!
69	Ashuganj 450 MW CCPP(North)	APSCCL	1360	360	280	7057000	Gas shortage
70	Ashuganj 450 MW CCPP(South)	APSCCL	1360	360	0	0	Gas shortage
71	Ashuganj 50 MW PP	APSCCL	143.968	45	31	576000	Gas shortage
72	Ashuganj 55 MW PP (Precision)	RPP	154	55	0	0	Gas shortage
73	Ashuganj 195MW PP (APSCCL-United)	IPP	209.73+1116	195	8	217454	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	1196607	
75	Ashuganj 150MW PP (Midland)	IPP	237.015	150	150	2162836	
76	Titas 50 MW Peaking PP	PDB	68.92	52	0	18872	Reserve.
77	Chandpur 150 MW CCPP	PDB	1106+157	153	135	3199950	
78	Chandpur 200MW (Desh energy)	IPP	1218.4	200	85	845760	Low Demand
79	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	19	425412	
80	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	8	142380	Engine problem
81	Impoprt (Tripura)	Imported power	0	160	108	2438400	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	21	460100	Engine problem
83	Jangalia 52 MW PP (Lakdhanvi)	IPP	918.92	52	25	779622	Engine problem
84	Cumilla 25 MW PP (Summit)	SIPP, PDB	313.67+216.97	25	21	468810	
85	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	0	0	Reserve.
86	Feni Lanka Power	IPP	718.415+19.78	114	52	954180	Low Demand
87	Chowmuhani 113 MW	IPP	129.78+23.1	113	107	1848840	
88	Bharob 54.5 MW	IPP	318.2	54	17	436320	33 kV feeder problem.
89	Chandpur 115(Doreen)	IPP	418.5+222.5	115	8	107520	Low Demand
Cumilla Area Total				3914	1284	2746163	
90	RPCL 210MW CCPP	IPP	435+1170	202	108	2774400	Gas shortage
91	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	20	430128	
92	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	8	0	0	Under maint.
93	Sarishabari 3 MW Solar Plant	IPP	13	3	0	11150	
94	Mymensingh 200 MW PP (United)	IPP	978.21	200	140	2138400	Low Demand
95	Jamalpur 115 MW PP (United)	IPP	978.12	115	97	2476800	Engine problem
96	Sutakathi 50 MW Solar PP	IPP	50	50	0	262080	
97	Tangal Pali Power Gen 22 MW	IPP	46.7	22	24	499920	
Mymensingh Area Total				622	389	8592878	
98	Fenchugonj CCPP Phase-1	PDB	232+133	70	43	789000	Machine problem
99	Fenchugonj CCPP Phase-2	PDB	235+135	90	42	974216	Machine problem
100	Kushara 163 MW CCPP (KP)	IPP	1109+154	163	110	3575455	Frequency control
101	Shahjibazar 330 MW CCPP	PDB	3110	330	265	5411000	
102	Fenchugonj 51 MW PP (Barakatalah)	RPP	192.90	51	53	1143000	
103	Fenchugonj 44MW (Energyprima)	RPP	1213.3+52	50	50	1167552	
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	236988	
105	Shahjibazar GTTP Unit- 8 & 9	PDB	235	66	40	1343232	Gas shortage
106	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	78	1706880	
107	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
108	Sylhet 225 MW CCPP	PDB	1142+1199	231	219	5158170	
109	Sylhet 20 MW GTTP	PDB	120	20	19	432000	
110	Sylhet 50MW PP (EPL)	RPP	272	50	31	848140	
111	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	13	356976	Engine problem
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1222+1119	341	260	2303500	FGMO
113	Bibiyana-III 400 MW CCPP	IPP	400 MW	400	329	6481000	Gas shortage
114	Sylhet 10MW PP (Dash)	RPP	61.95	10	10	252180	
115	Bibiyana South 400 MW	PDB	400 MW	383	180	4856600	Gas shortage
Sylhet Area Total				2477	1753	37035889	
116	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
117	Bheramara (HVDC)	Imported power	2500	1000	895	21561454	
118	Khulna 115 PP MW (KPCL-2)	QRPP	717	115	70	806400	Fuel shortage
119	Falipur 50 MW Peaking PP	PDB	96.89	54	0	0	Reserve.
120	Khulna 225 MW CCPP	NWPGCL	1150+1175	230	0	0	Reserve.
121	Gopalganj 100 MW Peaking PP	PDB	1616.98	109	0	0	Reserve.
122	Bheramara 410 MW CCPP	NWPGCL	1278+1132	410	260	6013440	Gas shortage
123	Noapara 40 MW PP (Khanjahan Ali)	QRPP	58.5	40	0	50250	Reserve.
124	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	0	Reserve.
125	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	35	575520	Low Demand
126	Madhumati 100 MW PP	NWPGCL	618	105	15	684664	Low Demand
127	Mongla Orion 100 MW Solar PP	IPP	100	100	0	475200	
Khulna Area Total				2384	1275	30167128	
128	Barisal 110 MW PP (Summit)	IPP	717.076	110	16	485088	Line O/L
129	Bhola 33 MW PP (Venture)	RPP	134.50	40	30	562445	Engine problem
130	Bhola 225 MW CCPP	PDB	2163+1168	194	38	1339000	Gas shortage
131	Bhola 95 MW PP (Aggreko)	QRPP	961.10	0	0	0	Contract Expired
132	Payra 1320 MW CCPP	BCPCL	2262	700	124	19846200	Line O/L
133	Bhola Nutan Bidout BD LTD	IPP	220	220	192	4610455	Line O/L
134	United Payra Power Ltd.	IPP	818.5+19.5	150	17	50400	Line O/L
Barisal Area Total				1958	993	26893588	
135	Baghabari 71 MW GTTP	PDB	171	71	0	0	Gas shortage
136	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage
137	Baghabari 50 MW Peaking PP	PDB	68.9	52	0	34366	Reserve.
138	Bera 70 MW Peaking PP	PDB	98.29	71	0	0	Reserve.
139	Amnura 50 MW PP(Sinha)	QRPP	77.79	0	0	0	Contract Expired
140	Katakhal 50 MW PP (Northern)	QRPP	68.9	50	16	20552	Low Demand
141	Katakhal 50 MW Peaking PP	PDB	68.7	50	0	14534	Reserve.
142	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	0	0	Gas shortage
143	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	0	0	Gas shortage
144	Sirajgonj Unit-3 225MW	NWPGCL	1141	164	378	3672845	Gas shortage
145	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1282+1132	414	378	9037745	Gas shortage
146	Santahar 50 MW Peaking PP	PDB	68.7	50	25	31844	Low Demand
147	Bogra 22 MW PP (GBB)	RPP	64	22	22	504240	
148	Bogra 20 MW PP (Energyprima)	RPP	53.3+52	0	0	0	
149	Ullapara 11 MW PP (Summit)	SIPP, REB	42.90	11	11	162288	
150	Native 52 MW PP (Baraka)	IPP	918.92	52	52	513437	
151	Chapainawabganj 100 MW Peaking PP	IPP	128.924	104	93	208944	Engine problem
152	Baghabari 200 MW PP (Paramount)	IPP	1351.6	200	0	0	Reserve.
153	Bagura 113 MW PP (Confidence)-2	IPP	618.55+7.2	113	90	2269824	