

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month May, 2022		Day : Sunday				Date : 15.05.22						
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :		15420 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 74.17 ft		Today = 74.12 ft		Rule Curve = 79.34 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.05.22 (Yesterday)		15.05.22 (Today)		Gen. shortfall for : Gas/Water/Coal limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	270	270	270			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	96	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Hanpur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Hanpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	282	334	300	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	352	395	360	400			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		110	Under maint.
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	324	334	335	335			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	125	125	150	210		Gas Shortage
14	Madanganj-35 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	84	93	93			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	52	53	54	54			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	49	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	100	105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	133	132	132			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	240	290	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	88	149	149	149			
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	53	300	300			
27	Bramanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	78	100	100			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	60	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	109	162	162	162			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbaachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	94	100	100			
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	82	90	95	95			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	43	95	96	96			
Dhaka Zone Total				6055	5898	2958	3892	4194	4274	435	770	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30		200	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	49	49	49	49			
45	Sikalbaha 105 MW PP (Baraka Sikalab)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	203	205	205			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	245	281	300	300			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	38	76	90	90			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	51	51			
52	Barakbunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
*	Matancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			3	13	15	25			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	82	93	96	96			
54	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	110	106	110			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	38	100	100	100			
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	0	40	80	80	80			
58	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	99	77	110	110			
Chattogram Zone Total				2442	2282	1102	1420	1514	1503	380	330	
59	a) Ashuganj TPP Unit- 4	Gas (APSCS)	1 x 150	150	129	0	0	0	0		129	Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCS)	1 x 150	150	134	0	0	0	0		134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCS)	14x3.968	53	45	32	30	35	35			
61	Ashuganj 225 MW CCPP	Gas (APSCS)	1x142+17x5	221	221	185	196	210	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCS)	1x360	360	0	0	0	0	360			Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCS)	1x361	360	360	280	280	280	280	80		Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	55			Gas Shortage
65	Ashuganj 195MW PP (APSCS-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	132	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	41	41			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	134	135	135			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	190	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	34	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	21	21			
76	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	96x1.4+6x1.01+15x1.09	200	200	0	20	200	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	100	100	100			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	32	105	113	113			
79	Bharoto 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	82	100	100			
**	Impoprt (Tripura)	India		160	160	116	120	143	166			
Cumilla Zone Total				3059	3014	1045	1617	1931	1969	945	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	104	96	120	150	106		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	106	115	115			
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	40	181	200	200			
86	Sarishaban 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
87	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	12	0	50	0			
88	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total												

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.05.22 (Yesterday)		15.05.22 (Today)		14.05.22 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22+1x33	97	70	44	44	44	44				
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatalullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	30	60	60				
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	253	269	270	270	61		Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x29.00	86	86	72	75	80	80				
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	219	219	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	8	8				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	285	300	341				
102	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Filter change	
103	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	381	400	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	36	39	38	41				
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	48	50	50	50				
Sylhet Zone Total					2522	2477	1661	1697	1746	1790	61	549	
107	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	205	200	250	300	210		Gas Shortage	
109	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	21	35	35				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	50	0	60				
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	200	200				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105				
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	105	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	35	0	100	0				
116	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	28	99	16	99				
117	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	32	32				
**	Bheramara (HVDC)	India		1000	1000	924	915	927	927				
Khulna Zone Total					2388	2384	1209	1527	1870	1963	210	0	
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	30	30	30				
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	80	86	87	87				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	850	800	1000				
122	Potukhalai 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
123	Bhola 220MW CAPP (Nutan Bidyut Bf)	Gas/HSD (IPP)	2x75+1x70	220	220	170	216	220	220				
Barishal Zone Total					1958	1958	951	1215	1204	1597	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100			Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	36	40				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	30	30				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	85	85	85				
129	Katakhat 50 MW Peaking PP	HFO (PDB)	6x8.9	50	50	0	40	40	40				
130	Katakhat 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	37	38				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	139	147	225	225	73		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	393	416	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	52	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total					2129	2129	710	1104	1420	1419	674	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175				
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	52	108	108	108				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Wajpara, Tutula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	115	115				
Rangpur Zone Total					800	720	232	398	406	398	85	85	
Sub-total: Plants in operation					22070	21484	10184.0	13297	14814	15420	2896	1734	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9899	12925	14400	14989			
(B) Plants under long term maintenance/ contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forecast Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Annura 50 MW PP(Sirsha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					278	0	0	0	0	0	0	0	
Gross Total					22348	21484	10184	13297	14814	15420	2896	1734	

(C) Actual data of 14.05.22 (Yesterday) Saturday :												
					Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
Sl. No.	Description	Value	Unit	Time	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
01.	Max. Demand at eve. peak (Generation end)	13297	MW	at = 19:30 hrs								
02.	Max. Demand at eve. peak (Sub-station end)	12925	MW	at = 19:30 hrs								
03.	Highest Generation (Generation end)	13297	MW	at = 19:30 hrs								
04.	Minimum Generation (Generation end)	8841	MW	at = 7:00 hrs	Dhaka	4713	4713	0	Mymensingh	1012	1012	0
05.	Day-peak Generation (Generation end)	10184	MW	at = 12:00 hrs	Chattoagram	1432	1432	0	Sylhet	452	452	0
06.	Evening-peak Generation (Generation end)	13297	MW	at = 19:30 hrs	Khulna	1587	1587	0	Barishal	392	392	0
07.	Evening Peak Load-shed (Sub-station end)	0	MW	at = 19:30 hrs	Rajshahi	1330	1330	0	Rangpur	783	783	0
08.	Minimum Generation Forecast up to 8:00 hrs.	9536	MW	at = 5:00 hrs	Cumilla	1224	1224	0				
09.	Generation shortfall at evening peak due to :								Total	12925	12925	0
a)	Gas limitation	2611	MW		13.	Fuel cost :	(a) Gas = 145699307 Taka	(c) Coal = 114267927 Taka				
d)	Coal supply Limitation	85	MW			(b) Oil = 490448568 Taka	Total = 750415802 Taka					
b)	Low water level in Kaplai lake	200	MW									
c)	Plants under shut down/ maintenance	1734	MW		14.	Maximum Temperature in Dhaka was :	33.9° C					
10.	Total Energy (Generation + India Import)	260.84	MKWh		15.	Export through East-West interconnections :						
	By Gas = 143.003 MKWh		By Oil = 66.498 MKWh			At evening peak-hour	: 10184 MW, at 19:30 hrs					
	By Coal = 25.026 MKWh		By Hydro = 0.728 MKWh			Maximum	: -52 MW, at 19:30 hrs					
	By Solar= 0.895 MKWh					Energy	: 0.043 MKWh					
11.	Total Gas Supplied	1049.30	MMCFD									
(D) Forecast of 15.05.22 (Today) Sunday :												
01.	Maximum Demand	13500	MW	(Generation end)	04.	Maximum Load-shed	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	15420	MW	(Generation end)	05.	Total Generation	264.82	MKWh				
03.	Reserve / Shortage	1920	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	38.2° C					

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation