

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 16-May-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	170	4205250	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	250	6082545	
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	95	2250863	
7	Hariapur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Hariapur 412 MW CCGP	EGCB	1273+1139	412	280	7469780	Gas shortage
9	Hariapur 350MW CCGP(HPL)	IPP	1235+1125	360	223	6350000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	225	5075100	GT-2 S/D, Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	100	92	2133120	Engine problem
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	335	125	3144727	Gas shortage & FGMO
13	Madanganj 102 PP(Summit)	ORPP	6*17	102	95	1919808	Engine problem
14	Madanganj-55 MW PP(Summit)	ORPP	3*17.08+1*11.3	55	55	1230869	
15	Karanganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.80	22	22	445140	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	GT-2 U/M & Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	85	1680000	Engine problem
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	333	7768967	Engine problem
21	Sagarjag 102 MW PP (Digital Po)	IPP	12*8.924	102	84	1554336	Gas shortage
22	Katobli 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1008360	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	2873280	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1171123	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1191184	
27	Basia 108MW RPCL	IPP	12*8.9	108	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	52	1143420	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	617300	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	639700	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	48	1070400	#REF!
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Koida 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	275	5626871	
34	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	302	1576071	
35	Bramhangonj 100 MW PP (Aggr)	IPP	114*0.959	100	100	810264	
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	750864	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	149	3338208	
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2463600	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	2426880	
40	Manikganj 162MW MPGL	IPP	9*18	162	162	3826960	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	0	
42	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	1194480	
Dhaka area Total				5898	3940	8307070	
43	Chattoogram TPP-1	PDB	1*210	180	0	0	Gas shortage
44	Chattoogram TPP-2	PDB	1*210	180	0	0	Gas shortage
45	Razzan 25 MW PP	RPCL	3*8.9	25	25	349228	
46	Taksonal 20MW PP (SolarTechTecnaf SolarTech Energ	IPP	20	20	0	132840	
47	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	1150080	
48	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	0	739640	Low water level
49	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4881783	
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka St)	IPP	6*17.5	105	105	2263199	
52	Hathazari 100 MW Peaking PP	IPP	11*9.9	98	60	423336	Engine problem
53	Dohazari-Kalaish 100 MW Peaking	PDB	6*17	102	51	338339	Fuel shortage
54	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	45	578160	Engine problem
55	Juddah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	83	1212480	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	531888	
57	Malancha Ctg. EP2 (Unilted)	IPP	5*8.73+3*9.34	0	16	454560	
58	Chattoogram 108 MW PP (ECPV)	IPP	18*5.7	108	94	1937520	Engine problem
59	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	32844	
60	Anwara 300 MW PP (Unilted)	IPP	17*17+24	300	282	6485509	Engine problem
61	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1078349	
62	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2596061	Engine problem
63	Juddah unit-2 (Acorn)	IPP	8*13.6	100	91	1233600	
64	Anilma Energy Ltd.	IPP	6*21.2	116	97	2324673	Engine problem
Chattoogram area Total				2382	1388	2871969	
65	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCCL	1*150	129	0	0	Gas shortage
67	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
68	Ashuganj 225 MW CCGP	APSCCL	1*142+1*75	221	183	4489000	#REF!
69	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	275	6974900	Gas shortage
70	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	0	0	Gas shortage
71	Ashuganj 50 MW CCGP	APSCCL	14*3.968	45	32	716640	Gas shortage
72	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	36000	Gas shortage
73	Ashuganj 195MW PP (APSCCL-UR)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	969742	
75	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	134	2798472	Engine problem
76	Titas 50 MW Peaking PP	PDB	6*8.92	52	18	442280	
77	Chandpur 150 MW Peaking PP	IPP	1*108+1*57	163	90	2154840	
78	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	200	4085760	Machine problem
79	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	436248	
80	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	171540	Engine problem
81	Import (Tripura)	Imported power	0	160	128	2917440	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	32	746300	
83	Jangalia 52 MW PP (Midanwil)	IPP	8*6.92	52	42	939467	Engine problem
84	Qumilia 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*8.97	25	20	472550	Engine problem
85	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	200	742272	
86	Feni Lanka Power	IPP	7*18.415+1*9.78	114	110	2384880	
87	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	9	224280	lube oil shortage.
88	Bhairab 54.5 MW	IPP	3*18.2	54	35	747000	33 kV feeder problem.
89	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	64	1217280	Engine problem
Cumilla Area Total				3074	1652	3383855	
90	RPCL 210MW CCGP	IPP	4*35+1*70	202	68	2170560	Gas shortage
91	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.80	22	20	391140	
92	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
93	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	9550	
94	Mymensingh 200 MW PP (Unilted)	IPP	9*78*21	200	166	3804000	Engine problem
95	Jamalpur 115 MW PP (Unilted)	IPP	9*78*21	115	105	2413200	Engine problem
96	Sultakhal 50 MW Solar PP	IPP	50	0	0	2403330	
97	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	24	513600	
Mymensingh Area Total				622	413	9542380	
98	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	44	1035000	Machine problem
99	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	30	688856	Machine problem
100	Kushara 163 MW CCGP (KP)	IPP	1*108+1*54	163	163	3658254	
101	Shahjibazar 330 MW PP	PDB	3*110	330	0	0	Gas shortage
102	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	0	465000	Gas shortage
103	Fenchugonj 44MW (Energyprima)	RPP	12*3.5+5*2	50	50	1031256	Gas shortage
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	255800	
105	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	50	856512	
106	Shahjibazar 96MW PP (Shahjibaz)	RPP	32*2.90	86	75	1767360	
107	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
108	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	220	5242790	
109	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	
110	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	460420	gas shortage
111	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	11	231648	
112	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	305	7046000	FGMO
113	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	280	6625000	
114	Sylhet 10MW PP (Eesh)	RPP	8*1.95	10	10	233100	
115	Bibiyana South 400 MW	PDB	400 MW	383	400	9283400	
Sylhet Area Total				2477	1649	3888139	
116	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
117	Bheramara (HVDC)	Imported power	2*500	1000	923	22312000	
118	Khulna 115 MW PP (KPCL-2)	ORPP	7*17	115	80	739200	Engine problem
119	Fariapur 250 MW Peaking PP	PDB	8*6.88	54	44	223200	Engine problem
120	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve.
121	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	65	385408	Engine problem
122	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	320	7500096	
123	Noapara 40 MW PP (Khanjahan A)	ORPP	5*8.5	40	32	97125	Engine problem
124	Noapara 100 MW PP (Bangla Tre)	IPP	70*1.4	100	100	306240	
125	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	105	2088800	
126	Madhumati 100 MW PP	NWPGCL	6*18	105	105	1640304	
127	Mongla Orion 100 MW Solar PP	IPP	100	100	0	632500	
Khulna Area Total				2384	1774	35904873	
128	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	32	611616	Line O/L
129	Bhola 33 MW PP (Venture)	RPP	1*34.50	40	33	545300	Engine problem
130	Bhola 225 MW CCGP	PDB	2*63+1*68	194	86	2056217	Gas shortage
131	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	0	0	0	Contract Expired
132	Payra 1320 MW PP	BPCL	2*622	1244	1030	22336900	Line O/L
133	Bhola Nutan Bidut BD LTD	IPP	220	220	212	4891473	
134	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	17	99	