

Evening Peak Generation and Day Long Energy Data of Power Stations

Date : 18-May-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW				
1	Ghorasal Repowered CCPP Unit-1	PDB	1260	260	0	0	Under maint.	
2	Ghorasal Repowered CCPP Unit-2	PDB	1210	180	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4441500		
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	250	5988109	Condenser problem	
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired	
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	100	2303136		
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.	
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Under maint.	
7	Haripur 350MW CCPP(HPL)	IPP	1*235+1*125	360	322	7836000		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	225	5054750	GT-2 SD, Gas shortage	
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	100	65	1779840	Engine problem	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	115	3156771	Gas shortage & FGMO	
11	Madanganj 102 PP(Summit)	QRPP	6*17	102	96	2103840		
12	Madanganj-55 MW PP(Summit)	ORPP	3*17.08+1*11.3	55	55	1122008		
13	Karanganj 102 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired	
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	409896		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.	
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	GT-2 U/M & Gas shortage	
17	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	91	1787520	Engine problem	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	331	7900503	Engine problem	
19	Sagarigaon 102 MW PP (Digital Po	IPP	1*28.924	102	93	2053480	Gas shortage	
20	Katohli 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage	
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1305720		
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	2270880	Engine problem	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1328882		
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	999717		
25	Bosila 108MW RPCL	IPP	12*9.15	0	0	0		
26	Sumit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.87+4*8.73	80	48	1179060	Engine problem	
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	17	347300	Engine problem	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	705100		
29	Gazipur 52 MW PP	RPCL	6*8.9	52	48	1049760	#REF!	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.	
31	Koida 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	291	6212607		
32	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	210	2405535	Low demand	
33	Bramhangonj 100 MW PP (Aggr	IPP	11*40.959	100	100	1105254		
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	99	1084511		
35	Kodda 149 MW PP Unit-1 (Summ	IPP	8*18.45+8.97	149	149	3426912		
36	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2584800		
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	2404600		
38	Manikganj 162MW (MPGL)	IPP	9*18	162	144	350320	Engine problem	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	0		
40	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	1222200		
Dhaka area Total				5898	3644	78927419		
41	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage	
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
43	Razzan 25 MW PP	RPCL	2*9.2	25	25	411301		
44	Taksonal 20MW PP (SolarTech)Tektan SolarTech Energ	IPP	20	20	0	134865		
44	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	1051200		
45	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	30	657040	Low water level	
46	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4920525		
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.	
48	Sikalbaha 105 MW PP (Baraka S	IPP	6*17.5	105	105	2003090		
49	Hathazari 100 MW Peaking PP	PDB	11*9.9	98	51	403840	Engine problem	
50	Dohazari-Kalash 100 MW Peakin	PDB	6*17	102	51	194546	Fuel shortage	
51	Juldah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	22	528480	Engine problem	
52	Juldah 100 MW PP Unit-3 (Acorn	IPP	8*13.5	100	90	1191360	Engine problem	
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	989544		
54	Malancha Cig. EP2 (Unlited)	IPP	5*8.73+3*9.34	0	10	421920		
54	Chattogram 108 MW PP (ECVP)	IPP	18*7.7	108	87	2011360	Engine problem	
55	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	26680		
56	Anwara 300 MW PP (Unlited)	IPP	17*17+24	300	282	6310364	Engine problem	
57	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1367596		
58	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2366898		
59	Juldah unit-2 (Acorn)	IPP	8*13.6	100	90	1222080		
60	Anilima Energy Ltd.	IPP	6*21.2	116	108	2394927		
Chattogram area Total				2382	1390	28622416		
61	Ashuganj TPP Unit-3	APSCCL	1*150	129	0	0	Contract Expired	
62	Ashuganj TPP Unit-4	APSCCL	1*150	129	0	0	Gas shortage	
63	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage	
62	Ashuganj 225 MW CCPP	APSCCL	1*142+1*75	221	183	4618000	#REF!	
63	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	300	7257000	Gas shortage	
64	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	360	0	0	Gas shortage	
65	Ashuganj 50 MW Peaking PP	APSCCL	1*43.968	45	31	754104	Gas shortage	
66	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	209520	Gas shortage	
67	Ashuganj 195MW PP (APSCCL-UR	IPP	20*9.73+1*16	195	8	200727	Gas shortage	
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	1020408	Engine problem	
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	130	2950690	Engine problem	
70	Titas 50 MW Peaking PP	PDB	6*8.92	50	41	569152	Engine problem	
71	Chandpur 150 MW Peaking PP	PDB	1*108+1*57	163	90	2142870	Machine problem	
72	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	200	4382720		
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	5	245304	Engine problem	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	7	148680	Engine problem	
**	Impoport (Tripura)	Imported power	0	160	138	2936640		
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	32	728900		
76	Jangalia 52 MW PP (Midanaw)	IPP	8*9.32	52	42	1016688	Engine problem	
77	Umtila 25 MW PP (Summit)	SIPP, PDB	3*3.87+2*6.97	25	20	497310	Engine problem	
78	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	150	1010604	Low demand	
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	80	2188800	Engine problem	
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	114	1333080		
81	Bhairab 54.5 MW	IPP	3*18.2	54	35	826920	33 kV feeder problem.	
82	Chandpur 115(Doreen)	IPP	4*18.52+2*2.5	115	83	1685760	Engine problem	
Cumilla Area Total				3074	1738	3675737		
83	RPCL 210MW CCPP	IPP	4*35+1*70	202	135	3020160	Gas shortage	
84	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	418248		
85	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.	
86	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10250		
87	Mymensingh 200 MW PP (Unlited	IPP	9.78*21	200	130	3350400	Low demand	
88	Jamalpur 115 MW PP (Unlited)	IPP	9.78*12	115	115	2571600		
89	Sultkhali 50 MW Solar PP	IPP	50	50	0	324360		
90	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	24	559680		
Mymensingh Area Total				622	424	10256498		
91	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	44	1034000	Machine problem	
92	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	682452	Machine problem	
93	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Under maint.	
94	Shahjibazar 330 MW PP (Baraka)	PDB	3*110	330	0	0	Under maint.	
95	Fenchugonj 51 MW PP (Barakata	RPP	19*2.90	51	53	1283400		
96	Fenchugonj 44MW (Energyprima)	RPP	12*3.35+5*2	50	47	1167336		
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	0	127500	Engine problem	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	50	1398912	Gas shortage	
98	Shahjibazar 96MW PP (Shahjibaz	RPP	32*2.90	86	81	1868160		
99	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.	
100	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	219	5194510		
101	Sylhet 20 MW GTTP	PDB	1*20	20	0	0		
102	Sylhet 50MW PP (EPL)	RPP	27*2	50	33	788740	Gas shortage	
102	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	11	241866	Engine problem	
103	Bibliana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	260	7147500	FGMO	
104	Bibiyanah-III 400 MW CCPP	PDB	400 MW	400	400	5224000		
105	Sylhet 10MW PP (Dash)	RRP	8*1.95	10	10	238500		
106	Bibiyanah South 400 MW	PDB	400 MW	383	400	9391700		
Sylhet Area Total				2477	1638	35788576		
**	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.	
**	Bheramara (HVDC)	Imported power	2*500	1000	895	21960000		
108	Khulna 115 MW (KPCL-2)	ORPP	7*17	115	85	876480	Engine problem	
109	Fardpur 50 MW Peaking PP	PDB	8*6.88	54	45	302400	Engine problem	
110	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.	
111	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	64	632960	Engine problem	
112	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	265	5987520	Gas shortage	
113	Noopara 40 MW PP (Khanjahan A	ORPP	5*8.5	40	40	525000		
113	Noopara 100 MW PP (Bangla Tre	IPP	70*1.4	100	100	675840		
114	Rupsha 105 MW PP (Orion ruspsh	IPP	6*18.445	105	105	2607840		
115	Madhumati 100 MW PP	NWPGCL	6*18	105	105	2582556		
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	648720		
Khulna Area Total				2384	1704	38805016		
117	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	48	760224	Line O/L	
118	Bhola 33 MW PP (Venture)	RPP	1*34.50	40	31	688997	Engine problem	
119	Bhola 225 MW CCPP	PDB	2*63+1*68	194	86	2044962	Gas shortage	
120	Bhola 95 MW PP (Aggreko)	GRPP	96*1.10	0	0	0	Contract Expired	
121	Payra 1320 MW	BPCL	2*622	1244	950	24489200	Line O/L	
122	Bhola Nutan Bidut BD LTD	IPP	2*20	220	191	4919700		
123	United Payra Power Ltd.	IPP	8*18.5+1*9.5	1				