

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel.: 9564667, 9551095

Month May, 2022		Day : Saturday				Date : 21.05.22									
Probable Maximum Demand :		12000 MW		Probable Maximum Generation :		15250 MW		Rule Curve = 78.20 ft.							
Sl. No.	Name of Power Station	Yesterday =	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 73.78 ft.		21.05.22 (Yesterday)		20.05.22 (Yesterday)	Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
						Actual Peak Generation (MW)		Probable Peak Generation (MW)							
						Day	Evening	Day	Evening						
<b>(A) Plants in operation:</b>															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	270	270	270						
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	97	100	100						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.		
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	325	320	330	35			Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling		
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage		
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	96	0	0		110		Under maint.		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	327	300	335	335						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	120	150	150	215			Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	16	90	90						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22						
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	43	40	54	54						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25						
19	Rugganur 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	16	50	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	2	50	105	105						
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	32	132	132						
23	Kanalgat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	60	290	300						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	73	149	149						
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300						
27	Branhanganj 100 MW PP (Agrakro)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
28	Aurahi 100MW PP (Agrakro)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
29	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	2	55	55	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	38	104	104	104						
32	Manikganj 162MW FPP(MPGL)	HFO (IPP)	9x18	162	162	17	162	144	162						
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0						
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55	55						
35	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0						
36	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	0	16	90	90						
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	39	91	90	90						
38	Madanganj 102 PPI(Summit)	HFO (NENP)	6x17	102	102	0	86	96	96						
<b>Dhaka Zone Total</b>				<b>6055</b>	<b>5898</b>	<b>1853</b>	<b>2713</b>	<b>3858</b>	<b>3866</b>	<b>887</b>	<b>770</b>				
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30		200		Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0						
42	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	11	25	25						
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0						
44	Patnaf 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	31	2	50	50						
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	17	105	105	105						
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	210	205	220	220						
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.06+3x8.04	300	300	155	263	280	280						
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	38	76	38	76						
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51						
51	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	51	51						
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			15	0	10	25						
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	24	83	80	83						
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54						
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	91	110	110	110						
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	39	90	100	100						
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	0	0	10	10	10						
58	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	65	108	110	110						
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2282</b>	<b>796</b>	<b>1220</b>	<b>1371</b>	<b>1402</b>	<b>380</b>	<b>330</b>				
59	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	26	30	30						
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	204	172	200	225						
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360			Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	315	330	300	330	30			Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	15	5	40				Gas Shortage		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	26	8	8	169			Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	3	118	150	150						
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	41	41						
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	90	90	90	90						
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	77	200	200						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	34	43	43						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	20	20	20						
76	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+6x1.91+15x1.258	200	200	0	0	200	200						
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	95	110	110						
78	Chowmuhani 113 MW	HFO (IPP)	12'9.79+2'13.1	113	113	15	114	113	113						
79	Bhilaro 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	35	35						
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.415+2x25.428	115	115	0	17	100	100						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.22 (Yesterday)		21.05.22 (Today)		20.05.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	43	43	43	43				
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	42	42		48	GT4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	11	53	51	51				
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	163	163	163	163				
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	55	60	60				
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	81	78	80	80				
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	12	12	12				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	300	341				
102	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400				
103	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	220	400	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	47	42	48	50				
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	0	10	10	10				
<b>Sylhet Zone Total</b>					<b>2522</b>	<b>2477</b>	<b>1579</b>	<b>1838</b>	<b>1850</b>	<b>1893</b>	<b>330</b>	<b>148</b>	
107	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278-1 x 132	410	410	290	270	280	300	140		Gas Shortage	
109	Fandpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	0	35	35				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
111	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	200	200				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	5	105	105	105				
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	32	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0				
116	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	99	15	99				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	904	904	400	919				
<b>Khulna Zone Total</b>					<b>2388</b>	<b>2384</b>	<b>1264</b>	<b>1450</b>	<b>1380</b>	<b>1983</b>	<b>140</b>	<b>0</b>	
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	30	31				
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	84	85	86	86				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	810	1070	900	1050				
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	105	105	220	220				
<b>Barishal Zone Total</b>					<b>1958</b>	<b>1958</b>	<b>1019</b>	<b>1340</b>	<b>1303</b>	<b>1647</b>	<b>0</b>	<b>0</b>	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	35	40				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.8	200	200	0	0	200	200				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	68	68	68				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	24	50	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	36	38				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	130	0	0	220	220		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	180	182	180	182				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	421	410	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	20	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	30	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	42	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2129</b>	<b>2129</b>	<b>824</b>	<b>1038</b>	<b>1366</b>	<b>1589</b>	<b>601</b>	<b>0</b>	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	21	108	110	110				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Taula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energyac)	HFO (IPP)	6*20	115	115	0	40	115	115				
<b>Rangpur Zone Total</b>					<b>800</b>	<b>720</b>	<b>201</b>	<b>323</b>	<b>408</b>	<b>400</b>	<b>184</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>22070</b>	<b>21484</b>	<b>8660.0</b>	<b>11749</b>	<b>13950</b>	<b>15250</b>	<b>3436</b>	<b>1333</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>					<b>8541</b>	<b>11587</b>	<b>13757</b>	<b>15040</b>					
<b>(B) Plants under long term maintenance contract expired</b>													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
<b>Sub-Total: Plants under long term maintenance contract expired</b>					<b>278</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>22348</b>	<b>21484</b>	<b>8660</b>	<b>11749</b>	<b>13950</b>	<b>15250</b>	<b>3436</b>	<b>1333</b>	
<b>(C) Actual data of 20.05.22 (Yesterday) Friday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 11749 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11587 MW, at = 21:00 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 12001 MW, at = 22:00 hrs		Dhaka 4182	4182	0	Mymensingh	898	898	0			
04.	Minimum Generation (Generation end)	: 7503 MW, at = 8:00 hrs		Chattoagram 1227	1227	0	Sylhet	382	382	0			
05.	Day-peak Generation (Generation end)	: 8660 MW, at = 12:00 hrs		Khulna 1489	1489	0	Barishal	401	401	0			
06.	Evening-peak Generation (Generation end)	: 11749 MW, at = 21:00 hrs		Rajshahi 1157	1157	0	Rangpur	616	616	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs		Cumilla 1234	1234	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 4396 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 3052 MW											
c)	Coal supply Limitation	: 184 MW											
b)	Low water level in Kaptai lake	: 200 MW											
c)	Plants under shut down/ maintenance	: 1333 MW											
10.	Total Energy (Generation + India Import)	: 228.30 MKWh											
	By Gas = 130.247 MKWh	By Oil = 45.267 MKWh											
	By Coal = 27.853 MKWh	By Hydro = 0.711 MKWh											
	By Solar= 1.033 MKWh												
11.	Total Gas Supplied	: 961.79 MMCFD											
<b>(D) Forecast of 21.05.22 (Today) Saturday :</b>													
01.	Maximum Demand	: 12000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 15250 MW (Generation end)	05.	Total Generation	: 228.28 MKWh								
03.	Reserve / Shortage	: 3250 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 36.5° C								

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation