

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | | Energy Generated | Remarks |
|------------------------------|---|----------------|--------------------|----------------------------|----------------------|-----------------|------------------|-------------------------|
| | | | | | MW | KWH | | |
| | | | | Unit No. X Capacity | MW | MW | KWH | |
| 1 | Ghorasal Repowered CCPP-Unit-1 | PDB | 1260 | 260 | 0 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCPP-Unit-2 | PDB | 1210 | 180 | 180 | 0 | 0 | Under maint. |
| 3 | Ghorasal TPP Unit-5 | PDB | 1210 | 190 | 180 | 4347000 | | |
| 4 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 270 | 6158282 | | Condenser problem |
| 5 | Ghorasal 78.5 MW PP(MAX) | GRPP | 2*40 | 0 | 0 | 0 | | Contract Expired |
| 6 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 96 | 2237272 | | Engine problem |
| 7 | Haripur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | | Under maint. |
| 8 | Haripur 412 MW CCPP | EGCB | 1*273+1*138 | 412 | 0 | 0 | | Under maint. |
| 9 | Haripur 360MW CCPP(HPL) | IPP | 1*235+1*125 | 360 | 348 | 7950000 | | Machine problem |
| 10 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 225 | 5234850 | | GT-2 S/D, Gas shortage |
| 11 | Meghnaghat 100 MW(IEI) | GRPP | 12*8.9 | 100 | 81 | 1689600 | | Engine problem |
| 12 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 335 | 150 | 3598371 | | Gas shortage & FGMO |
| 13 | Madanganj 102 PP(Summit) | GRPP | 6*17 | 102 | 96 | 2182592 | | Engine problem |
| 14 | Madanganj-55 MW PP(Summit) | IPP | 3*17.08+1*11.3 | 55 | 55 | 1106088 | | |
| 15 | Karanganj 100 MW PP (Powerpac) | GRPP | 8*13.45 | 0 | 0 | 0 | | Contract Expired |
| 16 | Narsingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 354816 | | |
| 17 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | | Under maint. |
| 18 | Siddhirgonj 2*120 MW GTTP | EGCB | 2*105 | 210 | 0 | 0 | | GT-2 U/M & Gas shortage |
| 19 | Siddhirgonj 100 PP(Dutch Bangla) | GRPP | 12*8.9 | 100 | 91 | 1564900 | | Engine problem |
| 20 | Siddhirgonj 335 MW CCPP | EGCB | 1*217+1*118 | 335 | 337 | 7906776 | | |
| 21 | Saagaraj 102 MW PP (Digital Po | IPP | 12*8.924 | 102 | 94 | 1807920 | | Engine problem |
| 22 | Katpali 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 0 | 0 | | Fuel shortage |
| 23 | Kamalaghat 54 MW PP(Banco En | IPP | 3*18 | 54 | 54 | 1260360 | | |
| 24 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 132 | 2978400 | | Engine problem |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 1227307 | | |
| 26 | Nababganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 55 | 1136343 | | |
| 27 | Basia 108MW RPCL | IPP | 12*9.75+1*13.5 | 0 | 0 | 0 | | |
| 28 | Summit Power (Madhabdidi Ashuli) | SIPP, REB | 3*3.67+4*7.3 | 80 | 47 | 1084380 | | Engine problem |
| 29 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 553440 | | Engine problem |
| 30 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 815600 | | |
| 31 | Gazipur 52 MW PP | RPCL | 6*8.9 | 52 | 50 | 1106880 | | #REF! |
| 32 | Tongi 80 MW GTTP | PDB | 1*105 | 105 | 0 | 0 | | Under maint. |
| 33 | Kodda 300 MW PP Unit-2 (Summ | IPP | 18*17.076 | 300 | 278 | 6077916 | | Engine problem |
| 34 | Karanganj 300 MW PP (APR) | IPP | 25*11.4 | 300 | 40 | 989705 | | Low Demand |
| 35 | Bramhangonj 100 MW PP (Aggr | IPP | 114*0.959 | 100 | 100 | 690376 | | |
| 36 | Aurahaat 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 98 | 690336 | | |
| 37 | Kodda 149 MW PP Unit-1 (Summ | IPP | 8*18.45+8.97 | 149 | 114 | 2907360 | | Engine problem |
| 38 | Gazipur 100 MW PP | RPCL | 6*17.5 | 105 | 105 | 2311200 | | |
| 39 | Meghnaghat-104 MW PP (OPCL) | IPP | 18*5.6 | 104 | 104 | 2372160 | | |
| 40 | Manikganj 162MW (MPGL) | IPP | 9*19 | 162 | 162 | 3879360 | | |
| 41 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 0 | | |
| 42 | Kanchan Purbachal Power Gener | IPP | 18.4*3 | 55 | 55 | 1191240 | | |
| Dhaka Area Total | | | | 5898 | 3552 | 77410130 | | |
| 43 | Chattogram TPP-1 | PDB | 1*210 | 180 | 100 | 1800000 | | Gas shortage |
| 44 | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | | Gas shortage |
| 45 | Razzan 25 MW PP | RPCL | 3*8.9 | 25 | 25 | 437547 | | |
| 46 | Teknaf 20MW PP (Solartech/Teknaf Solar)tech Energ | IPP | 20 | 20 | 0 | 0 | | |
| 47 | Patenga 50MW PP (Baraka) | IPP | 8*6.88 | 50 | 50 | 1155840 | | |
| 48 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 75 | 1119980 | | Low water level |
| 49 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 0 | 100630 | | HGPI |
| 50 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 0 | 0 | | Under maint. |
| 51 | Sikalbaha 105 MW PP (Baraka S | IPP | 6*17.5 | 105 | 105 | 2391153 | | |
| 52 | Hahazari 100 MW Peaking PP | PDB | 11*9.9 | 98 | 58 | 287472 | | Engine problem |
| 53 | Dohazari-Kalash 100 MW Peakin | PDB | 6*17 | 102 | 51 | 245201 | | Fuel shortage |
| 54 | Juddah 100 MW Unit-1 (Acom) | GRPP | 8*13.45 | 100 | 10 | 258000 | | Engine problem |
| 55 | Juddah 100 MW PP Unit-3 (Acom) | IPP | 8*13.5 | 100 | 50 | 772800 | | Engine problem |
| 56 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 22 | 531360 | | |
| 57 | Malancha Cig. EP2 (United) | IPP | 5*8.73+3*9.34 | 0 | 24 | 543840 | | |
| 58 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 77 | 1713600 | | Engine problem |
| 59 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 31199 | | |
| 60 | Anwara 300 MW PP (United) | IPP | 17*17.24 | 300 | 278 | 6463418 | | Engine problem |
| 61 | Jodac Power | IPP | 3*18.55+1*3.6 | 54 | 36 | 908131 | | Engine problem |
| 62 | Karnaphuli Power Ltd. | IPP | 18.415*6+6.5 | 110 | 87 | 1952064 | | Engine problem |
| 63 | Juddah unit-2 (Acom) | IPP | 8*13.6 | 100 | 65 | 906240 | | |
| 64 | Anima Energy Ltd. | IPP | 6*21.2 | 116 | 108 | 2480236 | | Engine problem |
| Chattogram Area Total | | | | 2382 | 1222 | 24192266 | | |
| 65 | Ashuganj TPP Unit-3 | APSCCL | 1*150 | 0 | 0 | 0 | | Contract Expired |
| 66 | Ashuganj TPP Unit-4 | APSCCL | 1*150 | 129 | 0 | 0 | | Gas shortage |
| 67 | Ashuganj TPP Unit-5 | APSCCL | 1*150 | 134 | 0 | 0 | | Gas shortage |
| 68 | Ashuganj 225 MW CCPP | APSCCL | 1*142+1*75 | 221 | 210 | 4435000 | | #REF! |
| 69 | Ashuganj 450 MW CCPP(North) | APSCCL | 1*360 | 360 | 290 | 7322100 | | Gas shortage |
| 70 | Ashuganj 450 MW CCPP(South) | APSCCL | 1*360 | 360 | 0 | 0 | | Gas shortage |
| 71 | Ashuganj 50 MW PP | APSCCL | 14*3.968 | 45 | 20 | 674424 | | Gas shortage |
| 72 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 5 | 145440 | | Gas shortage |
| 73 | Ashuganj 195MW PP (APSCCL-UR | IPP | 20*9.73+1*16 | 195 | 8 | 234181 | | Gas shortage |
| 74 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1190473 | | |
| 75 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 100 | 3066109 | | Engine problem |
| 76 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 32 | 390144 | | Engine problem |
| 77 | Chandpur 150 MW CCPP | IPP | 1*108+1*57 | 163 | 100 | 2374130 | | Machine problem |
| 78 | Chandpur 200MW (Desh energy) | IPP | 12*18.4 | 200 | 200 | 3709920 | | |
| 79 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 19 | 399636 | | Engine problem |
| 80 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 6 | 129420 | | Engine problem |
| 81 | Imporrt (Tripura) | Imported power | 0 | 160 | 126 | 2570880 | | |
| 82 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 32 | 387400 | | |
| 83 | Jangalia 52 MW PP (Lakshminav) | IPP | 8*8.92 | 52 | 8 | 203399 | | Fuel shortage |
| 84 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*9.27 | 25 | 21 | 434810 | | Engine problem |
| 85 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 20 | 464448 | | Low Demand |
| 86 | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 114 | 940500 | | |
| 87 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 116 | 1097040 | | |
| 88 | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 35 | 770760 | | 33 kV feeder problem. |
| 89 | Chandpur 115(Doreen) | IPP | 4*18.5+2*22.5 | 115 | 83 | 1248960 | | Engine problem |
| Cumilla Area Total | | | | 3014 | 1876 | 32160184 | | |
| 90 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 140 | 2911120 | | Gas shortage |
| 91 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 17 | 345240 | | |
| 92 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 8 | 0 | 0 | | Under maint. |
| 93 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 10100 | | |
| 94 | Mymensingh 200 MW PP (Unitec | IPP | 9*78.21 | 200 | 181 | 3561600 | | Engine problem |
| 95 | Jamalpur 115 MW PP (United) | IPP | 9*78.12 | 115 | 108 | 2496000 | | Engine problem |
| 96 | Saitkhalai 50 MW Solar PP | IPP | 50 | 50 | 0 | 266000 | | |
| 97 | Tangail Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 24 | 537600 | | |
| Mymensingh Area Total | | | | 622 | 470 | 10117750 | | |
| 98 | Fenchugonj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 44 | 1030000 | | Machine problem |
| 99 | Fenchugonj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 41 | 835112 | | Machine problem |
| 100 | Kushara 163 MW CCPP (KP) | IPP | 1*109+1*54 | 163 | 110 | 2628881 | | ST Under maint. |
| 101 | Shajibazar 330 MW CCPP | PDB | 3*110 | 330 | 157 | 3516000 | | Gas shortage |
| 102 | Fenchugonj 51 MW PP (Barakati | RPP | 19*2.90 | 51 | 0 | 0 | | Gas shortage |
| 103 | Fenchugonj 44MW (Energyprima | RPP | 12*3.35+2 | 50 | 0 | 0 | | Gas shortage |
| 104 | Hobiganj 11MW PP Colidence-E | SIPP, REB | 4*2.90 | 11 | 0 | 0 | | Engine problem |
| 105 | Shajibazar GTTP Unit- 8 & 9 | PDB | 2*35 | 66 | 60 | 1372224 | | Gas shortage |
| 106 | Shajibazar 86MW PP (Shahjibaz | RPP | 32*2.90 | 86 | 50 | 339840 | | Gas shortage |
| 107 | Shajibazar 100 MW GTTP | PDB | 1*100 | 100 | 0 | 0 | | Under maint. |
| 108 | Sylhet 225 MW CCPP (Shahjibaz | PDB | 1*142+1*89 | 231 | 208 | 528480 | | |
| 109 | Sylhet 20 MW GTTP | PDB | 1*20 | 20 | 0 | 0 | | Gas shortage |
| 110 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | | Gas shortage |
| 111 | Shahjahanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 16 | 74448 | | Engine problem |
| 112 | Bikiana-II 341 MW CCPP (Summ | IPP | 1*222+1*119 | 341 | 280 | 6839500 | | FGMO |
| 113 | Bibiyana-III 400 MW CCPP | PDB | 400 MW | 400 | 402 | 9350000 | | |
| 114 | Sylhet 10MW PP (Desh) | RPP | 8*1.95 | 10 | 10 | 240840 | | |
| 115 | Bibiyana South 400 MW | PDB | 400 MW | 383 | 398 | 9402100 | | |
| Sylhet Area Total | | | | 2477 | 1774 | 40899425 | | |
| 116 | Bheramara GTTP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | | Reserve. |
| 117 | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 922 | 22149090 | | |
| 118 | Khulna 115 PP MW (KPCL-2) | GRPP | 7*17 | 115 | 84 | 1824000 | | Engine problem |
| 119 | Fardpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 27 | 184800 | | Gas shortage |
| 120 | Khulna 225 MW CCPP | NWPGL | 1*150+1*75 | 225 | 0 | 0 | | Reserve. |
| 121 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 32 | 512768 | | Low Demand |
| 122 | Bheramara 410 MW CCPP | NWPGL | 1*278+1*132 | 410 | 275 | 6908256 | | Gas shortage |
| 123 | Noapara 40 MW PP (Khanjahan / | GRPP | 5*8.5 | 40 | 40 | 674625 | | |
| 124 | Noapara 100 MW PP (Bangla Tr | IPP | 70*1.4 | 100 | 10 | 63360 | | Low Demand |
| 125 | Rupsha 105 MW PP (Orion rupsh | IPP | 6*18.445 | 105 | 94 | 2028480 | | Engine problem |
| 126 | Maddumali 100 MW PP | NWPGL | 6*18 | 105 | 88 | 1610352 | | Engine problem |