

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022		Day : Saturday				Date : 28.05.22							
Probable Maximum Demand :		13800 MW		Probable Maximum Generation :		14559 MW		Rule Curve = 76.80 ft.					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 74.64 ft		Today = 74.59 ft		27.05.22 (Yesterday)		28.05.22 (Today)					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.05.22 (Yesterday)		28.05.22 (Today)		Gen. shortfall for Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	280	280				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	102	106	105	108				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	303	340	350				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	100	0	100	110	Under maint.	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	333	335	330	330				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	130	150	150	205		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	64	93	93				
16	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	0	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	43	53	53	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	24	50	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	105	105				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	64	132	132				
23	Kanalgat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	78	190	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	46	149	149	149				
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300				
27	Branhanganj 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
28	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	91	92	92				
32	Manikganj 162MW FPP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162				
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	37	47	55	55				
35	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
36	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	32	90	91				
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	76	82	0	85				
38	Madanganj 102 PPI(Summit)	HFO (NENP)	6x17	102	102	82	97	96	96				
Dhaka Zone Total				6055	5898	2616	2961	3916	3885	942	770		
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	38	63	40	40	167		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	5	0	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
44	Patnaf 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	50	50	50				
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	68	105	105	105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	280	300				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	50	25	50				
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	85				
51	Haifazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	60				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			35	36	10	30				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	59	55	75	85				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	35	36				
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	95	93	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	32	64	30	70				
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	0	10	0	10	10				
58	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	96	110	110				
Chattogram Zone Total				2442	2282	978	1087	1052	1288	247	555		
59	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	20	32	32				
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1775	221	221	148	180	215	215	41		Gas Shortage	
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	100	100	360		Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	0	0	90		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	55	55	50		Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	45	95	200	8	100		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	58	128	130	137				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	100	100	100	100				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	72	155	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	16	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	0	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	3	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	20	20				
76	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.056	200	200	0	0	150	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.79+2'3.1	113	113	9	115	9	113				
79	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x23.428	115	115	30	17	90	101				
**	Impport (Tripura)	India		160	160	100	92	143	165				
Cumilla Zone Total				3059	3014	1009	1431	1653	1770	904	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	130	176	150	150	26		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	97	115					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.05.22 (Yesterday)		28.05.22 (Today)		27.05.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT-1 Under maint.	
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakhatullah)	Gas (RPP)	19x2.90	51	51	0	47	0	0				
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	30	110	110		133	Gas Shortage	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0		11	Gas Shortage	
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	60	60	60				
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	157	157	160	160		173	Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	50	0	0		36	Gas Shortage	
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	275	300	341				
102	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	356	398	400	400				
103	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	27	0	0		23	Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	0	25	0	0		25	Gas Shortage	
Sylhet Zone Total					2522	2477	1548	1799	1760	1801	421	176	
107	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	240	265	285	270		145	Gas Shortage	
109	Fandpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	0	35	40				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	45	0	60				
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	105	105	105				
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0				
116	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	77	83	115	115				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	24	40	40				
**	Bheramara (HVDC)	India		1000	1000	918	914	930	930				
Khulna Zone Total					2388	2384	1391	1486	1815	1985	145	0	
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	12	10	10				
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	56	88	60	60				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	780	820	1050	1050				
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	164	225	220	220				
Barishal Zone Total					1958	1958	1052	1178	1407	1600	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.8	200	200	0	0	0	165				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	22	30	30				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	65	65	80				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	34				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	30	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	180	183	180	180				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	423	410	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	52	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	76	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2129	2129	783	1111	1132	1320	601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175		99	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	81	109	113	113				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatala 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	34	115	115	115				
Rangpur Zone Total					800	720	297	399	411	403	184	85	
Sub-total: Plants in operation					22070	21484	10118.0	11869	13675	14559	3470	1586	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9848	11552	13310	14171					
(B) Plants under long term maintenance/contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogra 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					278	0	0	0	0				
Gross Total					22348	21484	10118	11869	13675	14559	3470	1586	
(C) Actual data of 27.05.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	11869	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11552	MW, at = 21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	12083	MW, at = 1:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	9050	MW, at = 8:00 hrs		Dhaka	4109	4109	0	Mymensingh	850	850	0
05.	Day-peak Generation (Generation end)	:	10118	MW, at = 12:00 hrs		Chattoagram	1174	1174	0	Sylhet	501	501	0
06.	Evening-peak Generation (Generation end)	:	11869	MW, at = 21:00 hrs		Khulna	1495	1495	0	Barishal	220	220	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs		Rajshahi	1338	1338	0	Rangpur	833	833	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9098	MW, at = 5:00 hrs		Cumilla	1032	1032	0				
09.	Generation shortfall at evening peak due to :	:								Total	11552	11552	0
a)	Gas limitation	:	3119	MW	13.	Fuel cost :	(a) Gas = 150663472	Taka	(c) Coal = 207543713	Taka			
d)	Coal supply Limitation	:	184	MW		(b) Oil = 923339861	Taka	Total = 1281547046	Taka				
b)	Low water level in Kapali lake	:	167	MW									
c)	Plants under shut down/ maintenance	:	1586	MW	14.	Maximum Temperature in Dhaka was :	35.4° C						
10.	Total Energy (Generation + India Import)	:	256.83	MKWh	15.	Export through East-West interconnections :							
	By Gas = 133.882	MKWh		By Oil = 71.793	MKWh	At evening peak-hour :	10118	MW, at 21:00 hrs					
	By Coal = 24.796	MKWh		By Hydro = 1.031	MKWh	Maximum	-24	MW, at 19:30 hrs					
	By Solar= 0.990	MKWh				Energy	0.082	MKWh					
11.	Total Gas Supplied	:	1012.72	MMCFD									
(D) Forecast of 28.05.22 (Today) Saturday :													
01.	Maximum Demand	:	13800	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14559	MW (Generation end)	05.	Total Generation	:	293.32	MKWh				
03.	Reserve / Shortage	:	759	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	33.7° C						

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation