

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022		Day : Monday				Date : 30.05.22						
Probable Maximum Demand :		14000 MW		Yesterday = 74.58 ft		Probable Maximum Generation :		14908 MW		Rule Curve = 76.40 ft		
Sl. No.	Name of Power Station	Yesterday = Capacity (MW)	74.58 Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.05.22 (Yesterday)		30.05.22 (Today)		29.05.22 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	280	280			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	96	103	105	108			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Hariapur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	337	340	350			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariapur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	326	330	330	330			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	140	150	150	195	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	85	93	93	93			
16	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	53	53	53	53			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	49	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	72	90	105	105			
22	Kodda 150MW PP	HFO (BPD-BRPCL)	9x17.06	149	149	48	150	150	150			
23	Kanalgat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	218	286	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	76	202	300	300			
27	Branngangan 100 MW PP (Agroko)	HSD (IPP)	23x0.85+91x.959	100	100	97	100	100	100			
28	Aurahi 100MW PP (Agroko)	HSD (IPP)	23x0.85+91x.959	100	100	60	98	100	100			
29	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	70	90	92	92			
32	Manikganj 162MW SPP(MPGL)	HFO (IPP)	9x18	162	162	144	144	162	162			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	91	90	91			
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	88	81	88	85			
38	Madanganj 102 PPI(Summit)	HFO (NENP)	6x17	102	102	96	96	96	96			
Dhaka Zone Total				6055	5898	3294	3721	3922	3903	937	765	
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	68	70	70	162		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
44	Patnaf 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	30	50	50			
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	87	105	105	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	265	300	280	300			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	57	25	50			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102			
51	Haifazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	46	0	60			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	27	10	25			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	72	76	75	85			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	35	36			
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	65	30	70			
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	0	10	10	10	10			
58	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	90	108	110	110			
Chattogram Zone Total				2442	2282	962	1287	1082	1330	242	555	
59	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	35	35	32	36			
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	201	203	215	215			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	250	345	300	360			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	360		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	53	30	55	55	25	Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	110	8	16	16	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	123	130	137			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	12	50	50	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	30	54	152	152			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	20	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	20	20			
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.958	200	200	0	80	150	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	0			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.79+2'3.1	113	113	9	115	9	113			
79	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	17	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x23.428	115	115	102	100	90	101			
**	Impoprt (Tripura)	India		160	160	102	112	143	165			
Cumilla Zone Total				3059	3014	1399	1650	1721	1980	835	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	117	128	150	150	74	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	17	20	20			
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	104	103	115	115			
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	178	187	170	200			
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
87	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
88	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	23	24	22	22			
Mymensingh Zone Total				717	62							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.05.22 (Yesterday)		30.05.22 (Today)		29.05.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	GT-1 Under maint.	
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	41	42	42		49	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barikatullah)	Gas (RPP)	19x2.90	51	51	5	11	5	5				
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	41	56	60	60				
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	81	81				
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	219	219	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	20	20				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	24	16	16				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	300	341				
102	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	401	400	400				
103	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	11	0	11	39		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total					2522	2477	1557	1736	1718	1770	142	505	
107	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	240	235	285	270	175		Gas Shortage	
109	Fardpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	33	35	40				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	67	0	67				
111	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105				
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	105	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	21	0	100	0				
116	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	98	115	115				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	919	920	938	938				
Khulna Zone Total					2388	2384	1244	1633	1823	2000	175	0	
118	Barsail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	30	20	20				
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	87	88	88				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	900	1050	1050				
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	163	223	220	220				
Barishal Zone Total					1958	1958	955	1289	1445	1638	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	43	0	0	100		Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.8	200	200	0	56	100	165				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	30	30				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	80	65	80				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	175	174	195	200				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	417	410	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	76	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	94	90	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2129	2129	766	1128	1180	1277	601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	79	101	113	113				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	9	0	0				
147	Majpara, Taula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energyac)	HFO (IPP)	6*20	115	115	90	115	115	115				
Rangpur Zone Total					800	720	351	400	411	403	184	85	
Sub-total: Plants in operation					22070	21484	11023.0	13303	13831	14808	3190	1910	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss													
					10623	12820	13329	14271					
(B) Plants under long term maintenance/contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					278	0	0	0	0				
Gross Total					22348	21484	11023	13303	13831	14808	3190	1910	
(C) Actual data of 29.05.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 13303 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12820 MW, at = 21:00 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 13303 MW, at = 21:00 hrs		Dhaka 4763	4763	0	Mymensingh	1064	1064	0			
04.	Minimum Generation (Generation end)	: 9409 MW, at = 6:00 hrs		Chattoagram 1221	1221	0	Sylhet	526	526	0			
05.	Day-peak Generation (Generation end)	: 11023 MW, at = 12:00 hrs		Khulna 1540	1540	0	Barishal	343	343	0			
06.	Evening-peak Generation (Generation end)	: 13303 MW, at = 21:00 hrs		Rajshahi 1392	1392	0	Rangpur	892	892	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs		Cumilla 1079	1079	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9847 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2844 MW											
c)	Coal supply Limitation	: 184 MW											
b)	Low water level in Kapali lake	: 162 MW											
c)	Plants under shut down/ maintenance	: 1910 MW											
10.	Total Energy (Generation + India Import)	: 272.54 MKWh											
	By Gas = 132.999 MKWh	By Oil = 88.287 MKWh											
	By Coal = 24.478 MKWh	By Hydro = 1.349 MKWh											
	By Solar= 0.841 MKWh												
11.	Total Gas Supplied	: 988.98 MWh											
(D) Forecast of 30.05.22 (Today) Monday :													
01.	Maximum Demand	: 14000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	: 14808 MW (Generation end)	05.	Total Generation	: 286.82 MKWh								
03.	Reserve / Shortage	: 808 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 35.7° C								

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation