

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2022		Day : Saturday				Date : 04.06.22								
Probable Maximum Demand : 14100 MW		Probable Maximum Generation : 15274 MW				Rule Curve = 76.52 ft.								
Sl. No.	Name of Power Station	Yesterday = Nos. of Unit X Capacity (MW)	73.90 ft Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 73.50 ft.		03.06.22 (Yesterday)		04.06.22 (Today)		Gen. shortfall for Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening	Day	Evening				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	0	0	180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	180	0			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	280	280	280	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	98	102	102	102	0			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	0	0	105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	0	0		Contract Expired	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	327	330	340	340	0			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	0	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	396	390	412	412	0			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	0	0	105	105	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	250	170	170	170	0			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	133	150	150	150	0	202	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	40	55	55	55	0			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	94	93	93	93	0			
16	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	18	22	22	22	0			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	80	36	42	53	53	0			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25	25	0			
19	Rugganar 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33	33	0			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	50	50	50	50	0			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105	105	0			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	150	150	150	0			
23	Kanaleghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54	54	0			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	72	291	300	300	300	0			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	114	149	149	149	0			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300	300	0			
27	Branhanganj 100 MW PP (Agrakro)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100	100	0			
28	Aurahi 100MW PP (Agrakro)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100	100	0			
29	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55	55	0			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	25	35	55	55	55	0			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104	104	0			
32	Manikganj 162MW FPP(MPGL)	HFO (IPP)	9x18	162	162	17	162	162	162	162	0			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0	0	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	37	55	55	55	55	0			
35	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0	0	0			
36	Siddhirganj 100 MW PP/Dutch Bangla	HFO (NENP)	12x8.9	100	100	8	92	100	100	100	0			
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	72	85	88	88	88	0			
38	Madanganj 102 PPI(Summit)	HFO (NENP)	6x17	102	102	70	92	96	96	96	0			
Dhaka Zone Total				6055	5898	2620	3484	4161	4163	532	765			
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	68	68	70	70	162	0		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	0		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0	0	0			
42	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25	25	0			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0	0	0			
44	Patnaf 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	11	44	43	43	43	0			
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105	105	0			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	0	0	225	Awaiting for HGPI	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	115	300	300	300	0			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	77	90	90	90	90	0			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51	51	0			
51	Hafhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	43	17	50	50	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22	22	0			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			22	39	25	25	25	0			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	80	85	85	0			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	38	54	54	54	54	0			
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	86	98	110	110	110	0			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100	100	0			
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	0	10	10	10	10	10	0			
58	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	110	110	110	0			
Chattogram Zone Total				2442	2282	758	1072	1286	1350	242	555			
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	0	0		Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	0		Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	32	38	32	36	36	0			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	165	194	215	215	215	0			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	310	340	340	340	0			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	0		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	40	55	55	55	0			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	8	8	8	187	0		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51	51	0			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	81	122	130	140	140	0			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50	50	0			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	150	149	150	150	150	0			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	77	200	200	200	200	0			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22	22	22	0			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	7	11	11	11	0			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33	33	0			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	25	8	25	25	0			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20	20	0			
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.258	200	200	0	0	150	200	200	0			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	114	114	0			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	105	9	105	105	0			
79	Bhiaros 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35	35	0			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	77	83							

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.06.22 (Yesterday)		04.06.22 (Today)		03.06.22 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	0	0	0	70	GT-1 Under maint.	
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	41	41	48	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	5	53	55	53			
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53	ST Under maint.	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11			
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	60	60	60			
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81			
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	191	178	220	220			
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	20	20			
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24			
101	Bibianna-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	310	341			
102	Bibianna-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400			
103	Bibianna South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	7	32	40	40	18	Gas Shortage	
106	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	5	45	30	45			
Sylhet Zone Total					2522	2477	1669	1727	1812	1856	18	601
107	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0	150	Gas Shortage	
108	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	240	260	285	285			
109	Fandpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	40	35	40			
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	0	72			
111	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220			
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100			
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	2	93	105	105			
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	89	105	105			
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	67	0	100	0			
116	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	94	109	100	115			
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40	40			
**	Bheramara (HVDC)	India		1000	1000	906	905	930	930			
Khulna Zone Total					2388	2384	1317	1608	1700	2012	150	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	48	110			
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	27	20	27			
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	85	88	88			
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	740	970	1050	1050			
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150			
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	207	220	220	220			
Barishal Zone Total					1958	1958	1100	1351	1443	1645	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.8	200	200	0	0	100	160			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	35			
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	80	65	90			
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32			
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	50	50			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	173	190	170	170			
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	410	410			
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22			
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	95	113			
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	41	94	94	94			
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0			
Rajshahi Zone Total					2129	2129	730	1115	1157	1278	601	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	37	98	80	100			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Taula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	34	90	115	115			
Rangpur Zone Total					800	720	252	363	378	390	184	85
Sub-total: Plants in operation					22070	21484	9930	12725	14235	15274	2474	2006
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9610	12304	13764	14769				
(B) Plants under long term maintenance/contract expired												
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired
151	Bogra 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired					278	0	0	0	0	0	0	0
Gross Total					22348	21484	9939	12725	14235	15274	2474	2006
(C) Actual data of 03.06.22 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	: 12725 MW, at = 21:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12304 MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	: 12725 MW, at = 21:00 hrs										
04.	Minimum Generation (Generation end)	: 9394 MW, at = 9:00 hrs										
05.	Day-peak Generation (Generation end)	: 9939 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12725 MW, at = 21:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9265 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :	:										
a)	Gas limitation	: 2128 MW										
c)	Coal supply Limitation	: 184 MW										
b)	Low water level in Kapali lake	: 162 MW										
c)	Plants under shut down/ maintenance	: 2006 MW										
	Total Energy (Generation + India Import)	: 262.07 MKWh										
	By Gas =	140.189 MKWh	By Oil =	69.074 MKWh								
	By Coal =	26.060 MKWh	By Hydro =	1.564 MKWh								
	By Solar=	0.667 MKWh										
11.	Total Gas Supplied	: 1061.32 MMCFD										
			Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
			Dhaka	4146	4146	0	Mymensingh	1074	1074	0		
			Chattoagram	1171	1171	0	Sylhet	466	466	0		
			Khulna	1655	1655	0	Barishal	356	356	0		
			Rajshahi	1404	1404	0	Rangpur	873	873	0		
			Cumilla	1159	1159	0						
					Total	12304	12304			0		
			13.	Fuel cost :	(a) Gas = 160054933 Taka	(c) Coal = 218670465 Taka						
					(b) Oil = 897115331 Taka	Total = 1275840729 Taka						
			14.	Maximum Temperature in Dhaka was :	33.2° C							
			15.	Export through East-West interconnections :								
				At evening peak-hour	: 9939 MW, at 21:00 hrs							
				Maximum	: -102 MW, at 20:00 hrs							
				Energy	: 0.327 MKWh							
(D) Forecast of 04.06.22 (Today) Saturday :												
01.	Maximum Demand	: 14100 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 15274 MW (Generation end)	05.	Total Generation	: 290.38 MKWh							
03.	Reserve / Shortage	: 1174 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	37.3° C							

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation